

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7909260452 DOC. DATE: 79/09/21 NOTARIZED: NO
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.

DUCKET #
 05000269
 05000270
 05000287

AUTH. NAME AUTHOR AFFILIATION
 PARKER, W.O. Duke Power Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 REID, R.W. Operating Reactors Branch 4

SUBJECT: Responds to NRC 790718 ltr re reactor cavity annulus seal ring. Seal ring analyzed as potential missile following postulated pipe break inside reactor vessel cavity which indicated missile shielding over vessel is adequate.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: General Distribution for After Issuance of Operating Lic

NOTES: M. CUNNINGHAM - ALL AMENDS TO FSAR & CHANGES TO TECH SPECS.

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
ACTION:	05 BC OAB #4	7	1			
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	12 IRE	2	2	14 TA/EDO	1	1
	15 CORE PERF BR	1	1	17 ENGR BR	1	1
	18 REAC SFTY BR	1	1	19 PLANT SYS BR	1	1
	20 EEB	1	1	21 EPLT TRT SYS	1	1
	22 BRINKMAN	1	1	UELD	1	1
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	23 ACRS	16	16			

SEP 28 1979

TOTAL NUMBER OF COPIES REQUIRED: LTR 38 ENCL 0

K.B.
 MAY

DUKE POWER COMPANY
POWER BUILDING
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

September 21, 1979

TELEPHONE: AREA 704
373-4083

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. R. W. Reid, Chief
Operating Reactors Branch No. 4


Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Sir:

With regard to your letter dated July 18, 1979, concerning the reactor cavity annulus seal ring, the following response is provided.

We have analyzed the seal ring as a potential missile following a postulated pipe break inside the reactor vessel cavity. This analysis indicates that the missile shielding located over the reactor vessel is adequate to prevent this postulated missile from reaching the containment.

Very truly yours,


William O. Parker, Jr.

RLG:scs

790926 0452

Acc'd
S/P