

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8001090333 DOC. DATE: 80/01/02 NOTARIZED: NO DOCKET #
 FACIL: 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 AUTH. NAME: PARKER, W.O. AUTHOR AFFILIATION: Duke Power Co.
 RECIP. NAME: DENTON, H.R. RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation

SUBJECT: Discusses effective full-power days length. Figures for end of Cycle 4 suitable to maintain parameters within range assumed in safety analyses through at least 307 effective full-power days.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: General Distribution for after Issuance of Operating Lic

NOTES: M. CUNNINGHAM - ALL AMENDS TO FSAR & CHANGES TO TECH SPECS.

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
ACTION:	05 BC ORB #4	7				
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	12 I&E	2	2	14 TA/EDO	1	1
	15 CORE PERF BR	1	1	17 ENGR BR	1	1
	18 REAC SFTY BR	1	1	19 PLANT SYS BR	1	1
	20 EEB	1	1	21 EFLT TRT SYS	1	1
	22 BRINKMAN	1	1	EPB-DOR	1	1
	OELD	1	0			
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	23 ACRS	16	16			

JAN 10 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 39 ENCL 0

Handwritten signature and date: MAY

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

January 2, 1980

TELEPHONE: AREA 704
373-4083

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555


Attention: Mr. Robert W. Reid, Chief
Operating Reactors Branch No. 4

Re: Oconee Unit 2
Docket No. 50-270

Dear Sir:

My letter of December 13, 1979 requested extension of the Oconee 2, Cycle 4 from a nominal 297 EFPD to 353 EFPD. Some questions have arisen with regard to the 307 (297 + 10) EFPD length. The current approved Technical Specifications for Oconee 2 are valid through 307 EFPD. The figures which compromised the end of Cycle 4 (Figures 352-1B2, -2B2, -3B2, -4B2 and 2.1-2B and 2.3-2B) have all been verified as suitable to maintain all parameters within the range assumed in the safety analyses through at least 307 EFPD. Additionally, the expected burnup, as requested by members of your Staff, is 31,214 MWd/mtU (EOC maximum assembly)..

Very truly yours,



William O. Parker, Jr.

KRW:scs

A001
5
1/0

P 8001090

333