

KHNPDCDRAIsPEm Resource

From: Ciocco, Jeff
Sent: Tuesday, September 08, 2015 1:22 PM
To: apr1400rai@khnp.co.kr; KHNPDCDRAIsPEm Resource; Harry (Hyun Seung) Chang; Andy Jiyong Oh; Christopher Tyree
Cc: Foli, Adakou; Wunder, George; Lee, Samuel
Subject: APR1400 Design Certification Application RAI 204-8237 (09.05.03 - Lighting Systems)
Attachments: APR1400 DC RAI 204 EEB 8237.pdf; image001.jpg

KHNP,

The attachment contains the subject request for additional information (RAI). This RAI was sent to you in draft form. Your licensing review schedule assumes technically correct and complete responses within 30 days of receipt of RAIs. However, KHNP requests, and we grant, 45 days to respond to this RAI question 09.05.03-8. We may adjust the schedule accordingly.

Please submit your RAI response to the NRC Document Control Desk.

Thank you,

Jeff Ciocco
New Nuclear Reactor Licensing
301.415.6391
jeff.ciocco@nrc.gov



Hearing Identifier: KHNP_APR1400_DCD_RAI_Public
Email Number: 253

Mail Envelope Properties (a49c8592ebb844f79fed99cbeceed71d)

Subject: APR1400 Design Certification Application RAI 204-8237 (09.05.03 - Lighting Systems)
Sent Date: 9/8/2015 1:22:11 PM
Received Date: 9/8/2015 1:22:15 PM
From: Ciocco, Jeff
Created By: Jeff.Ciocco@nrc.gov

Recipients:

"Foli, Adakou" <Adakou.Foli@nrc.gov>
Tracking Status: None
"Wunder, George" <George.Wunder@nrc.gov>
Tracking Status: None
"Lee, Samuel" <Samuel.Lee@nrc.gov>
Tracking Status: None
"apr1400rai@khnp.co.kr" <apr1400rai@khnp.co.kr>
Tracking Status: None
"KHNPDCDRAIsPEm Resource" <KHNPDCDRAIsPEm.Resource@nrc.gov>
Tracking Status: None
"Harry (Hyun Seung) Chang" <hyunseung.chang@gmail.com>
Tracking Status: None
"Andy Jiyong Oh" <jiyong.oh5@gmail.com>
Tracking Status: None
"Christopher Tyree" <Christopher.tyree@aecom.com>
Tracking Status: None

Post Office: R4PWMSMRS03.nrc.gov

Files	Size	Date & Time
MESSAGE	650	9/8/2015 1:22:15 PM
APR1400 DC RAI 204 EEB 8237.pdf		91928
image001.jpg	5040	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

REQUEST FOR ADDITIONAL INFORMATION 204-8237

Issue Date: 09/08/2015

Application Title: APR1400 Design Certification Review – 52-046

Operating Company: Korea Hydro & Nuclear Power Co. Ltd.

Docket No. 52-046

Review Section: 09.05.03 - Lighting Systems

Application Section:

QUESTIONS

09.05.03-5

NUREG-0800, Section 9.5.3 states: "The emergency lighting system(s) is acceptable if the integrated design of the system(s) will provide adequate emergency lighting in all areas required for firefighting, control, and maintenance of equipment used for implementing safe shutdown of the plant during all plant operating conditions, and the access routes to and from these areas." In Section 9.5.3.2 of the DCD Tier 2, the applicant provided the following areas where the emergency AC [alternating current] lighting system is provided: the main control room, radwaste control room, emergency technical support center, operational support center, remote shutdown room, emergency diesel generator room, Class 1E battery room, Class-1E switchgear room, and their access aisles for the safety-related equipment. The staff determined that the applicant may not have identified all areas where the emergency lighting systems should be provided.

Please identify any other areas required for firefighting, control, and maintenance of equipment used for implementing safe shutdown of the plant during all plant operating conditions and the access routes to and from these areas, where the emergency lighting system will be provided.

09.05.03-6

DCD Tier 2, Section 9.5.3.2 states: "The security lighting is powered from offsite and backed up by the AAC source upon loss of offsite power. The COL applicant is to provide offsite power for the security lighting system." However, DCD Tier 2, Section 1.8.1, Table 1.8-2, COL 9.5(14) states: "The COL applicant is to provide electric power for the security lighting system."

Please modify the statement "electric power" in Table 1.8-2 to indicate that the power source for the security lighting system is "offsite power," as stated in section 9.5.3.2.

09.05.03-7

DCD Tier 2, Section 9.5.3.3 stated that the self-contained battery lighting located in Class 1E equipment areas meets seismic Category I requirements. The staff determined that other lighting fixtures located in the vicinity of safety-related equipment may not be supported so that the fixtures may adversely impact the safety-related equipment when subjected to seismic loading of a safe shutdown earthquake.

Please provide the seismic category classification for all other lighting fixtures (normal, emergency AC, and emergency direct current (DC) lighting systems) located in the vicinity of safety-related equipment.

09.05.03-8

DCD Tier 2, Section 9.5.3.4 states: "The emergency lighting is inspected and tested periodically."

Please identify the programs that will address inspection and testing of the emergency AC and DC lighting systems.

