

OCONEE NUCLEAR STATION
MONTHLY OPERATING STATUS REPORT

March 1989

1. Personnel Exposure

For the month of March, no individuals exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for March has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for March has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

8905260153 890515
PDR ADOCK 05000269
R PDR

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-269

UNIT NAME OCONEE 1

DATE 05/14/89

COMPLETED BY J. J. MEAD

TELEPHONE (704)-373-5762

REPORT MONTH March 1989

Revision 1

N O .	DATE	(1) T Y P E	DURATION HOURS	(2) R E A S O N	(3) M E T H O D O F S H U T D O W N R/X	LICENSE EVENT REPORT NO.	(4) S Y S - T E M C O D E	(5) C O M P O N E N T C O D E	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
8-P	89- 3- 1	F	--	A	--		HC	VALVEX	POWER REDUCTION TO REMOVE UNIT FROM SERVICE TO REPAIR MAIN STEAM ATMOSPHERIC DUMP VALVE
5	89- 3- 1	F	85.05	A	1		HC	VALVEX	UNIT REMOVED FROM SERVICE TO REPAIR MAIN STEAM ATMOSPHERIC DUMP VALVE (1MS-155)
9-P	89- 3- 5	F	--	A	--		XX	VALVEX	REPAIR VARIOUS SECONDARY VALVES

(1)

F Forced
S Scheduled

(2)

Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

(3)

Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

(4)

Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For Licensee
 Event Report (LER)
 File (NUREG-0161)

(5)

Exhibit I - Same Source