

OCONEE NUCLEAR STATION
MONTHLY OPERATING STATUS REPORT

June 1989

1. Personnel Exposure

For the month of June, no individual(s) exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for June has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for June has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

8908220315 890815
PDR ADCK 05000269
R FDC