

OCONEE NUCLEAR STATION  
MONTHLY OPERATING STATUS REPORT

July 1989

1. Personnel Exposure

For the month of July, no individual(s) exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for July has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for July has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

8909190234 890831  
PDR ADOCK 05000249  
R PDC