

OCONEE NUCLEAR STATION
MONTHLY OPERATING STATUS REPORT

October 1990

1. Personnel Exposure -

For the month of October, no individual(s) exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for October has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for October has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this list.

9012200060 901214
PDR ADOCK 05000269
R PDR

REVISION 1

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-270

UNIT NAME OCONEE 2

DATE 11/15/90

COMPLETED BY S. W. MOSER

TELEPHONE (704)-373-5762

PAGE 1 OF 2

REPORT MONTH October 1990

N O	DATE	(1) T Y P E	DURATION HOURS	(2) R E A S O N	(3) M E T H O D O F S H U T D O W N R/X	LICENSE EVENT REPORT NO.	(4) S Y S T E M C O D E	(5) C O M P O N E N T C O D E	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
1	90-10- 1	S	576.00	C	1		RC	FUELXX	END-OF-CYCLE '11' REFUELING OUTAGE
2	90-10-25	S	53.77	C	--		RC	FUELXX	REFUELING OUTAGE EXTENSION
9-P	90-10-27	S	--	C	--		RC	FUELXX	PLACE GENERATOR ON-LINE FOLLOWING END-OF-CYCLE '11' REFUELING OUTAGE
10-P	90-10-27	S	--	B	--		HA	TURBIN	HOLDING POWER IN PREPARATION FOR TURBINE OVERSPEED TRIP TEST
3	90-10-27	S	1.20	B	1		HA	TURBIN	TURBINE OVERSPEED TRIP TEST
11-P	90-10-27	S	--	B	--		IE	INSTRU	HOLDING LOAD INCREASE FOR POWER RANGE NUCLEAR INSTRUMENTATION CALIBRATION
12-P	90-10-28	S	--	B	--		IE	INSTRU	HOLDING LOAD INCREASE FOR NUCLEAR INSTRUMENTATION CALIBRATION
13-P	90-10-28	F	--	A	--		RB	CRDRVE	HOLDING POWER DUE TO CONTROL ROD DRIVE OUT INHIBIT DUE TO ASYMMETRIC ROD FAULT

1)
F Forced
S Scheduled

(2)
Reason:
A-Equipment Failure (Explain)
B-Maintenance or test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operator Error (Explain)
H-Other (Explain)

(3)
Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Other (Explain)

(4)
Exhibit G - Instructions
for Preparation of Data
Entry Sheets For License
Event Report (LER)
File (NUREG-0161)

(5)
Exhibit I - Same Source