

OCONEE NUCLEAR STATION
MONTHLY OPERATING STATUS REPORT

July 1991

1. Personnel Exposure -

For the month of July, no individual(s) exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for July has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for July has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this list.