

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9207280010 DOC. DATE: 92/07/22 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
 50-413 Catawba Nuclear Station, Unit 1, Duke Power Co. 05000413
 50-414 Catawba Nuclear Station, Unit 2, Duke Power Co. 05000414

AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H.B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Responds to NRC Bulletin 92-001, "Failure of Thermo-Lag 330 Fire Barrier Sys to Maintain Cabling in Wide Cable Trays & Small Conduits Free from Fire Damage." Neither Oconee nor Catawba use Thermo-Lag matl. Bulletin inapplicable to units.

DISTRIBUTION CODE: IE11D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Bulletin Response (50 DKT)

NOTES: LPDR 2cys AMDTS to FSAR. ASLB 1cy. 05000413
 LPDR 2cys AMDTS to FSAR. ASLB 1cy. 05000414

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 LA	1 0	PD2-3 PD	1 1
	WIENS, L	1 1	MARTIN, R	1 1
INTERNAL:	AEOD/DOA	1 1	NRR/DET/EMEB 7E	1 1
	NRR/DOEA/OEAB11	1 1	NRR/DOEA/OGCB11	1 1
	NRR/DREP/PEPB9D	1 1	NRR/DST/ 8E2	1 1
	NRR/PMAS/ILRB12	1 1	<u>REG FILE</u> 02	1 1
	RES/DSIR/EIB	1 1	RGN2 FILE 01	1 1
EXTERNAL:	NRC PDR	1 1	NSIC	1 1
NOTES:		3 3		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 18 0

Handwritten signature/initials

Duke Power Company
P.O. Box 1006
Charlotte, NC 28201-1006

HAL B. TUCKER
Senior Vice President
Nuclear Generation
(704)382-4531



DUKE POWER

July 22, 1992

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Subject: Oconee Nuclear Station Units 1, 2, and 3
Docket Nos. 50-269, -270, -287
Catawba Nuclear Station Units 1 and 2
Docket Nos. 50-413, -414
Response to NRC Bulletin No. 92-01
Failure of Thermo-Lag 330 Fire Barrier System to Maintain Cabling
in Wide Cable Trays and Small Conduits Free From Fire Damage

Gentlemen:

The purpose of this letter is to submit the responses for Oconee Nuclear Station and Catawba Nuclear Station to NRC Bulletin 92-01, "Failure of Thermo-Lag 330 Fire Barrier System to Maintain Cabling in Wide Cable Trays and Small Conduits Free From Fire Damage," dated June 24, 1992. The response for McGuire Nuclear Station will be sent separately.

The subject bulletin identified three actions that addressees take immediately upon receiving this bulletin.

The first and second actions apply to all plants that use either 1-hour or 3-hour preformed Thermo-Lag 330 panels and conduit shapes. Oconee Nuclear Station and Catawba Nuclear Station do not use this material in their plants and, therefore, these actions do not apply to them.

The third action requires each licensee to provide written notification stating whether it has or does not have Thermo-Lag 330 fire barrier systems installed in their facilities. Oconee Nuclear Station and Catawba Nuclear Station do not have this material used for fire barriers in their plants. This letter fulfills this third action requirement.

9207280010 920722
PDR ADDCK 05000269
Q PDR


Printed on recycled paper

IF/11
1/0

Document Control Desk
July 22, 1992
Page 2

I declare under penalty of perjury that the statements set forth herein are true and correct to the best of my knowledge.

Very Truly Yours,



Hal B. Tucker
Senior Vice President
Nuclear Generation

rpc

Attachments

cc: S. D. Ebnetter
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

L. A. Wiens
Project Manager
Office of Nuclear Reactor Regulation
Mail Stop 14 H25, NRR/PD2-3
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

R. E. Martin
Project Manager
Office of Nuclear Reactor Regulation
Mail Stop 14 H25, NRR/PD2-3
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

P. E. Harmon
NRC Senior Resident Inspector
Oconee Nuclear Station

W. T. Orders
NRC Senior Resident Inspector
Catawba Nuclear Station