

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8402220517 DOC. DATE: 84/02/13 NOTARIZED: YES DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H. B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Application for amend to Licenses DPR-38, DPR-47 & DPR-55
 revising Tech Specs to establish degraded mode for
 emergency condenser cooling water sys.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 312
 TITLE: OR Submittal: General Distribution

NOTES: AEOD/Ornstein: lcy.
 AEOD/Ornstein: lcy.
 AEOD/Ornstein: lcy.

*w/ check \$48.00
 #648175*

05000269
 05000270
 05000287

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	NRR ORB4 BC	01	7	7					
INTERNAL:	ELD/HDS4		1	0	NRR/DE/MTEB		1	1	
	NRR/DL DIR		1	1	NRR/DL/ORAB		1	0	
	NRR/DSI/METB		1	1	NRR/DSI/RAB		1	1	
	<u>REG FILE</u>	04	1	1	RGN2		1	1	
EXTERNAL:	ACRS	09	6	6	LPDR	03	1	1	
	NRC PDR	02	1	1	NSIC	05	1	1	
	NTIS		1	1					
NOTES:			1	1					

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

February 13, 1984

TELEPHONE
(704) 373-4531

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4

Subject: Oconee Nuclear Station
Units 1, 2, and 3
Docket Nos. 50-269, -270, -287

Dear Sir:


Pursuant to 10 CFR 50 §50.90, please find attached (Attachment 1) a proposed amendment to the Oconee Facility Operating License and revisions to the Oconee Nuclear Station Technical Specifications.

The proposed amendment would revise Technical Specification 3.4.5, establishing a degraded mode for the Emergency Condenser Cooling Water (ECCW) System. This would allow for continued operation of the Oconee units for a limited period of time, if the ECCW System becomes inoperable. The supporting technical justification is provided in Attachment 3.

Regarding the issue of no significant hazards consideration, an analysis of the proposed amendment was performed in accordance with the standards contained in §50.92. The results of the analysis conclude that the proposed amendment does not involve a significant hazard. Please find attached (Attachment 2) the No Significant Hazards Consideration evaluation. Further, Duke is forwarding a copy of this application to the South Carolina Department of Health and Environmental Control for review and, as appropriate, subsequent consultation with the staff.

This proposed revision to the Oconee Technical Specifications is considered to consist of one Class III and two Class I license amendments. Accordingly, please find enclosed a check in the amount of \$4,800 for the applicable licensing fees.

Very truly yours,



Hal B. Tucker

PFG/php

Attachment

Handwritten notes:
A001
w/check
684175
\$4,800

8402220517	840213
PDR	ADOCK 05000269
P	PDR

Mr. Harold R. Denton, Director
February 13, 1984
Page 2

cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303


Mr. John F. Suermann
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. J. C. Bryant
NRC Resident Inspector
Oconee Nuclear Station

Mr. Hayward Shealey, Chief
Bureau of Radiological Health
South Carolina Department of Health and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201


Mr. Harold R. Denton, Director
February 13, 1984
Page 3

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



Hal B. Tucker, Vice President

Subscribed and sworn to before me this 13th day of February, 1984.


Notary Public

My Commission Expires:

September 20, 1984