

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8408200059 DOC. DATE: 84/08/08 NOTARIZED: YES DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H.B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Application for amend to Licenses DPR-38, DPR-47 & DPR-55,
 revising air lock testing frequency from quarterly to
 semiannually, fee encl.

DISTRIBUTION CODE: A017S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+6
 TITLE: OR Submittal: Append J Containment Leak Rate Testing

NOTES: AEOD/Ornstein: 1cy. 05000269
 OL: 02/06/73
 AEOD/Ornstein: 1cy. 05000270
 OL: 10/06/73
 AEOD/Ornstein: 1cy. 05000287
 OL: 07/19/74

-NO Check Rec'd

RECIPIENT
 ID CODE/NAME
 NRR ORB4 BC 01

COPIES
 LTTR ENCL
 7 7

RECIPIENT
 ID CODE/NAME

COPIES
 LTTR ENCL

INTERNAL: ADM-LFMB
 NRR/DSI/ASB
REG FILE 04

1 0
 1 1
 1 1

ELD/HDS4 08
 NRR/DSI/CSB 06
 RGN2

1 1
 1 1
 1 1

EXTERNAL: ACRS 07
 NRC PDR 02
 NTIS

10 10
 1 1
 1 1

LPDR 03
 NSIC 05

1 1
 1 1

NOTES: 1 1

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

August 8, 1984

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4

Subject: Oconee Nuclear Station
Docket Nos. 50-269, 50-270, 50-287


Dear Sir:

Pursuant to 10 CFR §50.90, please find attached (Attachment 1) a proposed amendment to the Oconee Facility Operating License and revisions to the Oconee Nuclear Station Technical Specifications. The proposed amendment would revise Technical Specification 4.4.1.5.2(a) and (involves a change of the air lock testing frequency from quarterly to semiannually). The supporting technical justification is provided in Attachment 3.

Please note that the proposed amendment would change the Technical Specification 4.4.1.5.2(a) to conform to the requirements of 10 CFR 50, Appendix J and results in very minor changes to facility operation clearly in keeping with the regulations. Duke has determined that the proposed amendment warrants a No Significant Hazards Consideration (Attachment 2). A copy of this application is also forwarded to the South Carolina Department of Health and Environmental Control for review and appropriate, subsequent consultation with the staff.

Pursuant to 10 CFR 170.21, please find enclosed a check in the amount of \$150.00 for the application fee.


Very truly yours,



Hal B. Tucker

MAH:slb

Attachment



No Check Rec'd

A017



11

Mr. Harold R. Denton, Director

August 8, 1984

Page 2

cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Ms. Helen Nicolaras
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. J. C. Bryant
NRC Resident Inspector
Oconee Nuclear Station


Mr. Hayward Shealey, Chief
Bureau of Radiological Health
South Carolina Department of Health and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Mr. Harold R. Denton, Director

August 8, 1984

Page 3

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



Hal B. Tucker, Vice President

Subscribed and sworn to before me the 8th day of August, 1984.


Notary Public

My Commission Expires:

September 20, 1984