

Duke Power Company
Oconee Nuclear Station
Attachment 1
Proposed Technical Specification Revision

Pages

6.1-6

8506040292 850529
PDR ADOCK 05000269
P PDR

TABLE 6.1-1

MINIMUM OPERATING SHIFT REQUIREMENTS
(With Fuel in the Three Reactor Vessels)

	<u>One Unit Operating*</u>	<u>Two Units Operating*</u>	<u>All Units Operating*</u>	<u>All Units Shutdown</u>
Shift Supervisor	1	1	1	1
Additional SRO	1	2**	2	None
Shift Technical Advisor (SRO)	1	1	1	None
Reactor Operator	4	5**	5	3
Nuclear Equipment Operator	4	5	5	5

*Above cold shutdown.

**Only one SRO and four Reactor Operators required if both units are operated from one Control Room.

Duke Power Company
Oconee Nuclear Station
Attachment 2
No Significant Hazards Consideration Evaluation

No Significant Hazards Consideration Evaluation

Duke Power Company (Duke) has made the determination that this amendment request involves a No Significant Hazards Consideration by applying the standards established by the Commission's regulations in 10 CFR 50.92. This ensures that operation of the facility in accordance with the proposed amendment would not:

- 1) Involve a significant increase in the probability or consequences of an accident previously evaluated; or
- 2) Create the possibility of a new or different kind of accident from any accident previously evaluated; or
- 3) Involve a significant reduction in margin of safety.

The Commission has provided guidance concerning the application of these standards by providing certain examples (48 FR 14870). Examples (ii) and (vii) of the types of amendments considered not likely to involve significant hazards consideration are applicable to this amendment request. These specific examples involve amendment requests that are considered to be a change that constitutes an additional limitation, or control not presently included in the technical specifications and, a change to make a license conform to changes in the regulations, where the license change results in very minor changes to facility operations clearly in keeping with the regulations, respectively.

The proposed Technical Specification amendment addressed in this submittal has been determined by Duke to be a more stringent requirement and a change in conformance to the changes in regulations. Briefly, the proposed amendment would revise Technical Specification Table 6.1-1 to reflect an increase in the required minimum number of nuclear equipment operators in conformance to the NUREG-0737, Item I.A.1.3, and results in very minor changes to facility operations clearly in keeping with the regulations.

Duke has determined, based on consideration that the requested amendment is a conformatory change in nature, that the revision does not involve a significant increase in the probability or consequences of accidents previously considered, nor create the possibility of a new or different kind of accident, and will not involve a significant decrease in a safety margin. Therefore, Duke concludes that there is not significant hazards consideration involved in this amendment request.