

# REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8602240334 DOC. DATE: 86/02/06 NOTARIZED: YES DOCKET #  
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269  
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270  
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION  
 TUCKER, H. B. Duke Power Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director (post 851125  
 STOLZ, J. F. Office of Nuclear Reactor Regulation, Director (post 851125

SUBJECT: Application for amends to Licenses DPR-38, DPR-47 & DPR-55,  
 changing Tech Specs to enable testing of initiation control  
 circuitry in reactor bldg spray sys W/o energizing pump. Fee  
 paid.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+6  
 TITLE: OR Submittal: Inservice Inspection/Testing

NOTES: AEOD/Ornstein: 1cy. *Rec'd w/ chet 8/50.00* 05000269  
 AEOD/Ornstein: 1cy. 05000270  
 AEOD/Ornstein: 1cy. 05000287

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PWR-B PD6 PD 01	5 5	PWR-B EB	1 1
	NICOLARAS, H	1 1		
INTERNAL:	ADM/LFMB	1 0	ELD/HDS4	1 0
	NRR BWR ADTS	1 1	NRR BWR EB	1 1
	NRR PWR-A ADTS	1 1	NRR PWR-A EB	1 1
	NRR PWR-B ADTS	1 1	NRR PWR-B EB	1 1
	NRR/TAMB	1 1	<u>REG FILE</u> 04	1 1
	RGN2	1 1		
EXTERNAL:	24X	1 1	LPDR 03	1 1
	NRC PDR 02	1 1	NSIC 05	1 1
NOTES:		1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 23 ENCL 21

DUKE POWER COMPANY

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

February 6, 1986

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Attention: Mr. John F. Stolz, Chief  
Operating Reactors Branch No. 4

Subject: Oconee Nuclear Station  
Docket Nos. 50-269, -270, -287

Dear Sir:


Pursuant to 10CFR50, § 50.90 please find attached a proposed amendment to the Oconee Facility Operating License and revision to the Oconee Nuclear Station Technical Specifications (Attachment 1). This proposal consists of a change to Technical Specification (T.S.) 4.5.2.1.1(a), Reactor Building Spray System.

The intent of T.S. 4.5.2.1.1 is to test the initiation control circuitry. The proposed T.S. revision would provide for testing of the initiation control circuitry without actually energizing the pump. This is consistent with the requirements specified by T.S. 4.5.1.1.1. Verification of pump performance is accomplished every three months per Oconee's Inservice Test program.

Duke Power Company (Duke) has determined the attached proposed amendment as having No Significant Hazards Consideration. Please find attached the No Significant Hazards Consideration Evaluation (Attachment 2) and the supporting Technical Justification (Attachment 3). Duke is forwarding a copy of this application to the South Carolina Department of Health and Environmental Control for review and, as appropriate, subsequent consultation with the staff.

Pursuant to 10 CFR 170.21, please find enclosed a check in the amount of \$150.00 for the application fee.

Very truly yours,



Hal B. Tucker

PJN

Attachments

8602240334 860206  
PDR ADDCK 05000269  
P PDR

A047  
1/1  
Rec'd w/check \$150.00

Mr. Harold R. Denton, Director

cc: Dr. J. Nelson Grace, Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Ms. Helen Nicolaras  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Mr. J. C. Bryant  
NRC Resident Inspector  
Oconee Nuclear Station

Mr. Heyward Shealy, Chief  
Bureau of Radiological Health  
South Carolina Department of  
Health & Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201


Mr. Harold R. Denton, Director

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



Hal B. Tucker, Vice President

Subscribed and sworn to before me this 6th day of February 1986



Notary Public

My Commission Expires:

September 20, 1989