

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8708040424 DOC. DATE: 87/07/28 NOTARIZED: YES DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
 AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H. B. Duke Power Co.

RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-38, DPR-47 & DPR-55,
 deleting unnecessary requirements to test redundant
 components for operability prior to initiating maint. Fee
 paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+18
 TITLE: DR Submittal: General Distribution

NOTES: AEOD/Ornstein: 1cy. 05000269
 AEOD/Ornstein: 1cy. 05000270
 AEOD/Ornstein: 1cy. 05000287

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 LA	1 0	PD2-3 PD	5 5
	PASTIS, H	1 1		
INTERNAL:	ARM/DAF/LFMB	1 0	NRR/DEST/ADE	1 1
	NRR/DEST/ADS	1 1	NRR/DEST/CEB	1 1
	NRR/DOEA/TSB	1 1	NRR/PMAS/ILRB	1 1
	DGC/HDS2	1 0	<u>REG FILE</u> 01	1 1
	RES/DE/EIB	1 1		
EXTERNAL:	EG&G BRUSKE, S	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC	1 1

NOTES: 1 1
 w/ check \$150.00
 #18408798

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

July 28, 1987

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Redundant Component Testing and
Administrative Technical Specification Changes

Gentlemen:

Pursuant to 10CFR 50, §50.90, please find attached (Attachment 1) a proposed amendment to the Oconee Nuclear Station (ONS) Facility Operating Licenses and revisions to the ONS Technical Specifications (T.S.). The proposed amendments delete unnecessary requirements to test redundant components for operability prior to initiating maintenance on any component of the High Pressure Injection (HPI) System, Low Pressure Injection (LPI) System, Reactor Building Cooling (RBC) System, Reactor Building Spray (RBS) System, or the Low Pressure Service Water (LPSW) System (T.S. 3.3). In addition, several administrative changes are included in this request.

Specific administrative changes are:

- o T.S. 3.7.2 Auxiliary Electrical Systems (page 3.7-3) is updated by the deletion of an expired footnote.
- o T.S. Table 4.1-2 Minimum Equipment Test Frequency (page 4.1-9) is clarified by the addition of a footnote which indicates that functional testing of Refueling System Interlocks (Item 4) is applicable only to those interlocks associated with the Reactor Building Purge System.
- o T.S. 4.6.4 Emergency Power Periodic Testing (page 4.6-1) is updated by the deletion of an expired footnote.
- o T.S. 4.18 Snubbers (page 4.18-1 and 4.18-2) is updated by the deletion of expired footnotes.

8708040424 870728
PDR ADCK 05000269
P PDR

Handwritten:
A001
w/checkbox
15000
#18408798


Document Control Desk
July 28, 1987
Page 2

Duke has determined the attached proposed amendment as having no Significant Hazards Considerations. Attachment 2 provides the No Significant Hazards Consideration Evaluation. Attachment 3 provides the supporting Technical Justification.

Duke is forwarding a copy of this application to the South Carolina Department of Health and Environmental Control for review and, as appropriate, subsequent consultation with the Staff.

Pursuant to 10CFR 170, \$170.12, please find enclosed a check in the amount of \$150.00 for the application fee.

Very truly yours,



Hal B. Tucker

PJN/199/jgc

Attachment

xc: Dr. J. Nelson Grace
Regional Administrator
U.S. Nuclear Regulatory
Commission - Region II
101 Marietta St. NW
Suite 2900 - Atlanta, GA 30323

Ms. Helen Pastis
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Heyward Shealy, Chief
Bureau of Radiological Health
S.C. Dept. of Health and
Environmental Control
2600 Bull Street
Columbia, S.C. 29201

Mr. J.C. Bryant
NRC Resident Inspector
Oconee Nuclear Station

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the Oconee Nuclear Station License Nos. DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.

Hal B. Tucker

Hal B. Tucker, Vice President

Subscribed and sworn to before me this 28th day of July, 1987.

Linda L. Kessler
Notary Public

My Commission Expires:

May 1, 1989

