

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8708200027 DOC. DATE: 87/08/14 NOTARIZED: YES DOCKET #  
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269  
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270  
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION  
 TUCKER, H. B. Duke Power Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-38, DPR-47 & DPR-55,  
 revising Tech Spec 3.4.4 to raise min upper surge tank level  
 from 5 to 6 ft. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+6  
 TITLE: OR Submittal: General Distribution

NOTES: AEOD/Ornstein: 1cy. 05000269  
 AEOD/Ornstein: 1cy. 05000270  
 AEOD/Ornstein: 1cy. 05000287

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 LA	1 0	PD2-3 PD	5 5
	PASTIS, H	1 1		
INTERNAL:	ARM/DAF/LFMB	1 0	NRR/DEST/ADS	1 1
	NRR/DEST/CEB	1 1	NRR/DEST/MTB	1 1
	NRR/DOEA/TSB	1 1	NRR/PMAS/ILRB	1 1
	OGC/HDS2	1 0	<u>REG FILE</u> 01	1 1
	RES/DE/EIB	1 1		
EXTERNAL:	EG&G BRUSKE, S	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC	1 1

NOTES:

1 1

w/ check \$150

#18408912

**DUKE POWER COMPANY**

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

August 14, 1987

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Subject: Oconee Nuclear Station  
Docket Nos. 50-269, -270, -287

Dear Sir:


Pursuant to 10 CFR 50, §50.90 please find attached a proposed amendment to the Oconee Facility Operating License and a revision to the Oconee Nuclear Station Technical Specifications (Attachment 1). The proposed amendment would revise Technical Specification 3.4.4 to raise the minimum upper surge tank level from 5 feet to 6 feet. The 6 feet level setpoint includes an allowance for instrument error. The amendment request also includes a revision to the bases of Technical Specification 3.4. The table of emergency feedwater flow vs. time required to remove decay heat and reactor coolant pump heat following reactor trip from 102% rated power has been revised. The revised table supercedes the table presently shown in the bases of Technical Specification 3.4.

Pursuant to 10 CFR 50.91, Duke Power Company has performed a No Significant Hazards Consideration evaluation in accordance with the standards in §50.92. This analysis (Attachment 2) has determined that the proposed amendment request does not represent a significant hazards consideration.

Duke is forwarding a copy of this application to the South Carolina Department of Health and Environmental Control for review and, as appropriate, subsequent consultation with the NRC Staff.

Pursuant to 10 CFR 170, §170.12, please find attached a check in the amount of \$150.00 for application fee.

Very truly yours,



Hal B. Tucker

MAH/65/sbn

Attachments

8708200027 870814  
PDR ADOCK 05000269  
P PDR

*Handwritten notes:*  
H001  
w/ check  
\$150  
#18408912

U. S. Nuclear Regulatory Commission

August 14, 1987

Page Two


xc: Dr. J. Nelson Grace, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Mr. J. C. Bryant  
NRC Resident Inspector  
Oconee Nuclear Station

Mr. Heyward Shealy, Chief  
Bureau of Radiological Health  
South Carolina Department of Health &  
Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201


Ms. Helen Pastis  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47, and DPR-55; and that all statements and matter set forth therein are true and correct to the best of his knowledge.



Hal B. Tucker, Vice President

Subscribed and sworn to before me this 14th day of August, 1987.



Notary Public

My Commission Expires:

May 1, 1989

