

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8801210001 DDC DATE: 88/01/06 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
 AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H. B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-38, DPR-47 & DPR-55,
 revising Tech Specs 3.15 re control room pressurization &
 filtering sys & 4.12 on testing of sys, per Generic Ltr 83-37
 re NUREG-0737. Fee paid.

DISTRIBUTION CODE: A003D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+16
 TITLE: DR/Licensing Submittal: Suppl 1 to NUREG-0737(Generic Ltr 82-33)

NOTES: AEOD/Ornstein: 1cy. 05000269
 AEOD/Ornstein: 1cy. 05000270
 AEOD/Ornstein: 1cy. 05000287

| RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|---------------------------|---------------------|---------------------------|---------------------|
| PD2-3 LA | 1 1 | PD2-3 PD | 7 7 |
| PASTIS, H | 1 1 | | |
| INTERNAL: ARM/DAE/LFMB | 1 0 | NRR/DLPQ/HFB | 1 1 |
| <u>REG FILE</u> 01 | 1 1 | RES/DE/EIB | 1 1 |
| RES7DRPS DIR | 1 1 | | |
| EXTERNAL: LPDR | 1 1 | NRC PDR | 1 1 |
| NSIC | 1 1 | | |
| NOTES: | 1 1 | | |

Rec'd w/check \$150.00
 # 18476154

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

January 6, 1988

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
NUREG 0737 Item III.D.3.4
Control Room Habitability Technical Specifications

Gentlemen:


Per Duke's January 30, 1987 supplemental response to Generic Letter 83-37 (NUREG 0737 Technical Specifications) and pursuant to 10CFR 50, §50.90, please find attached (Attachment 1) a proposed amendment to the Oconee Nuclear Station (ONS) Facility Operating Licenses and revisions to the ONS Technical Specifications. The proposed amendment addresses the operability and testing of the control room pressurization and filtering systems. The proposed Technical Specification 3.15 provides Limiting Conditions for Operation (LCO) for the control room pressurization and filtering system and reporting requirements wherein the LCO is not satisfied. The proposed Technical Specification 4.12 provides for additional testing of the control room pressurization and filtering system as well as clarifications to existing Technical Specification requirements.

By letter dated August 14, 1987, Duke proposed the relocation of control room outside air intakes. Relocation of the intakes should resolve current NRC concerns regarding atmospheric dilution factors and occupancy factors. Modifications for relocation of the intakes are contingent upon NRC concurrence on the acceptability of the relocation. Duke is currently awaiting NRC concurrence.

Based upon the Technical Justification provided in Attachment 2, Duke has determined the attached proposed amendment as having No Significant Hazards Considerations. Attachment 3 provides the No Significant Hazards Consideration Evaluation. Duke is forwarding a copy of this application to the South Carolina Department of Health and Environmental Control for review and, as appropriate, subsequent consultations with the Staff.

Pursuant to 10CFR 170.21, enclosed is a check in the amount of \$150.00 for the application fee.

Very truly yours,



Hal B. Tucker

PJN/1200/sbn

Attachment

8801210001 880106
PDR ADDCK 05000269
P PDR

Rec'd w/ HOC 12/150.00
18476154

A003
11

U. S. Nuclear Regulatory Commission
January 6, 1988
Page 2


xc: Dr. J. Nelson Grace, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Ms. Helen Pastis
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Heyward Shealy, Chief
Bureau of Radiological Health
S.C. Department of Health and
Environmental Control
2600 Bull Street
Columbus, S.C. 29201


Mr. P. H. Skinner
NRC Resident Inspector
Oconee Nuclear Station

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the Oconee Nuclear Station License Nos. DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



Hal B. Tucker, Vice President

Subscribed and sworn to before me this 6th day of January, 1988.


Notary Public

My Commission Expires:

