

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8805240169 DOC.DATE: 88/05/13 NOTARIZED: NO DOCKET #
 FACIL:50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH.NAME AUTHOR AFFILIATION
 TUCKER,H.B. Duke Power Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-38,DPR-47 & DPR-55 re
 NUREG-0737,Items II.B.1,II.F.1.3 & II.F.1.6

DISTRIBUTION CODE: A003D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 3+9
 TITLE: OR/Licensing Submittal: Suppl 1 to NUREG-0737(Generic Ltr 82-33)

NOTES:AEOD/Ornstein:1cy. 05000269S
 AEOD/Ornstein:1cy. 05000270
 AEOD/Ornstein:1cy. 05000287/

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 LA	1 1	PD2-3 PD	7 7
	PASTIS,H	1 1		
INTERNAL:	ARM/DAF/LFMB	1 0	NRR/DLPO/HFB 10	1 1
	NUDOCS-ABSTRACT	1 1	<u>REG FILE</u> 01	1 1
	RES/DE/EIB	1 1	RES/DRPS DEPY	1 1
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		
NOTES:		1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 18

R
I
D
S
/
A
D
D
S

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

May 13, 1988

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
GL 83-37 Items II.B.1, II.F.1.3, and II.F.1.6

Gentlemen:

By letter dated November 1, 1983 the NRC provided Generic Letter (GL) 83-37. By letter dated October 8, 1984 as supplement August 27, 1985 and August 13, 1986, Duke Power Company (Duke) provided a response to GL 83-37 and proposed Technical Specifications pertaining to NUREG 0737 Items II.B.1, II.F.1.3, and II.F.1.6. (Reactor Coolant System High Point Vents, Containment High Range Radiation Monitors, and Containment Hydrogen Monitors respectively).

A Technical Evaluation Report (TER) concerning Oconee's conformance to NUREG 0737 Action Items requiring Technical Specifications was provided by NRC letter dated November 19, 1987. Within Duke's January 18, 1988 response to the TER, Duke committed to revising Technical Specifications previously submitted for the Reactor Coolant System (RCS) High Point Vents, Containment High Range Radiation Monitors, and Containment Hydrogen Monitors by May 18, 1988. As such, pursuant to 10CFR 50, Part 50.90, please find attached (Attachment 1) a supplement to the October 8, 1984 proposed amendment to the Oconee Nuclear Station (ONS) Facility Operating Licenses and revisions to the ONS Technical Specifications. This supplement provides more stringent operability requirements for the RCS High Point Vents, additional bases for the RCS High Point Vents, additional bases for the Containment High Range Radiation Monitors, updated surveillance requirements for the Containment Hydrogen Monitors, and supporting administrative changes. This supplement revises pages included in the August 13, 1986 and March 15, 1988 amendment request.

8805240169 880513
PDR ADOCK 05000269
P DCD

Handwritten:
A046
A003
1/1

Document Control Desk
May 13, 1988
Page 2

Technical Specifications associated with NUREG 0737 Items II.B.1, II.F.1.3, and II.F.1.6 included within this amendment request are considered to be a separate licensing action from the design and modifications associated with the subject NUREG 0737 Items. Further, by letter dated November 2, 1983, the NRC staff found that the RCS high point vent system at Oconee is acceptable and in conformance with the requirements of 10CFR50.44(c)(3)(iii) and the guidelines of NUREG 0737 Item II.B.1 and NUREG 0800 Section 5.4.12. On March 18, 1983, the NRC issued an order confirming commitments to implement NUREG 0737 Items II.F.1.3 and II.F.1.6 (among others). By letter dated September 1, 1983, the NRC staff concluded that the requirements of NUREG 0737 Item II.F.1.6 have been met.

Duke has determined the attached proposed amendment as having No Significant Hazards Considerations. Attachment 2 provides the No Significant Hazards Consideration Evaluation and Technical Justification. Duke is providing a copy of this application to the South Carolina Department of Health and Environmental Control for review and, as appropriate, subsequent consultations with the staff.

Inasmuch as these proposed changes are a supplement to a previous amendment request, no license fees are required.

Very truly yours,

H. B. Tucker
Hal B. Tucker
PJN/321/bhp

Attachment

xc: Dr. J. Nelson Grace, Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., NW, Suite 2900
Atlanta, Georgia 30323

Ms. Helen Pastis
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Heyward Shealy, Chief
Bureau of Radiological Health
S.C. Department of Health and
Environmental Control
2600 Bull Street
Columbus, SC 29201

Mr. P.H. Skinner
NRC Resident Inspector
Oconee Nuclear Station

DUKE POWER COMPANY

OCONEE NUCLEAR STATION

Attachment 1

Reference Attachment 1 to amendment requests
dated August 13, 1986 and March 15, 1988

<u>Remove Pages</u>	<u>Insert Pages</u>
iii	iii
	3.1-24
3.1-25	
3.5-45	3.5-45
4.1-8a	4.1-8a