

Part 21 (PAR)

Event # 51458

Rep Org: DRESDEN	Notification Date / Time: 10/06/2015 22:06 (EDT)
Supplier: GENERAL ELECTRIC HITACHI	Event Date / Time: 10/05/2015 12:00 (CDT)
	Last Modification: 10/06/2015
Region: 3	Docket #:
City: MORRIS	Agreement State: Yes
County:	License #:
State: IL	
NRC Notified by: AARON THOMPSON	Notifications: ANN MARIE STONE R3DO
HQ Ops Officer: JEFF HERRERA	PART 21/50.55 REACTORS EMAIL
Emergency Class: NON EMERGENCY	
10 CFR Section:	
21.21(d)(3)(i) DEFECTS AND NONCOMPLIANCE	

PART 21 REPORT - ELECTROMATIC RELIEF VALVE (EMRV) CUTOUT SWITCH

"Following the return of the actuator that failed bench testing to GEH, on 6/12/15 at 1804 [CDT], General Electric Hitachi (GEH) notified Dresden Station of a potential parts quality Potential Failure of the EMRV Cutout Switch. It has been determined the notification is applicable to DNPS [Dresden Nuclear Power Station], Units 2 and 3.

"The GEH investigation concluded that the EMRV actuator assemblies failed to change state because of the failure of the cutout switch to fully close and provide the appropriate current path. Multiple contributing factors were discovered which could have led to the presence of the gaps in the cutout switch. The most significant of these factors is a change in lever arm positioning causing increased forces in the tension spring which prevent proper closure of the cutout switch. Design changes to reduce wear caused by vibration on the actuators changed lever arm position and also allowed for additional dimensional tolerance which tended to increase force in the tension spring.

"Identification of Facility and Component: DNPS / EMRV Actuator, GEH Part Number 352B2632G001

"Safety Significance (e.g., substantial hazard that is or could be created): Identified condition is a Potential Substantial Safety Hazard since it could cause affected EMRVs to fail to operate as designed, which could result in a loss of safety function. Potential to affect the Minimum Critical Power Ratio (MCPR), Reactor Coolant System (RCS), Automatic Depressurization System (ADS), and Low Set Relief Function

"Plants with similar GEH cutout switches: Quad Cities Nuclear Power Station."

Part 21 Reference: EN #51386

JEI9
NRR

The licensee notified the NRC Resident Inspector.

REACTOR PLANT
EVENT NOTIFICATION WORKSHEET

EN # 51458

NRC Operation Telephone Number: PRIMARY – 301-816-5100 or 800-532-3469*, BACKUPS – [1st] 301-951-0550 or 800-449-3694*
[2nd] 301-415-0550 and [3rd] 301-415-0553 *Licensees who maintain their own ETS are provided these telephone numbers.

NOTIFICATION TIME 2206 EDT	FACILITY OR ORGANIZATION Dresden	UNIT 2/3	NAME OF CALLER Aaron Thompson	CALL BACK # (815)942-0402
EVENT TIME & ZONE 1200 CDT	EVENT DATE 10/05/2015	POWER/MODE BEFORE 97% Mode 1 - Unit 2 100% Mode 1 - Unit 3	POWER/MODE AFTER 97% Mode 1 - Unit 2 100% Mode 1 - Unit 3	
EVENT CLASSIFICATIONS		1-Hr. Non-Emergency 10CFR50.72(b)(1)		
<input type="checkbox"/> GENERAL EMERGENCY	GEN/AAEC	<input type="checkbox"/> TS Deviation	ADEV	<input type="checkbox"/> (v)(A) Safe S/D Capability AINA
<input type="checkbox"/> SITE AREA EMERGENCY	SIT/AAEC	4-Hr. Non-emergency 10CFR50.72(b)(2)		<input type="checkbox"/> (v)(B) RHR Capability AINB
<input type="checkbox"/> ALERT	ALE/AAEC	<input type="checkbox"/> (i) TS Required S/D	ASHU	<input type="checkbox"/> (v)(C) Control of Rad Release AINC
<input type="checkbox"/> UNUSUAL EVENT	UNU/AAEC	<input type="checkbox"/> (iv)(A) ECCS Discharge to RCS	ACCS	<input type="checkbox"/> (v)(D) Accident Mitigation AIND
<input type="checkbox"/> 50.72 NON-EMERGENCY (see next columns)		<input type="checkbox"/> (iv)(B) RPS Actuation (scram)	ARPS	<input type="checkbox"/> (xii) Offsite Medical AMED
<input type="checkbox"/> PHYSICAL SECURITY (73.71)	DDDD	<input type="checkbox"/> (xi) Offsite Notification	APRE	<input type="checkbox"/> (xiii) Lost Comm/Asmt/Resp ACOM
<input type="checkbox"/> MATERIAL/EXPOSURE	B???	8-Hr. Non-emergency 10CFR50.72(b)(3)		<input type="checkbox"/> 60-DAY Optional 10CFR50.73(a)(1)
<input type="checkbox"/> FITNESS FOR DUTY	HFIT	<input type="checkbox"/> (ii)(A) Degraded Condition	ADEG	<input type="checkbox"/> Invalid Specified System Actuation AINV
<input checked="" type="checkbox"/> OTHER UNSPECIFIED REQMT. (see last column)		<input type="checkbox"/> (ii)(B) Unanalyzed Condition	AUNA	<input checked="" type="checkbox"/> Other Unspecified Requirement (Identify)
<input type="checkbox"/> INFORMATION ONLY	NNF	<input type="checkbox"/> (iv)(A) Specified System Actuation	ASEF	<input type="checkbox"/> 10 CFR 21.21 (d)(3)(i) Defect NONR
<input type="checkbox"/> NONR				

DESCRIPTION

Include: Systems affected, actuations and their initiating signals, causes, effect of event on plant, actions taken or planned, etc. (continue on back)

PART 21 REPORT - ELECTROMATIC RELIEF VALVE CUTOUT SWITCH

"This is a non-emergency notification from Dresden Nuclear Power Station (DNPS) required under 10 CFR Part 21 concerning the design of Electromatic Relief Valve (EMRV) actuators Cutout Switches.

Following the return of the actuator that failed bench testing to GEH, on 6/12/15 at 18:04, General Electric Hitachi (GEH) notified Dresden Station of a potential parts quality Potential Failure of the EMRV Cutout Switch. It has been determined the notification is applicable to DNPS, Units 2 and 3.

The GEH investigation concluded that the EMRV actuator assemblies failed to change state because of the failure of the cutout switch to fully close and provide the appropriate current path. Multiple contributing factors were discovered which could have led to the presence of the gaps in the cutout switch. The most significant of these factors is a change in lever arm positioning causing increased forces in the tension spring which prevent proper closure of the cutout switch. Design changes to reduce wear caused by vibration on the actuators changed lever arm position and also allowed for additional dimensional tolerance which tended to increase force in the tension spring.

Identification of Facility and Component: DNPS / EMRV Actuator, GEH Part Number 352B2632G001

Identification of Component Manufacturer and/or Supplier: GE-Hitachi Nuclear Energy.

Nature of Defect: Cutout switch fails to close.

Safety Significance (e.g., substantial hazard that is or could be created): Identified condition is a Potential Substantial Safety Hazard since it could cause affected EMRVs to fail to operate as designed, which could result in a loss of safety function. Potential to affect the Minimum Critical Power Ratio (MCPR), Reactor Coolant System (RCS), Automatic Depressurization System (ADS), and Low Set Relief Function

NOTIFICATIONS	YES	NO	WILL BE	ANYTHING UNUSUAL OR	<input type="checkbox"/> YES (Explain above)	<input checked="" type="checkbox"/> NO
NRC Resident	x			NOT UNDERSTOOD?		
State(s)		X		DID ALL SYSTEMS	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO (Explain above)
Local		X		FUNCTION AS REQUIRED?		
Other Gov Agencies		X		MODE OF OPERATION	ESTIMATED RESTART DATE: (MM/DD/YY) N/A	ADDITIONAL INFO ON BACK
Media/Press Release		x		UNTIL CORRECTED: Mode 1		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

REACTOR PLANT EVENT NOTIFICATION WORKSHEET (CONTINUED)

ADDITIONAL INFORMATION

RADIOLOGICAL RELEASES: CHECK OR FILL IN APPLICABLE ITEMS (specific details/explanations should be covered in event description)

LIQUID RELEASE	GASEOUS RELEASE	UNPLANNED RELEASE	PLANNED RELEASE	ONGOING	TERMINATED
MONITORED	UNMONITORED	OFFSITE RELEASE	T. S. EXCEEDED	RM ALARMS	AREAS EVACUATED
PERSONNEL EXPOSED OR CONTAMINATED		OFFSITE PROTECTIVE ACTIONS RECOMMENDED		* State release path in description	

	Release Rate (Ci/sec)	% T. S. Limit	HOO Guide	Total Activity (Ci)	% T. S. Limit	HOO Guide
Noble Gas			0.1 Ci/sec			1000 Ci
Iodine			10 µCi/sec			0.01 Ci
Particulate			1 µCi/sec			1 mCi
Liquid (excluding tritium & dissolved noble gas)			10 µCi/min			0.1 Ci
Liquid (tritium)			0.2 Ci/min			5 Ci
Total Activity						

	Plant Stack	Condenser/Air Ejector	Main Steam Line	SG Blowdown	Other
RAD MONITOR READINGS					
ALARM SETPOINTS					
% T. S. LIMIT (if applicable)					

RCS OR SG TUBE LEAKS: CHECK OR FILL IN APPLICABLE ITEMS: (specific details/explanations should be covered in the event description)

LOCATION OF LEAK (e.g., SG #, valve, pipe, etc.)

LEAK RATE	UNITS: gpm/gpd	T. S. LIMITS	SUDDEN OR LONG TERM DEVELOPMENT
LEAK START DATE	TIME	COOLANT ACTIVITY & UNITS	PRIMARY SECONDARY

LIST OF SAFETY RELATED EQUIPMENT NOT OPERATIONAL

EVENT DESCRIPTION (continued from front)

Date of Discovery of Initial Condition (taken from the IR): 06/12/15

Date of Discovery of the Substantial Safety Hazard (date of approval of the technical evaluation): 10/05/15

Recommended Actions: Perform inspection at the next available opportunity to verify that proper over travel exists on the cutout switch and that the associated EMRV actuates properly.

"Number and Locations of All Defective Components: 1 - EMRV Unit 5 (SN 15433-5) was in Inventory.

"Any Advice Related to the Defect: Perform inspection at the next available opportunity to verify that positive over travel exists on the EMRV cutout switch.

"Contacts (Name, Title, Location, Phone Number, etc): Daniel Sipple, Sr Staff I&C Design Engineer, Dresden Nuclear Power Station, daniel.sipple@exeloncorp.com, (815) 416-3631 "

The licensee notified the NRC Resident Inspector.

Plants with similar GEH cutout switches: Quad Cities Nuclear Power Station.