

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 2639

FILE: MONTHLY REPORT FILE

FROM: Duke Power Company Charlotte, NC A C Thies			DATE OF DOC 3-7-75	DATE REC'D 3-11-75	LTR XXX	TWX	RPT	OTHER
TO: DL			ORIG one signed	CC	OTHER	SENT AEC PDR <u>XX</u> SENT LOCAL PDR <u>XX</u>		
CLASS	UNCLASS XXXXX	PROP INFO	INPUT	NO CYS REC'D 1		DOCKET NO: 50-269 <u>270</u> 287		

DESCRIPTION:

Ltr trans the following:

**DO NOT REMOVE
ACKNOWLEDGED**

ENCLOSURES:

Monthly Report for February
Plant & Component Operability & Availability
This Report to be used in preparing Grey
Book by Plans & Operations.

No. of Cys Rec'd 1

PLANT NAME: Oconee 1-2-3

FOR ACTION/INFORMATION 3-11-75 ehf

BUTLER (S)	SCHWENCER (S)	ZIEMANN (S)	REGAN (E)
W/ Copies	W/ Copies	W/ Copies	W/ Copies
CLARK (S)	STOLZ (S)	DICKER (E)	LEAR (S)
W/ Copies	W/ Copies	W/ Copies	W/ Copies
PARR (S)	VASSALLO (S)	KNIGHTON (E)	W.D. THOMPSON
W/ Copies	W/ Copies	W/ Copies	W/ 2 Copies
KNIEL (S)	PURPLE (S)	YOUNGBLOOD (E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies

INTERNAL DISTRIBUTION

<u>REG FILE</u>	<u>TECH REVIEW</u>	<u>DENTON</u>	<u>LIC ASST</u>	<u>A/T IND</u>
AEC PDR	SCHROEDER	GRIMES	DIGGS (S)	BRAITMAN
OGC, ROOM P-506-A	MACCARRY	GAMMILL	GEARIN (S)	SALTZMAN
MUNTZING/STAFF	KNIGHT	KASTNER	GOULBOURNE (S)	B. HURT
CASE	PAWLICKI	BALLARD	KREUTZER (E)	
GIAMBUSSO	SHAO	SPANGLER	LEE (S)	<u>PLANS</u>
BOYD	STELLO		MAIGRET (S)	MC DONALD
MOORE (S) (BWR)	HOUSTON	<u>ENVIRO</u>	REED (E)	CHAPMAN
DEYOUNG (S) (PWR)	NOVAK	MULLER	SERVICE (S)	DUBE w/input
SKOVHOLT (S)	ROSS	DICKER	SHEPPARD (S)	E. COUPE
GOLLER (S)	IPPOLITO	KNIGHTON	SLATER (E)	
P. COLLINS	TEDESCO	YOUNGBLOOD	SMITH (S)	D. THOMPSON (2)
DENISE	LONG	REGAN	TEETS (S)	KLECKER
<u>REG OPR</u>	LAINAS	PROJECT LDR	WILLIAMS (E)	EISENHUT
FILE & REGION (2)	BENAROYA		WILSON (S)	
T.R. WILSON	VOLIMER	HARLESS	INGRAM (S)	<i>MR</i>
STEELE				<i>(2) R</i>

EXTERNAL DISTRIBUTION

1-LOCAL PDR <u>Wolke, S.C.</u>	(1) (2) (10) - NATIONAL LABS	1-PDR SAN/LA/NY
1-TIC (ABERNATHY)	1-W. PENNINGTON, RM-E-201G.T.	1-BROOKHAVEN NAT LAB
1-NSIC (BUCHANAN)	1-CONSULTANTS	1-G. ULRIKSON, ORNL
1-ASLE	NEWARK/BLUME/ACBABIAN	1-AGNES RUTH GUSMAN
1-NEWTON ANDERSON		ROOM B-127 G.T.
16-ACRS HOLDING		1-J. RUNKLES RM-E-2
		G.T.

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28201

A. C. THIES
SENIOR VICE PRESIDENT
PRODUCTION AND TRANSMISSION

P. O. Box 2178

March 7, 1975



Director
Office of Management Information
and Program Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Regulatory

File Cyl

Dear Sir:

Please find attached information concerning the performance of the Oconee Nuclear Station for the month of February, 1975. Also enclosed are corrected status reports for Oconee Unit 1 for December, 1974 and January, 1975. The Oconee Unit 1 refueling outage ended with replacement of the reactor vessel head on December 23, 1974. A forced outage commenced at that time for maintenance of reactor coolant pump seals. The corrected operating status and plant shutdown sheets indicate the revised forced outage and plant shutdown data.

In review of the data presented for Oconee Units 2 and 3 in the Operating Status Report dated February 21, 1975, certain errors have been identified. In the Oconee 2 Facility Data Section, the dates for Items 6 and 7 are incorrect. The actual dates of initial criticality and commercial operation are November 11, 1973 and September 9, 1974, respectively. These corrections were brought to your attention in my letter of December 13, 1974.

The data presented for Oconee Unit 3 indicates that this unit is not in commercial operation. This is not the case, however, as Unit 3 was declared commercially operable on December 16, 1974. This information was transmitted in my letter of January 10, 1975.

Thank you for your attention to this matter.

Very truly yours,

A. C. Thies

ACT:vr
Attachment

cc: Mr. Norman C. Moseley



2639

UNIT Oconee 1
DATE 3/7/75

DOCKET NO. 50-269

OPERATING STATUS

1. REPORTING PERIOD: December 1, 1974 THROUGH December 31, 1974
HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (MWth) 2568 MAX. DEPENDABLE CAPACITY (MWe-NET) 871
3. LOWEST POWER LEVEL TO WHICH SPECIFICALLY RESTRICTED (IF ANY) (MWe-NET): None
4. REASONS FOR RESTRICTION (IF ANY):

	THIS REPORTING PERIOD	YR TO DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL	<u>0</u>	<u>5446.7</u>	<u>9800.5</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>0</u>	<u>5265.2</u>	<u>8254.3</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>0</u>	<u>12226629</u>	<u>18237510</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>0</u>	<u>4230112</u>	<u>6318700</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>-4547</u>	<u>3993941</u>	<u>5953019</u>
12. REACTOR AVAILABILITY FACTOR (1)	<u>0</u>	<u>62.2</u>	<u>76.5</u>
13. UNIT AVAILABILITY FACTOR (2)	<u>0</u>	<u>60.1</u>	<u>64.4</u>
14. UNIT CAPACITY FACTOR (3)	<u>0</u>	<u>52.4</u>	<u>53.3</u>
15. UNIT FORCED OUTAGE RATE (4)	<u>100</u>	<u>10.1</u>	<u>9.7</u>
16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH):			

17. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: _____
18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

	DATE LAST FORECAST	DATE ACHIEVED
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICAL POWER GENERATION	_____	_____
COMMERCIAL OPERATION	_____	_____

- (1) REACTOR AVAILABILITY FACTOR = $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (2) UNIT AVAILABILITY FACTOR = $\frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (3) UNIT CAPACITY FACTOR = $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{MAX. DEPENDABLE CAPACITY (MWe-NET)} \times \text{HOURS IN REPORTING PERIOD}}$
- (4) UNIT FORCED OUTAGE RATE = $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$

UNIT SHUTDOWNS

DOCKET NO. 50-269
UNIT NAME Oconee Unit 1
DATE 3/7/75

REPORT MONTH December, 1974

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
16	741019	S	552.0	C	1	Reactor coolant pump seal repairs
17	741224	F	192	A	1	
<div><div>(1) REASON A-EQUIPMENT FAILURE (EXPLAIN) B-MAINT. OR TEST C-REFUELING D-REGULATORY RESTRICTION E-OPERATOR TRAINING AND LICENSE EXAMINATION F-ADMINISTRATIVE G-OPERATIONAL ERROR (EXPLAIN) H-OTHER (EXPLAIN)</div><div>(2) METHOD 1-MANUAL 2-MANUAL SCRAM 3-AUTOMATIC SCRAM</div></div>						

SUMMARY:

UNIT Oconee Unit 1DATE March 7, 1975DOCKET NO. 50-269

OPERATING STATUS

1. REPORTING PERIOD: January 1, 1975 THROUGH January 31, 1975
 HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (MWth) 2568 MAX. DEPENDABLE CAPACITY (MWe-NET) 871
3. LOWEST POWER LEVEL TO WHICH SPECIFICALLY RESTRICTED (IF ANY) (MWe-NET): None
4. REASONS FOR RESTRICTION (IF ANY):

	THIS REPORTING PERIOD	YR TO DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL	<u>0</u>	<u>0</u>	<u>9800.5</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>0</u>	<u>0</u>	<u>8254.3</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>0</u>	<u>0</u>	<u>18237510</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>0</u>	<u>0</u>	<u>6318700</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>-6039</u>	<u>-6039</u>	<u>5946980</u>
12. REACTOR AVAILABILITY FACTOR (1)	<u>0</u>	<u>0</u>	<u>72.3</u>
13. UNIT AVAILABILITY FACTOR (2)	<u>0</u>	<u>0</u>	<u>60.0</u>
14. UNIT CAPACITY FACTOR (3)	<u>0</u>	<u>0</u>	<u>50.4</u>
15. UNIT FORCED OUTAGE RATE (4)	<u>100</u>	<u>100</u>	<u>16.5</u>
16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH):			

17. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: _____
18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

	DATE LAST FORECAST	DATE ACHIEVED
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICAL POWER GENERATION	_____	_____
COMMERCIAL OPERATION	_____	_____

- (1) REACTOR AVAILABILITY FACTOR = $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (2) UNIT AVAILABILITY FACTOR = $\frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (3) UNIT CAPACITY FACTOR = $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{MAX. DEPENDABLE CAPACITY (MWe-NET) X HOURS IN REPORTING PERIOD}}$
- (4) UNIT FORCED OUTAGE RATE = $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE + FORCED OUTAGE HOURS}} \times 100$

UNIT SHUTDOWNS

DOCKET NO. 50-269UNIT NAME Oconee Unit 1DATE 3/7/75REPORT MONTH January, 1975

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
17	741224	F	744.0	A	1	Reactor coolant pump seal repairs <div><div>(1) REASON A-EQUIPMENT FAILURE (EXPLAIN) B-MAINT. OR TEST C-REFUELING D-REGULATORY RESTRICTION E-OPERATOR TRAINING AND LICENSE EXAMINATION F-ADMINISTRATIVE G-OPERATIONAL ERROR (EXPLAIN) H-OTHER (EXPLAIN)</div><div>(2) METHOD 1-MANUAL 2-MANUAL SCRAM 3-AUTOMATIC SCRAM</div></div>

SUMMARY:

UNIT Oconee Unit 1DATE March 7, 1975DOCKET NO. 50-269

OPERATING STATUS

1. REPORTING PERIOD: February 1, 1975 THROUGH February 28, 1975
 HOURS IN REPORTING PERIOD: 671.0
2. CURRENTLY AUTHORIZED POWER LEVEL (MWth) 2568 MAX. DEPENDABLE CAPACITY (MWe-NET) 871
3. LOWEST POWER LEVEL TO WHICH SPECIFICALLY RESTRICTED (IF ANY) (MWe-NET): None
4. REASONS FOR RESTRICTION (IF ANY):

	THIS REPORTING PERIOD	YR TO DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL	<u>74.8</u>	<u>74.8</u>	<u>9875.4</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>0</u>	<u>0</u>	<u>8254.3</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>0</u>	<u>0</u>	<u>18237510</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>0</u>	<u>0</u>	<u>6318700</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>(-7603)</u>	<u>(-13642)</u>	<u>5939377</u>
12. REACTOR AVAILABILITY FACTOR (1)	<u>11.5</u>	<u>5.3</u>	<u>69.4</u>
13. UNIT AVAILABILITY FACTOR (2)	<u>0</u>	<u>0</u>	<u>58.0</u>
14. UNIT CAPACITY FACTOR (3)	<u>0</u>	<u>0</u>	<u>47.9</u>
15. UNIT FORCED OUTAGE RATE (4)	<u>100</u>	<u>100</u>	<u>21.8</u>
16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH):			

17. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: March 10, 1975

18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

	DATE LAST FORECAST	DATE ACHIEVED
INITIAL CRITICALITY	<u> </u>	<u> </u>
INITIAL ELECTRICAL POWER GENERATION	<u> </u>	<u> </u>
COMMERCIAL OPERATION	<u> </u>	<u> </u>

(1) REACTOR AVAILABILITY FACTOR = $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$

(2) UNIT AVAILABILITY FACTOR = $\frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$

(3) UNIT CAPACITY FACTOR = $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{MAX. DEPENDABLE CAPACITY (MWe-NET)} \times \text{HOURS IN REPORTING PERIOD}}$

(4) UNIT FORCED OUTAGE RATE = $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$

DOCKET NO. 50-269UNIT Oconee Unit 1DATE 3/7/75**AVERAGE DAILY UNIT POWER LEVEL**MONTH February, 1975

AVERAGE DAILY POWER LEVEL (MWe-net)		AVERAGE DAILY POWER LEVEL (MWe-net)	
DAY		DAY	
1	<u>0</u>	17	<u>0</u>
2	<u>0</u>	18	<u>0</u>
3	<u>0</u>	19	<u>0</u>
4	<u>0</u>	20	<u>0</u>
5	<u>0</u>	21	<u>0</u>
6	<u>0</u>	22	<u>0</u>
7	<u>0</u>	23	<u>0</u>
8	<u>0</u>	24	<u>0</u>
9	<u>0</u>	25	<u>0</u>
10	<u>0</u>	26	<u>0</u>
11	<u>0</u>	27	<u>0</u>
12	<u>0</u>	28	<u>0</u>
13	<u>0</u>	29	<u> </u>
14	<u>0</u>	30	<u> </u>
15	<u>0</u>	31	<u> </u>
16	<u>0</u>		

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

DOCKET NO. 50-269
UNIT NAME Oconee Unit 1
DATE March 7, 1975

DATE March 7, 1975

SUMMARY:

UNIT Oconee Unit 2DATE March 7, 1975DOCKET NO. 50-270

OPERATING STATUS

1. REPORTING PERIOD: February 1, 1975 THROUGH February 28, 1975
 HOURS IN REPORTING PERIOD: 671.00
2. CURRENTLY AUTHORIZED POWER LEVEL (MWth) _____ MAX. DEPENDABLE CAPACITY (MWe-NET) 871
3. LOWEST POWER LEVEL TO WHICH SPECIFICALLY RESTRICTED (IF ANY) (MWe-NET): None
4. REASONS FOR RESTRICTION (IF ANY): _____

	THIS REPORTING PERIOD	YR TO DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL	<u>0</u>	<u>437.4</u>	<u>2383.5</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>0</u>	<u>429.3</u>	<u>2304.7</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>0</u>	<u>1055278</u>	<u>5362176</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>0</u>	<u>357490</u>	<u>1826466</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>(-2905)</u>	<u>334678</u>	<u>1722204</u>
12. REACTOR AVAILABILITY FACTOR (1)	<u>0</u>	<u>30.9</u>	<u>57.4</u>
13. UNIT AVAILABILITY FACTOR (2)	<u>0</u>	<u>30.3</u>	<u>55.5</u>
14. UNIT CAPACITY FACTOR (3)	<u>0</u>	<u>27.2</u>	<u>47.6</u>
15. UNIT FORCED OUTAGE RATE (4)	<u>100.0</u>	<u>69.7</u>	<u>44.4</u>
16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH):			

17. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: March 7, 1975
18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

	DATE LAST FORECAST	DATE ACHIEVED
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICAL POWER GENERATION	_____	_____
COMMERCIAL OPERATION	_____	_____

- (1) REACTOR AVAILABILITY FACTOR = $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (2) UNIT AVAILABILITY FACTOR = $\frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (3) UNIT CAPACITY FACTOR = $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{MAX. DEPENDABLE CAPACITY (MWe-NET)} \times \text{HOURS IN REPORTING PERIOD}}$
- (4) UNIT FORCED OUTAGE RATE = $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$

DOCKET NO. 50-270UNIT Oconee Unit 2DATE 3/7/75**AVERAGE DAILY UNIT POWER LEVEL**MONTH February, 1975**DAY** **AVERAGE DAILY POWER LEVEL**
 (MWe-net)

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY **AVERAGE DAILY POWER LEVEL**
 (MWe-net)

17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u> </u>
30	<u> </u>
31	<u> </u>

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

UNIT SHUTDOWNS

DOCKET NO. 50-270

UNIT NAME Oconee Unit 2

DATE March 7, 1975

REPORT MONTH February, 1975

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
2	750119	F	671.0	A	1	Replacement of leaking pressurizer relief valves and reactor coolant pump motor repairs
<div> <div>(1) REASON</div> <div> A-EQUIPMENT FAILURE (EXPLAIN) B-MAINT. OR TEST. C-REFUELING D-REGULATORY RESTRICTION E-OPERATOR TRAINING AND LICENSE EXAMINATION F-ADMINISTRATIVE G-OPERATIONAL ERROR (EXPLAIN) H-OTHER (EXPLAIN) </div> </div> <div> <div>(2) METHOD</div> <div> 1-MANUAL 2-MANUAL SCRAM 3-AUTOMATIC SCRAM </div> </div>						

SUMMARY:

UNIT Unit 3DATE March 7, 1975DOCKET NO. 50-287

OPERATING STATUS

1. REPORTING PERIOD: February 1, 1975 THROUGH February 28, 1975
HOURS IN REPORTING PERIOD: 671.0
2. CURRENTLY AUTHORIZED POWER LEVEL (MWth) 2568 MAX. DEPENDABLE CAPACITY (MWe-NET) 871
3. LOWEST POWER LEVEL TO WHICH SPECIFICALLY RESTRICTED (IF ANY) (MWe-NET): None
4. REASONS FOR RESTRICTION (IF ANY):

	THIS REPORTING PERIOD	YR TO DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL	<u>572.4</u>	<u>1061.7</u>	<u>1245.6</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>564.1</u>	<u>1025.2</u>	<u>1207.9</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>1139692</u>	<u>2222642</u>	<u>2667292</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>395310</u>	<u>774870</u>	<u>923784</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>376752</u>	<u>737007</u>	<u>878143</u>
12. REACTOR AVAILABILITY FACTOR (1)	<u>85.3</u>	<u>75.0</u>	<u>69.2</u>
13. UNIT AVAILABILITY FACTOR (2)	<u>84.1</u>	<u>72.5</u>	<u>67.1</u>
14. UNIT CAPACITY FACTOR (3)	<u>64.5</u>	<u>59.8</u>	<u>56.0</u>
15. UNIT FORCED OUTAGE RATE (4)	<u>15.9</u>	<u>27.6</u>	<u>32.9</u>
16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH):			
17. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:			
18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:			

	DATE LAST FORECAST	DATE ACHIEVED
INITIAL CRITICALITY	<u> </u>	<u> </u>
INITIAL ELECTRICAL POWER GENERATION	<u> </u>	<u> </u>
COMMERCIAL OPERATION	<u> </u>	<u> </u>

- (1) REACTOR AVAILABILITY FACTOR = $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (2) UNIT AVAILABILITY FACTOR = $\frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (3) UNIT CAPACITY FACTOR = $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{MAX. DEPENDABLE CAPACITY (MWe-NET)} \times \text{HOURS IN REPORTING PERIOD}}$
- (4) UNIT FORCED OUTAGE RATE = $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$

DOCKET NO. 50-287UNIT Oconee Unit 3DATE 3/7/75

AVERAGE DAILY UNIT POWER LEVEL

MONTH February, 1975DAY AVERAGE DAILY POWER LEVEL
(MWe-net)

1	859
2	857
3	857
4	787
5	-
6	-
7	-
8	-
9	220
10	490
11	683
12	818
13	809
14	697
15	611
16	617

DAY AVERAGE DAILY POWER LEVEL
(MWe-net)

17	616
18	621
19	629
20	626
21	619
22	617
23	595
24	623
25	623
26	624
27	628
28	627
29	
30	
31	

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.