

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-269 270/287

REC: CASE E G
NRC

ORG: PARKER W O
NRC

DOCDATE: 02/01/78
DATE RCVD: 02/06/78

DOCTYPE: LETTER NOTARIZED: YES

COPIES RECEIVED
LTR 3 ENCL 40

SUBJECT: DPR-34 47
LICENSEE NO DPR-33 DPR-33 & DPR-52 APPL FOR AMEND: TECH SPECS
PROPOSED CHANGE CONCERNING REVISIONS TO SECTIONS OF THE AUXILIARY
ELECT SYSTEMS AND EMERGENCY PWR PERIODIC TESTING TECH
SPECS... NOTARIZED 02/01/78.

PLANT NAME: OCONEE - UNIT 1
OCONEE - UNIT 2
OCONEE - UNIT 3

REVIEWER INITIAL: XJM
DISTRIBUTER INITIAL:

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

NOTES:
1. M. CUNNINGHAM - ALL AMENDMENTS TO FSAR AND CHANGES TO TECH SPECS

GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LICENSE.
(DISTRIBUTION CODE A001)

FOR ACTION: BRANCH CHIEF SCHWENCER**W/7 ENC

INTERNAL:

REG FILE**W/ENCL
I & E**W/2 ENCL
HANAUER**W/ENCL
EISENHUT**W/ENCL
BAER**W/ENCL
GRIMES**W/ENCL
J. MCGOUGH**W/ENCL

NRC PDR**W/ENCL
DELD**LTR ONLY
CHECK**W/ENCL
SHAD**W/ENCL
BUTLER**W/ENCL
J. COLLINS**W/ENCL

EXTERNAL:

LPDR'S
WALHALLA, SC**W/ENCL
TIC**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/16 ENCL

DISTRIBUTION: LTR 40 ENCL 39
SIZE: 2P+12P

CONTROL NBR: 780380138

***** THE END *****

ao
pr

05
B03813

DUKE POWER COMPANY

POWER ENGINEERING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242


REGULATORY DOCKET FILE COPY

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

TELEPHONE: AREA 704
373-4083

February 1, 1978

Mr. Edson G. Case, Acting Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555




Re: Oconee Nuclear Station
Docket Nos. 50-269,-270,-287

Dear Mr. Case:

Pursuant to 10CFR40, §50.90, please find attached a proposed change to the Oconee Nuclear Station Technical Specifications. This change revises sections of the Auxiliary Electrical Systems and Emergency Power Periodic Testing Technical Specifications. The limiting conditions for operation and the surveillance requirements for the 125 VDC distribution systems have been revised to closely conform to Standard Technical Specification, NUREG-0103 Revision 1. Additionally, Specification 3.7.2 has been revised to provide flexibility in the operation of the DC power distribution systems and to improve the AC power distribution specifications. Specification 4.6.9 contains a conservative value for specific gravity (1.200) which may be reduced, depending on the results of future testing to be made with degraded battery cells.

Very truly yours,


William O. Parker, Jr.

RLG/rpc

780380138

Attachment


A001/S
3/40

Mr. Benard C. Rusche

Page 2

February 1, 1978

WILLIAM O. PARKER, JR., being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



William O. Parker, Jr., Vice President

Subscribed and sworn to before me this 1st day of February, 1978.


Notary Public

My Commission Expires:

February 15, 1982