

Docket Nos. 50-269-
50-270
50-287

JUL 13 1972

Duke Power Company
ATTN: Mr. Austin C. Thies
Senior Vice President,
Production & Transmission
422 South Church Street
P.O. Box 2178
Charlotte, North Carolina 28201

Gentlemen:

On the basis of our continuing review of the Final Safety Analysis Report for Oconee Nuclear Station Units 2 & 3, we find that we need additional information to complete our evaluation. The specific information required is an analysis of a double-ended break in the line that connects a core flooding tank (CFT) to the reactor vessel. The location of this break should be between the reactor vessel nozzle and the first check valve leading to the CFT. This analysis should be conducted using the evaluation model approved under the Interim Policy Statement, Appendix A, Part 4.

In order to maintain our licensing review schedule, we will need a completely adequate response by August 14, 1972. Please inform us within 7 days after receipt of this letter of your confirmation of the schedule or the date you will be able to meet. If you cannot meet our specified date or if your reply is not fully responsive to our requests, it is highly likely that the overall schedule for completing the licensing review for this project will have to be extended. Since reassignment of the staff's efforts will require completion of the new assignment prior to returning to this project, the extent of extension will most likely be greater than the extent of delay in your response.

Please contact us if you desire any discussion or clarification of the material requested.

Sincerely,

Original signed by
R. C. DeYoung

R. C. DeYoung, Assistant Director
for Pressurized Water Reactors
Directorate of Licensing

cc: See next page

Duke Power Company

- 2 -

JUL 13 1972

cc: William L. Porter, Esq.
Duke Power Company
P.O. Box 2178
422 South Church Street
Charlotte, North Carolina 28201

DISTRIBUTION:

Docket SHanauer
AEC PDR RSBoyd
Local PDR RCDeYoung
DL Reading DSkovholt
PWR-4 Reading FSchroeder
RCDeYoung RFMaccary
PWR Branch Chiefs DKnuth
RWKlecker RTedesco
Licensing Assistant
Project Leader HDenton
DDavis OGC
RO (4)

CRESS:dp T4132, R05	L:PWR-4 OKP	L:PWR-4 AS	L:RSYS RTM for	L:AD/PWR RCDeYoung		
T6104, SURNAME 7/10/72	DDavis:dp 7/12/72	ASchwencer 7/12/72	VStello 7/12/72	7/12/72		