



Pinanski Building
One University Avenue
Lowell, Massachusetts 01854
tel: 978.934.3366
fax: 978.934.4067
url: www.uml.edu/radlab

RADIATION LABORATORY

January 12, 2016

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Re: License Amendment Request, License No. R-125, Docket No. 50-223

The University of Massachusetts Lowell hereby requests review of an amendment to License No. R-125 Technical Specification 4.4 *Containment Building*. The requested change is to extend the surveillance interval for performing an integrated leak rate test as specified in Technical Specification 4.4.3 from 5 years to 10 years.

A detailed justification for this request is provided in the enclosed document. A draft of the affected Technical Specifications page associated with the proposed change is also enclosed.

Please exempt this request from fees per 10CFR170.11.a.(4).

Please direct any requests for additional information regarding this submittal to:

Mr. Leo Bobek, Reactor Supervisor
Radiation Laboratory
University of Massachusetts Lowell
One University Avenue
Lowell, MA 01854

I declare under penalty of perjury that the foregoing is true and correct.

Sincerely,

A handwritten signature in black ink, appearing to read 'Leo M. Bobek'.

Leo M. Bobek
Reactor Supervisor, Radiation Laboratory

Enclosure