

Docket Nos.: 50-269, 50-270
and 50-287

MAR 25 1976

Duke Power Company
ATTN: Mr. William O. Parker, Jr.
Vice President - Steam Production
422 South Church Street
P. O. Box 2178
Charlotte, North Carolina 28242

Gentlemen:

This letter is in response to a telephone request from Mr. Tuckman of your staff concerning a July 9, 1975 request to modify specification 3.9.7 of Appendix A for the Oconee Nuclear Station. Mr. Tuckman requested this letter in order to close the Duke Power Company files on this matter.

The July 9, 1975 letter resulted from a July 8 incidence when a waste discharge valve failed to remain closed while source checking the effluent monitor. The action requested was to utilize personnel surveillance of the effluent monitors to detect alarm conditions, and subsequent manual action to terminate the waste discharge.

The staff had reviewed the change request; however, as a result of the corrective action taken (Abnormal Occurrence Report AO-269/75-9 dated July 18, 1975), the staff considered the change unnecessary and no further action was taken.

To complete your records on this matter the NRC staff is denying your request for technical specification change dated July 9, 1975.

Sincerely,

Original signed by W. H. Regan, Jr.

William Regan, Chief
Environmental Projects Branch 3
Division of Site Safety and
Environmental Analysis

cc: See attached list

OFFICE ☐

SURNAME ☐

DATE ☐

Duke Power Company

2

MAR 25 1976

cc: Mr. William L. Porter
Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

Mr. Troy B. Conner
Conner & Knotts
1747 Pennsylvania Avenue, N. W.
Suite 1050
Washington, D. C. 20006

DISTRIBUTION:

DOCKET FILE (ENVIRON)

EP-3 Reading

DSE Reading

NRR Reading

NRC-PDR

Local-PDR

OELD

VMoore

DScaletti/WRegan

MDuncan

ACRS (16)

RPurple/GZech

x36990

OFFICE ➤

DSE:EP-3

~~DOR:OR-1~~

DSE:EP-3

SURNAME ➤

DScaletti/1k

~~GZech~~

WRegan

DATE ➤

3/25/76

~~3/ /76~~

3/25/76