

**NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)**

CONTROL NO: 12808
FILE: _____

FROM: Duke Power Co. Charlotte, N. C. William O. Parker, Jr.			DATE OF DOC 10-31-75	DATE REC'D 11-8-75	LTR XXX	TWX	RPT	OTHER
TO: Benard C. Rusche			ORIG 3 Signed	CC	OTHER	SENT NRC PDR <u>XXXX</u> SENT LOCAL PDR <u>XXX</u>		
CLASS	UNCLASS XXXX	PROP INFO	INPUT	NO CYS REC'D 3	DOCKET NO: 50-269 <u>270</u> 287			

DESCRIPTION:
Ltr. notrized 10-31-75....Re our ltrs. of 10-14-
and 10-15-75...Trans the following.....

ENCLOSURES:
Additional information relative to the Oconee
Nuclear Station ECCS analysis, With Attach.
1-4.....

PLANT NAME: Oconee 1,2,&3

ACKNOWLEDGED
(Rec'd 3 cys. Encl.)
DO NOT REMOVE

FOR ACTION/INFORMATION

VCR 11-13-75

BUTLER (L) W/ Copies	SCHWENCER (L) W/ Copies	ZIEMANN (L) W/ Copies	REGAN (E) W/ Copies	REID (L) W/ COPIES
CLARK (L) W/ Copies	STOLZ (L) W/ Copies	DICKER (E) W/ Copies	LEAR (L) W/ Copies	
PARR (L) W/ Copies	VASSALLO (L) W/ Copies	KNIGHTON (E) W/ Copies	SPIES W/ Copies	
KNIEL (L) W/ Copies	PURPLE (L) W/ Copies	YOUNGBLOOD (E) W/ Copies	LPH W/ Copies	

INTERNAL DISTRIBUTION

REG. FILE NRC PDR	TECH REVIEW SCHROEDER	DENTON GRIMES	LIC ASST R. DIGGS (L)	A/T IND. BRAITMAN
OGC, ROOM P-506A	MACCARY	GAMMILL	H. GEARIN (L)	SALTZMAN
GOSSICK/STAFF	KNIGHT	KASTNER	E. GOULBOURNE (L)	MELTZ
CASE	PAWLICKI	BALLARD	P. KREUTZER (E)	
GIAMBUSO	SHAO	SPANGLER	J. LEE (L)	PLANS
BOYD	STELLO		M. RUSHBROOK (L)	MCDONALD
MOORE (L)	HOUSTON	ENVIRO	S. REED (E)	CHAPMAN
DEYOUNG (L)	NOVAK	MULLER	M. SERVICE (L)	DUBE (Ltr)
SKOVHOLT (L)	ROSS	DICKER	S. SHEPPARD (L)	E. COUPE
GOLLER (L) (Ltr)	IPPOLITO	KNIGHTON	M. SLATER (E)	PETERSON
P. COLLINS	TEDESCO	YOUNGBLOOD	H. SMITH (L)	HARTFIELD (2)
DENISE	J. COLLINS	REGAN	S. TEETS (L)	KLECKER
REG OPR	LAINAS	PROJECT LDR	G. WILLIAMS (E)	EISENHUT
FILE & REGION (2)	BENAROYA		V. WILSON (L)	WIGGINTON
MIPC	VOLLMER	WALLES	R. INGRAM (L)	
	PAWLICKI		M. DUNCAN (E)	

EXTERNAL DISTRIBUTION

1 - LOCAL PDR <i>Thalhalla S.C.</i>	1 - NATIONAL LABS	1 - PDR-SAN/LA/NY
1 - TIC (ABERNATHY)	1 - W. PENNINGTON, Rm E-201 GT	1 - BROOKHAVEN NAT LAB
1 - NSIC (BUCHANAN)	1 - CONSULTANTS	1 - G. ULRIKSON ORNL
1 - ASLB	NEWMARK/BLUME/AGBABIAN	
1 - Newton Anderson		
16 ACRS HOLDING/SENT <i>Sheppard</i>		

JPJ

GCCS

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

Regulatory Docket File

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

TELEPHONE: AREA 704
373-4083

October 31, 1975

Mr. Benard C. Rusche
Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. R. A. Purple, Chief
Operating Reactors Branch #1



Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Mr. Rusche:

With regard to your letters of October 14 and 15, 1975 concerning requests for additional information relative to the Oconee Nuclear Station ECCS analysis, Attachments 1 and 2 are provided.

As you are aware, Amendment 6 of the Oconee Unit 1 Facility Operating License, DPR-38, revised Technical Specifications to permit operation within the appropriate fuel and core design limits during the second fuel cycle. The proposed control rod withdrawal limit for four-pump operation (Figure 3.5.2-1A2) after 250 ± 5 full power days of operation was not included. The omission of this curve was due to the expected approval of Technical Specifications based on the ECCS Final Acceptance Criteria before the curve would be required. On July 9, 1975, an analysis of Oconee ECCS performance using an approved evaluation model was submitted. This submittal included revised control rod withdrawal curves for Oconee 1 Cycle 2 operation.

Currently, Oconee Unit 1, Cycle 2 measured boron concentration data indicate that it may be necessary to begin removal of the Group 7 control rods from the core as early as 235 EFPD, rather than the originally estimated 245-255 EFPD. The associated small discrepancy, approximately 20 ppmB, between the measured and the predicted boron concentration at this core lifetime, is well within the tolerance of calculational uncertainties. In order to assure the continued full power operation of Oconee 1, revised Final Acceptance Criteria control rod position limits and operational power imbalance envelopes have been prepared which permit withdrawal of Group 7 control rods 245 ± 10 EFPD



12808

Mr. Benard C. Rusche


Page 2

October 31, 1975

(in lieu of 250 ± 5 EFPD proposed in July 9, 1975 submittal). Therefore, pursuant to 10CFR50, §50.90 and the provisions of the Commission's December 27, 1975 Order for Modification of License for Oconee Nuclear Station, Units 1, 2, and 3, it is requested that the control rod position limit and operational power imbalance envelope described in Attachment 3 be approved prior to attaining 235 EFPD on Oconee 1. Presently, with expected capacity factors, it is estimated that this will occur on November 28, 1975.

The limitation on power operation with one idle reactor coolant pump in each loop would be imposed since the ECCS cooling performance has not been calculated in accordance with the Final Acceptance Criteria requirements specifically for this mode of operation. Pursuant to 10CFR50, §50.90, a revision to Oconee Technical Specification 3.1.1 is requested which will permit operation for a period of five days with one idle reactor coolant pump in each loop. This time period could allow repairs to the idle pumps and the return to an acceptable combination of operating reactor coolant pumps. The five days for this mode of operation is acceptable since this mode of operation is expected to have considerable margin for the peak cladding temperature limit and since the likelihood of a LOCA within the five day period is considered very remote. Proposed Technical Specification replacement pages are provided in Attachment 4.

Very truly yours,




William O. Parker, Jr.

MST:vr

Attachments


Mr. Benard C. Rusche
Page 3
October 31, 1975

WILLIAM O. PARKER, JR., being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47 and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.




William O. Parker, Jr., Vice President

ATTEST



John C. Goodman, Jr.
Assistant Secretary

Subscribed and sworn to before me this 31st day of October, 1975.


Edna B. Farmer
Notary Public

My Commission Expires:

October 24, 1977