

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-269/270/287

REC: OREILLY J P
NRC

ORG: PARKER W O
DUKE PWR

DOCDATE: 01/31/78
DATE RCVD: 02/06/78

DOCTYPE: LETTER NOTARIZED: NO

COPIES RECEIVED

SUBJECT:

LTR 1 ENCL 1

LICENSEE EVENT REPORT RO-269/78-2 ON 1/5/78 CONCERNING KEOWEE HYDRO
UNIT 1 NOT VERIFIED OPERABLE WITHIN ONE HOUR OF TAKING UNIT 2 OUT OF
SERVICE.

PLANT NAME: OCONEE - UNIT 1
OCONEE - UNIT 2
OCONEE - UNIT 3

REVIEWER INITIAL: XEF
DISTRIBUTER INITIAL:

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

NOTES:

1. M. CUNNINGHAM - ALL AMENDMENTS TO FSAR AND CHANGES TO TECH SPECS

INCIDENT REPORTS
(DISTRIBUTION CODE A002)

FOR ACTION: BRANCH CHIEF SCHWENCER**W/4 ENCL

INTERNAL:

REG FILE**W/ENCL

I & E**W/2 ENCL

SCHROEDER/IPPOLITO**W/ENCL

NOVAK/CHECK**W/ENCL

KNIGHT**W/ENCL

HANAUER**W/ENCL

EISENHUT**W/ENCL

SHAD**W/ENCL

KREGER/J. COLLINS**W/ENCL

L. CROCKER**W/ENCL

NRC PDR**W/ENCL

MIPC**W/3 ENCL

HOUSTON**W/ENCL

GRIMES**W/ENCL

BUTLER**W/ENCL

TEDESCO**W/ENCL

BAER**W/ENCL

VOLLNER/BUNCH**W/ENCL

ROSA**W/ENCL

EXTERNAL:

LPDR/S

WALHALLA, SC**W/ENCL

TIC**W/ENCL

NSIC**W/ENCL

ACRS CAT B**W/16 ENCL

DISTRIBUTION: LTR 45 ENCL 45
SIZE: 1P+2P

CONTROL NBR: 780390034

***** THE END *****

ao⁴lv

DUKE POWER COMPANY
POWER BUILDING
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28202

REGULATORY DOCKET FILE COPY

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

January 31, 1978

TELEPHONE: AREA 704
373-4083

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Suite 1217
230 Peachtree Street, Northwest
Atlanta, Georgia 30303

RE: Oconee Units 1,2,3
Docket Nos. 50-269, -270, -287

Dear Mr. O'Reilly:

Pursuant to Sections 6.2 and 6.6.2 of the Oconee Nuclear Station
Technical Specifications, please find attached Reportable Occurrence
Report RO-269/78-2.

Very truly yours,

William O. Parker Jr. by WAH
William O. Parker, Jr.

KRW:ge
Attachment

cc: Director, Office of Management Information
and Program Control

A002/S
0/1

Report Number: RO-269/78-2

Report Date: January 31, 1978

Occurrence Date: January 5, 1978

Facility: Oconee Units 1, 2 and 3, Seneca, South Carolina

Identification of Occurrence: Keowee Hydro Unit 1 not verified operable within one hour of taking Unit 2 out of service.

Conditions Prior to Incident: Unit 1 100% FP
Unit 2 90% FP
Unit 3 71% FP

Description of Occurrence

On January 5 at 1040 Keowee Hydro Unit 2 (a source of auxillary power to the Oconee Nuclear Station) was taken out of service for maintenance resulting in the disabling at the emergency start feature of the unit. At 1600 the unit was returned to service and verified operable. Keowee Unit 1 was not, however, verified operable until 1609. Technical Specification 3.7.2(b) requires that in such an instance the other Keowee Unit (Unit 1) be verified operable within one hour of removal of the unit (Unit 2) from service.

Apparent Cause of Occurrence

The apparent cause of the delay in checking Keowee Unit 1 operability was failure to follow established procedures (personnel error). Procedure OP/O/A/1106/19 provides steps to assure that the requirements of Technical Specification 3.7.2(b) are met.

Analysis of Occurrence

Technical Specifications state that one Keowee Hydro Unit may be inoperable for periods not exceeding 72 hours for tests and maintenance provided the other Keowee Unit is connected to the underground feeder cable and verified operable. Keowee Unit 1 was connected to the underground feeder cable and was operable when checked. All off-site sources of emergency power and all Oconee Nuclear Station Units were available for emergency power if needed. The health and safety of the public were not endangered by this incident.

Corrective Action

All operators associated with this incident reviewed the applicable Technical Specifications and operating procedures.

LICENSEE EVENT REPORT

EXHIBIT A

[illegible]