

50-269/270/287

## NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER  
INCIDENT REPORT

TO: Mr. Norman C. Mosley

FROM: Duke Power Co.  
Charlotte, N.C. 28242  
Wm. O. Parker, Jr.DATE OF DOCUMENT  
9-10-76DATE RECEIVED  
9-27-76☒ LETTER  
☒ ORIGINAL  
☐ COPY☐ NOTORIZED  
☒ UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

1 signed

DESCRIPTION Ltr re their 6-23-76 ltr, their 8-16-76 ltr...furn addl info on RO-50-269/76-9 involving transmission lines....

ENCLOSURE

PLANT NAME: Oconee Units 1-2-3

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED  
SEND DIRECTLY TO KREGER/J. COLLINSACKNOWLEDGED  
Do Not Remove

## FOR ACTION/INFORMATION

DHL 9-29-76

BRANCH CHIEF:

Schwenger

W/3 CYS FOR ACTION

LIC. ASST.:

Sheppard

W/1 CYS

ACRS 16 CYS SENT TO LA

## INTERNAL DISTRIBUTION

REG FILE (3)

NRC PDR (3)

I &amp; E (2)

MIPC

SCHROEDER/IPPOLITO

HOUSTON

NOVAK/CHECK

GRIMES

CASE

BUTLER

HANAUER

TEDESCO/MACCARY

EISENHUT

BAER

SHAO

VOLLMER/HUNCH

KREGER/J. COLLINS

## EXTERNAL DISTRIBUTION

LEDR: WALKER, S.C.

TTC:

NSIC:

CONTROL NUMBER

9696

DUKE POWER COMPANY  
POWER BUILDING  
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.  
VICE PRESIDENT  
STEAM PRODUCTION


TELEPHONE: AREA 704  
373-4083

Regulatory Docket File

September 10, 1976

Mr. Norman C. Moseley, Director  
U. S. Nuclear Regulatory Commission  
Suite 818  
230 Peachtree Street, Northwest  
Atlanta, Georgia 30303


Re: Oconee Nuclear Station  
Docket Nos. 50-269, -270, 287



Dear Mr. Moseley:


Reportable Occurrence Report RO-269/76-9, which was submitted by our letter of June 23, 1976, described an incident in which Keowee Hydro Station Unit 2 was inadvertently separated from the underground and overhead transmission lines. A supplemental response to this report, submitted by our letter of August 16, 1976, stated that additional corrective action involving the electrical termination of control wiring would be completed by September 13, 1976. This corrective action is being performed, but due to problems encountered with material procurement and qualification, and due to an unanticipated large number of manhours required, this work is now scheduled to be completed no later than October 15, 1976.

Very truly yours,

  
William O. Parker, Jr.

EDB:vr

cc: Director, Office of Management Information  
and Program Control



5696