

FROM: Duke Power Company Charlotte, N.C. A.C.Thies			DATE OF DOC 11-8-74	DATE REC'D 11-11-74	LTR XXXXX	TWX	RPT	OTHER
TO: Director of Regulatory Operations			ORIG 1-signed	CC	OTHER	SENT AEC PDR XXXXXXXX SENT LOCAL PDR XXXXXXXX		
CLASS	UNCLASS	PROP INFO	INPUT	NO CYS REC'D 1		DOCKET NO: <u>50-269</u> , 50-270, and 50-287		
DESCRIPTION: Ltr trans the following... <b>ACKNOWLEDGED</b>  <b>DO NOT REMOVE</b>  PLANT NAME: Oconee 1-2-3				ENCLOSURES:  Monthly Report for <u>October</u> Plant & Component Operability & Availability This Report to be used in preparing Grey Book by Plans & Operations.  No. of Cys Rec'd <u>1</u>				

FOR ACTION/INFORMATION

11-16-74 JGB

BUTLER(L)	SCHWENGER(L)	ZIERHANN(L)	REGAN(E)
W/ Copies	W/ Copies	W/ Copies	W/ Copies
CLARK(L)	STOLZ(L)	DICKER(E)	LEAR(L)
W/ Copies	W/ Copies	W/ Copies	W/ Copies
PARR(L)	VASSALLO(L)	KNIGHTON(E)	W. Magee
W/ Copies	W/ Copies	W/ Copies	W/2 Copies
KNIEL(L)	PURPLE (L)	YOUNGBLOOD(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies

REG FILE

AEC PDR  
OGC, ROOM P-506A  
MUNTING/STAFF  
CASE  
GIAMBUSSO  
BOYD  
MOORE (L)(EWR)  
DEYOUNG (L)(FWR)  
SKOVHOLT (L)  
COLLER (L)  
P. COLLINS  
DENISE  
REG-OPR  
FILE & REGION (2)  
MORRIS  
STEELE

TECH REVIEW

SCHROEDER  
MACCARY  
KNIGHT  
PAWLICKI  
SHAO  
STELLO  
HOUSTON  
NOVAK  
ROSS  
IPPOLITO  
TEDESCO  
LONG  
LAINAS  
BENAROYA  
VOLPER

DETECT

GRIMES  
GARMILL  
KASTNER  
BALLARD  
SPANGLER  
  
ENVIRO  
MULLER  
DICKER  
KNIGHTON  
YOUNGBLOOD  
REGAN  
PROJECT LDR  
  
HARLESS

LIC ASST

DIGGS (L)  
GEARIN (L)  
GOULBOURNE (L)  
KREUTZER (E)  
LEE (L)  
MAIGRET (L)  
REED (E)  
SERVICE (L)  
SHEPPARD (L)  
SLATER (E)  
SMITH (L)  
TEETS (L)  
WILLIAMS (E)  
WILSON (L)

A/T LTR

BRAITMAN  
SALTZMAN  
B. HURT  
  
PLANS  
✓ MCDONALD  
✓ CHAPMAN  
DUBE w/input  
E. COUPE  
D. THOMPSON (2)  
KLECKER  
EISENHUT

FEDERAL DISTRIBUTION

✓ 1 - LOCAL PDR Walhalla, SC  
✓ 1 - TIC (ASER/ATNY)  
✓ 1 - NSIC (BUCHANAN)  
1 - ASLB  
1 - Newton Anderson  
16 - ACRS HOLDING

(1)(2)(10)-NATIONAL LABS  
1-ASLB(E/W Bldg, Rm 529)  
1-W. PENNINGTON, Rm E-201 GT  
1-B&M SWINEBROOK, Rm E-201 GT  
1-CONSULTANTS  
NEUMARK/BLUM/AGABIAN  
GT

1-PDR-SANITARY  
1-DROGHDAVY  
1-G. CLARKSON, Rm  
1-ACMEB (Rm 101)  
Rm E-127 GT  
1-RD. ATLAS, Rm  
GT

DR Central Files

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28201

A. C. THIES  
SENIOR VICE PRESIDENT  
PRODUCTION AND TRANSMISSION

P. O. Box 2178

November 8, 1974

Regulatory

File Cy.

Director of Regulatory Operations  
U. S. Atomic Energy Commission  
Washington, D. C. 20545

Re: Oconee Nuclear Station  
Docket Nos. 50-269, -270, and -287



Dear Sir:


Please find attached information concerning the performance and operating status of the Oconee Nuclear Station for the month of October, 1974. This information is in the format recommended in Regulatory Guide 1.16, Revision 2. Please note that Oconee Unit 2 commenced commercial operation on September 9, 1974. Information presented herein is cumulative from that date.

Very truly yours,

*A.C. Thies*  
A. C. Thies

ACT:vr  
Attachments

cc: Mr. Norman C. Moseley



~~11559~~  
11559

UNIT Oconee Unit 1DATE 11/8/74DOCKET NO. 50-269

## OPERATING STATUS

1. REPORTING PERIOD: October 1, 1974 THROUGH October 31, 1974  
 HOURS IN REPORTING PERIOD: 745  
 2. CURRENTLY AUTHORIZED POWER LEVEL (MWth) 2568 MAX. DEPENDABLE CAPACITY (MWe-NET) 871  
 3. LOWEST POWER LEVEL TO WHICH SPECIFICALLY RESTRICTED (IF ANY) (MWe-NET): None  
 4. REASONS FOR RESTRICTION (IF ANY):

	THIS REPORTING PERIOD	YR TO DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL . . . . .	<u>383.1</u>	<u>5446.6</u>	<u>9800.5</u>
6. REACTOR RESERVE SHUTDOWN HOURS . . . . .	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE . . . . .	<u>340.5</u>	<u>5265.2</u>	<u>8254.3</u>
8. UNIT RESERVE SHUTDOWN HOURS . . . . .	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH) . . . . .	<u>690694</u>	<u>12226629</u>	<u>18237510</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH) . . . . .	<u>227472</u>	<u>4230112</u>	<u>6318700</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH) . . . . .	<u>209487</u>	<u>4000606</u>	<u>5959684</u>
12. REACTOR AVAILABILITY FACTOR (1) . . . . .	<u>51.4</u>	<u>74.7</u>	<u>86.3</u>
13. UNIT AVAILABILITY FACTOR (2) . . . . .	<u>49.3</u>	<u>72.5</u>	<u>72.9</u>
14. UNIT CAPACITY FACTOR (3) . . . . .	<u>32.3</u>	<u>62.9</u>	<u>60.3</u>
15. UNIT FORCED OUTAGE RATE (4) . . . . .	<u>19.8</u>	<u>7.0</u>	<u>7.7</u>
16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH):			

17. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: November 24, 1974  
 18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

	DATE LAST FORECAST	DATE ACHIEVED
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICAL POWER GENERATION	_____	_____
COMMERCIAL OPERATION	_____	_____

- (1) REACTOR AVAILABILITY FACTOR =  $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$   
 (2) UNIT AVAILABILITY FACTOR =  $\frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$   
 (3) UNIT CAPACITY FACTOR =  $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{MAX. DEPENDABLE CAPACITY (MWe-NET)} \times \text{HOURS IN REPORTING PERIOD}}$   
 (4) UNIT FORCED OUTAGE RATE =  $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$

# UNIT SHUTDOWNS

DOCKET NO. 50-269

UNIT NAME Oconee Unit 1.

DATE November 18, 1974

REPORT MONTH October, 1974

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
14	741005	F	73.5	B	1	
15	741016	F	17.0	A	3	
16	741019	S	287.5	C	1	
						<p>(1) REASON</p> <p>A-EQUIPMENT FAILURE (EXPLAIN)</p> <p>B-MAINT. OR TEST.</p> <p>C-REFUELING</p> <p>D-REGULATORY RESTRICTION</p> <p>E-OPERATOR TRAINING AND LICENSE EXAMINATION</p> <p>F-ADMINISTRATIVE</p> <p>G-OPERATIONAL ERROR (EXPLAIN)</p> <p>H-OTHER (EXPLAIN)</p> <p>(2) METHOD</p> <p>1-MANUAL</p> <p>2-MANUAL SCRAM</p> <p>3-AUTOMATIC SCRAM</p>

SUMMARY:

DOCKET NO. 50-269UNIT Oconee 1DATE 11/8/74**AVERAGE DAILY UNIT POWER LEVEL**MONTH October, 1974

AVERAGE DAILY POWER LEVEL (MWe-net)		AVERAGE DAILY POWER LEVEL (MWe-net)	
DAY		DAY	
1	816	17	249
2	789	18	462
3	706	19	-0-
4	706	20	-0-
5	375	21	-0-
6	-0-	22	-0-
7	-0-	23	-0-
8	38	24	-0-
9	369	25	-0-
10	561	26	-0-
11	681	27	-0-
12	690	28	-0-
13	702	29	-0-
14	733	30	-0-
15	736	31	-0-
16	276		

**DAILY UNIT POWER LEVEL FORM INSTRUCTIONS**

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

UNIT Oconee II  
DATE 11/8/74

DOCKET NO. 50-270

OPERATING STATUS

1. REPORTING PERIOD: October 1, 1974 THROUGH October 31, 1974  
HOURS IN REPORTING PERIOD: 745  
2. CURRENTLY AUTHORIZED POWER LEVEL (MWth) 2568 MAX. DEPENDABLE CAPACITY (MWe-NET) 871  
3. LOWEST POWER LEVEL TO WHICH SPECIFICALLY RESTRICTED (IF ANY) (MWe-NET): None  
4. REASONS FOR RESTRICTION (IF ANY):

	THIS REPORTING PERIOD	YR TO DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL . . . . .	<u>203.0</u>	<u>699.0</u>	<u>699.0</u>
6. REACTOR RESERVE SHUTDOWN HOURS . . . . .	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE . . . . .	<u>190.5</u>	<u>623.9</u>	<u>623.9</u>
8. UNIT RESERVE SHUTDOWN HOURS . . . . .	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH) . . . . .	<u>403970</u>	<u>1337839</u>	<u>1337839</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH) . . . . .	<u>137340</u>	<u>455996</u>	<u>455996</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH) . . . . .	<u>125397</u>	<u>425153</u>	<u>425153</u>
12. REACTOR AVAILABILITY FACTOR (1) . . . . .	<u>27.2</u>	<u>52.6</u>	<u>52.6</u>
13. UNIT AVAILABILITY FACTOR (2) . . . . .	<u>25.6</u>	<u>49.0</u>	<u>49.0</u>
14. UNIT CAPACITY FACTOR (3) . . . . .	<u>19.3</u>	<u>38.3</u>	<u>38.3</u>
15. UNIT FORCED OUTAGE RATE (4) . . . . .	<u>74.4</u>	<u>50.7</u>	<u>50.7</u>
16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH):			
17. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:			
18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:			

	DATE LAST FORECAST	DATE ACHIEVED
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICAL POWER GENERATION	_____	_____
COMMERCIAL OPERATION	_____	_____

- (1) REACTOR AVAILABILITY FACTOR =  $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$   
(2) UNIT AVAILABILITY FACTOR =  $\frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$   
(3) UNIT CAPACITY FACTOR =  $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{MAX. DEPENDABLE CAPACITY (MWe-NET)} \times \text{HOURS IN REPORTING PERIOD}}$   
(4) UNIT FORCED OUTAGE RATE =  $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$

# UNIT SHUTDOWNS

DOCKET NO. 50-270  
UNIT NAME Oconee Unit 2  
DATE November 8, 1974

REPORT MONTH September, 1974

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
1	740909	F	13.9	B	3	
2	740917	F	15.8	B	3	
3	740923	F	3.5	A	3	
4	740927	F	3.5	A	3	
5	740928	F	49.2	A	1	
						<p>(1) REASON  A-EQUIPMENT FAILURE (EXPLAIN)  B-MAINT. OR TEST.  C-REFUELING  D-REGULATORY RESTRICTION  E-OPERATOR TRAINING AND  LICENSE EXAMINATION  F-ADMINISTRATIVE  G-OPERATIONAL ERROR  (EXPLAIN)  H-OTHER (EXPLAIN)</p> <p>(2) METHOD  1-MANUAL  2-MANUAL  SCRAM  3-AUTOMATIC  SCRAM</p>

SUMMARY:

# UNIT SHUTDOWNS

DOCKET NO. 50-270  
 UNIT NAME Oconee Unit 2  
 DATE November 18, 1974

REPORT MONTH October, 1974

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
5	740928	F	554.5	A	1	<div> <div> (1) REASON  A-EQUIPMENT FAILURE (EXPLAIN)  B-MAINT. OR TEST  C-REFUELING  D-REGULATORY RESTRICTION  E-OPERATOR TRAINING AND  LICENSE EXAMINATION  F-ADMINISTRATIVE  G-OPERATIONAL ERROR  (EXPLAIN)  H-OTHER (EXPLAIN) </div> <div> (2) METHOD  1-MANUAL  2-MANUAL  SCRAM  3-AUTOMATIC  SCRAM </div> </div>

SUMMARY:



DOCKET NO. 50-270  
UNIT Oconee 2  
DATE 11/8/74

**AVERAGE DAILY UNIT POWER LEVEL**

MONTH October, 1974

DAY	AVERAGE DAILY POWER LEVEL (MWe-net)
1	<u>-0-</u>
2	<u>-0-</u>
3	<u>-0-</u>
4	<u>-0-</u>
5	<u>-0-</u>
6	<u>-0-</u>
7	<u>-0-</u>
8	<u>-0-</u>
9	<u>-0-</u>
10	<u>-0-</u>
11	<u>-0-</u>
12	<u>-0-</u>
13	<u>-0-</u>
14	<u>-0-</u>
15	<u>-0-</u>
16	<u>-0-</u>

DAY	AVERAGE DAILY POWER LEVEL (MWe-net)
17	<u>-0-</u>
18	<u>-0-</u>
19	<u>-0-</u>
20	<u>-0-</u>
21	<u>-0-</u>
22	<u>-0-</u>
23	<u>-0-</u>
24	<u>312</u>
25	<u>646</u>
26	<u>553</u>
27	<u>630</u>
28	<u>799</u>
29	<u>819</u>
30	<u>835</u>
31	<u>834</u>

**DAILY UNIT POWER LEVEL FORM INSTRUCTIONS**

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

UNIT Oconee IIIDATE 11/8/74DOCKET NO. 50-287

## OPERATING STATUS

1. REPORTING PERIOD: October 1, 1974 THROUGH October 31, 1974  
 HOURS IN REPORTING PERIOD: 745
2. CURRENTLY AUTHORIZED POWER LEVEL (MWth) 2568 MAX. DEPENDABLE CAPACITY (MWe-NET) \_\_\_\_\_
3. LOWEST POWER LEVEL TO WHICH SPECIFICALLY RESTRICTED (IF ANY) (MWe-NET): None
4. REASONS FOR RESTRICTION (IF ANY): \_\_\_\_\_

	THIS REPORTING PERIOD	YR TO DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL . . . . .	<u>350.58</u>	<u>489.98</u>	<u>489.98</u>
6. REACTOR RESERVE SHUTDOWN HOURS . . . . .	<u>N/A</u>		
7. HOURS GENERATOR ON LINE . . . . .	<u>284.35</u>	<u>355.65</u>	<u>355.65</u>
8. UNIT RESERVE SHUTDOWN HOURS . . . . .	<u>N/A</u>		
9. GROSS THERMAL ENERGY GENERATED (MWH) . . . . .	<u>N/A</u>		
10. GROSS ELECTRICAL ENERGY GENERATED (MWH) . . . . .	<u>76949</u>	<u>76949</u>	<u>76949</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH) . . . . .	<u>N/A</u>		
12. REACTOR AVAILABILITY FACTOR (1) . . . . .	<u>N/A</u>		
13. UNIT AVAILABILITY FACTOR (2) . . . . .	<u>N/A</u>		
14. UNIT CAPACITY FACTOR (3) . . . . .	<u>N/A</u>		
15. UNIT FORCED OUTAGE RATE (4) . . . . .	<u>N/A</u>		
16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH):			

17. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: \_\_\_\_\_
18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

	DATE LAST FORECAST	DATE ACHIEVED
INITIAL CRITICALITY		<u>9/5/74</u>
INITIAL ELECTRICAL POWER GENERATION		<u>9/18/74</u>
COMMERCIAL OPERATION	<u>12/1/74</u>	

- (1) REACTOR AVAILABILITY FACTOR =  $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (2) UNIT AVAILABILITY FACTOR =  $\frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (3) UNIT CAPACITY FACTOR =  $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{MAX. DEPENDABLE CAPACITY (MWe-NET)} \times \text{HOURS IN REPORTING PERIOD}}$
- (4) UNIT FORCED OUTAGE RATE =  $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$

DK Central File

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28201

A. C. THIES

SENIOR VICE PRESIDENT

PRODUCTION AND TRANSMISSION

P. O. Box 2178

November 12, 1974

Director of Regulatory Operations  
U. S. Atomic Energy Commission  
Washington, D. C. 20545

Re: Oconee Nuclear Station  
Docket Nos. 50-269, -270, and -287

Dear Sir:

My letter of November 8, 1974 transmitted information concerning the performance and operating status of the Oconee Nuclear Station for the month of October, 1974. Since then, two errors have been discovered in the data and have been called to the attention of Mr. S. Chapman of your staff. Please find attached corrected copies of this information.

Very truly yours,

*A. C. Thies*

A. C. Thies

ACT:vr

Attachments

cc: Mr. N. C. Moseley

*Summary Rpt.*  
*2*

CORRECTED COPY

UNIT Oconee Unit 1DATE 11/8/74DOCKET NO. 50-269

## OPERATING STATUS

1. REPORTING PERIOD: October 1, 1974 THROUGH October 31, 1974  
 HOURS IN REPORTING PERIOD: 745
2. CURRENTLY AUTHORIZED POWER LEVEL (MWth) 2568 MAX. DEPENDABLE CAPACITY (MWe-NET) 871
3. LOWEST POWER LEVEL TO WHICH SPECIFICALLY RESTRICTED (IF ANY) (MWe-NET): None
4. REASONS FOR RESTRICTION (IF ANY):

	THIS REPORTING PERIOD	YR TO DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL . . . . .	<u>383.1</u>	<u>5446.6</u>	<u>9800.5</u>
6. REACTOR RESERVE SHUTDOWN HOURS . . . . .	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE . . . . .	<u>367.1</u>	<u>5291.7</u>	<u>8280.8</u>
8. UNIT RESERVE SHUTDOWN HOURS . . . . .	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH) . . . . .	<u>690694</u>	<u>12226629</u>	<u>18237510</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH) . . . . .	<u>227472</u>	<u>4230112</u>	<u>6318700</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH) . . . . .	<u>209487</u>	<u>4000606</u>	<u>5959684</u>
12. REACTOR AVAILABILITY FACTOR (1) . . . . .	<u>51.4</u>	<u>74.7</u>	<u>86.3</u>
13. UNIT AVAILABILITY FACTOR (2) . . . . .	<u>49.3</u>	<u>72.5</u>	<u>72.9</u>
14. UNIT CAPACITY FACTOR (3) . . . . .	<u>32.3</u>	<u>62.9</u>	<u>60.3</u>
15. UNIT FORCED OUTAGE RATE (4) . . . . .	<u>19.8</u>	<u>7.0</u>	<u>7.7</u>
16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH):			

17. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: December 1, 1974
18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

	DATE LAST FORECAST	DATE ACHIEVED
INITIAL CRITICALITY	<u>          </u>	<u>          </u>
INITIAL ELECTRICAL POWER GENERATION	<u>          </u>	<u>          </u>
COMMERCIAL OPERATION	<u>          </u>	<u>          </u>

- (1) REACTOR AVAILABILITY FACTOR =  $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (2) UNIT AVAILABILITY FACTOR =  $\frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (3) UNIT CAPACITY FACTOR =  $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{MAX. DEPENDABLE CAPACITY (MWe-NET)} \times \text{HOURS IN REPORTING PERIOD}}$
- (4) UNIT FORCED OUTAGE RATE =  $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$

CORRECTED COPY

UNIT Oconee IIIDATE 11/8/74DOCKET NO. 50-287~~OPERATING STATUS~~

1. REPORTING PERIOD: October 1, 1974 THROUGH October 31, 1974  
 HOURS IN REPORTING PERIOD: 745
2. CURRENTLY AUTHORIZED POWER LEVEL (MW<sub>th</sub>) 2568 MAX. DEPENDABLE CAPACITY (MW<sub>e</sub>-NET) \_\_\_\_\_
3. LOWEST POWER LEVEL TO WHICH SPECIFICALLY RESTRICTED (IF ANY) (MW<sub>e</sub>-NET): None
4. REASONS FOR RESTRICTION (IF ANY): \_\_\_\_\_

	THIS REPORTING PERIOD	YR TO DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL	<u>350.58</u>	<u>489.98</u>	<u>489.98</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>N/A</u>		
7. HOURS GENERATOR ON LINE	<u>284.35</u>	<u>355.65</u>	<u>355.65</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>N/A</u>		
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>N/A</u>		
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>70181</u>	<u>76949</u>	<u>76949</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>N/A</u>		
12. REACTOR AVAILABILITY FACTOR (1)	<u>N/A</u>		
13. UNIT AVAILABILITY FACTOR (2)	<u>N/A</u>		
14. UNIT CAPACITY FACTOR (3)	<u>N/A</u>		
15. UNIT FORCED OUTAGE RATE (4)	<u>N/A</u>		
16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH):			

17. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: \_\_\_\_\_
18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

	DATE LAST FORECAST	DATE ACHIEVED
INITIAL CRITICALITY		<u>9/5/74</u>
INITIAL ELECTRICAL POWER GENERATION		<u>9/18/74</u>
COMMERCIAL OPERATION	<u>12/1/74</u>	

- (1) REACTOR AVAILABILITY FACTOR =  $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (2) UNIT AVAILABILITY FACTOR =  $\frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (3) UNIT CAPACITY FACTOR =  $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{MAX. DEPENDABLE CAPACITY (MW}_e\text{-NET)} \times \text{HOURS IN REPORTING PERIOD}}$
- (4) UNIT FORCED OUTAGE RATE =  $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$