

NRC Resolution of Facility Comment

Facility Comment:

Scenario SEG-6213E rev 001 event 3 is a bus D11 lockout. The correct Technical Specification call for this event is 3.03.

NRC Resolution:

Facility comment accepted. Review of facility electrical Technical Specification surveillance requirements shows a requirement that offsite power sources be able to power onsite busses to be considered operable. With a fault on the bus, no source can power the bus, all are considered inoperable, hence T.S. 3.0.3 is the correct call rather than 3.8.1.1 & 3.8.2.1 as listed in the scenario guide

Mr. Joe D'Antonio

Joe this letter is to confirm that during the administration of the operating test for Limerick generating station between 1/19/2016 and 1/21/2016 SEG-6213E rev001 contained an error for the Tech. Spec. decision for event 3 D11 bus lockout. After review between Operations management, training management and the lead exam author it was agreed that Tech. Spec. 3.03 is the appropriate determination for this condition. AR 2543804-26 has been generated to ensure that SEG-6213E rev001 is revised to correct this error prior to future use.

Robert Forst