

---

## RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

### APR1400 Design Certification

Korea Electric Power Corporation / Korea Hydro & Nuclear Power Co., LTD

Docket No. 52-046

RAI No.: 297-8309  
SRP Section: 19.03 –Beyond Design Basis External Event  
Application Section: 19.03  
Date of RAI Issue: 11/09/2015

---

### **Question No. 19.03-6**

The NRC staff requests that the APR1400 design certification applicant establish a Combined License (COL) item for a COL applicant to propose a License Condition to verify the development and implementation of the guidance, strategies, and programs for the mitigation strategies for ensuring core cooling, containment function, and spent fuel pool cooling capabilities during an extended loss of ac power event at APR1400 nuclear power plant. The staff requests that the APR1400 design certification applicant provide a model license condition in the APR1400 DCD with key elements for the implementation of mitigation strategies for extended loss of ac power events, such as found in other design certification and COL applications with the applicable NRC safety evaluations.

### **Response**

A COL 19.3(10) item will be added in DCD for a COL applicant to propose a License Condition to verify the development and implementation of the guidance, strategies, and programs for the mitigation strategies for ensuring core cooling, containment function, and spent fuel pool cooling capabilities during an extended loss of ac power event at an APR1400 nuclear power plant.

---

#### **Impact on DCD**

DCD Tier 2, Section 19.3.2.3 and Table 1.8-2 will be revised as indicated in the Attachment.

#### **Impact on PRA**

There is no impact on the PRA.

#### **Impact on Technical Specifications**

There is no impact on the Technical Specifications.

**Impact on Technical/Topical/Environmental Reports**

There is no impact on any Technical, Topical, or Environmental Report.

**APR1400 DCD TIER 2**

COL applicant is to address details of the storage location for FLEX equipment (COL 19.3(4)).

Also, the COL applicant is to address site-specific strategies to mitigate BDBEEs as specified in NRC Order EA-12-049 (COL 19.3(5)), including but not limited to the following:

- a. Evaluation of site-specific external hazards
- b. Determination and protection of portable equipment
- c. Providing means for acquisition, staging, and installation of equipment
- d. Establishing means for maintaining and testing of portable equipment
- e. Establishing procedures and guidance on mitigation of BDBEEs
- f. Establishing training of personnel to the developed strategies and procedures

Insert A



19.3.2.4 Recommendation 7.1 – Reliable Spent Fuel Pool Instrumentation

The APR1400 employs reliable indication of the water level in the SFP capable of supporting identification of the following pool water level conditions:

- a. Level that is adequate to support operation of the normal fuel pool cooling system
- b. Level that is adequate to provide substantial radiation shielding for a person standing on the spent fuel pool operating deck
- c. Level at which fuel remains covered and actions to implement makeup water addition should no longer be deferred

The APR1400 SFP water level instrumentation is consistent with the guidelines addressed in NRC EA-12-051, NEI 12-02 (Reference 8), and JLD-ISG-2012-03 (Reference 9).

The primary instrument channel provides level indication through the use of guided wave radar (GWR) technology using the principle of time domain reflectometry (TDR).

**Insert A**

The COL applicant is to propose a License Condition to verify the development and implementation of the guidance, strategies, and programs for the mitigation strategies for ensuring core cooling, containment function, and spent fuel pool cooling capabilities during and extended loss of ac power event at an APR1400 nuclear power plant (COL 19.3(10)), including the following conditions:


At least one (1) year before the latest date set forth in the schedule for completing the inspections, tests, and analyses in the ITAAC submitted in accordance with 10 CFR §52.99(a), the licensee shall use the guidance contained in JLD-ISG-2012-01, “Compliance with Order EA-12-049, Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events,” Revision 0 and the information presented in DCD Section 19.3.2.3 to complete the development of strategies and guidance of maintaining and, if necessary, restoring core cooling, containment, and spent fuel pool cooling capabilities beginning 72 hours after loss of all normal and emergency ac power sources, including any alternate ac source under 10 CFR 50.63. These strategies must be capable of:

- Mitigating a simultaneous loss of all ac power sources, both from the onsite and offsite power systems, and loss of normal access to the normal heat sink,
- Maintaining core cooling, containment, and spent fuel pool cooling capabilities for the APR1400 during and after such an event affecting on the plant, and
- Being implemented in all plant modes.

**APR1400 DCD TIER 2**

Table 1.8-2 (29 of 29)

Item No.	Description
COL 19.3(1)	The COL applicant is to perform site-specific seismic hazard evaluation and seismic risk evaluation as applicable in accordance with NTTF Recommendation 2.1 as outlined in the NRC RFI.
COL 19.3(2)	The COL applicant is to address the flood requirements for wet sites
COL 19.3(3)	The COL applicant is to develop the details for offsite resources.
COL 19.3(4)	The COL applicant is to address the details of storage location for FLEX equipment.
COL 19.3(5)	The COL applicant is to address site-specific strategies to mitigate BDBEES as specified in the NRC Order EA-12-049.
COL 19.3(6)	The COL applicant is to address SFP level instrumentation maintenance procedure development and perform training as specified in NRC Order EA-12
COL 19.3(7)	The COL applicant is to address development of EOPs, SAMGs, and EDMGs that incorporate lessons learned from TEPCO's Fukushima Dai-Ichi nuclear power plant accident as addressed in SECY-12-0025.
COL 19.3(8)	The COL applicant is to address enhancement of the offsite communication system as specified in the NRC Request for Information pertaining to NTTF Recommendation 9.3.
COL 19.3(9)	The COL applicant is to address staffing for large-scale natural events as specified in the NRC RFI pertaining to NTTF Recommendation 9.3.



COL 19.3(10) The COL applicant is to propose a License Condition to verify the development and implementation of the guidance, strategies, and programs for the mitigation strategies for ensuring core cooling, containment function, and spent fuel pool cooling capabilities during and extended loss of ac power event at an APR1400 nuclear power plant.