



509 Main St. • Jackson, S.C. 29831 • (803) 471-9207

TK #6

JK NO.039402

42

|           |          |          |          |            |           |         |         |
|-----------|----------|----------|----------|------------|-----------|---------|---------|
| Truck     | Driver   | User     | Disp     | Ticket Num | Ticket ID | Time    | Date    |
| 0825      | 003036   | dsellers | 37724811 | 0          |           | 13:47   | 8/28/13 |
| Load Size | Mix Code | Returned | Qty      | Mix Age    | Seq       | Load ID |         |
| 8.00 CYDS | 20JNF033 |          |          |            | W1        | 43      |         |

| Material | Description     | Design Qty | Required  | Batched   | % Var   | % Moisture | Actual    | Wat |
|----------|-----------------|------------|-----------|-----------|---------|------------|-----------|-----|
| CEMENT1  | TYPE III CEMENT | 125.0 lb   | 1000.0 lb | 995.0 lb  | -0.50%  |            |           |     |
| FFLYASH  | CLASS F ASH     | 363 lb     | 2904 lb   | 2905 lb   | 0.03%   |            |           |     |
| SAND1    | NATURAL SAND    | 1790 lb    | 14940 lb  | 14920 lb  | -0.14%  | 3.63% A    | 62 gl     |     |
| STONE    | STONE           | 800 lb     | 6495 lb   | 6480 lb   | -0.24%  | 1.49% M    | 11 gl     |     |
| WATER1   | CITY WATER      | 48.50 gl   | .00 gl    | .00 gl    |         |            |           |     |
| SLAG     | SLAG            | 210.0 lb   | 1680.0 lb | 1670.0 lb | -0.60%  |            |           |     |
| STRACCEL | ADVA 575        | 40.00 oz   | 320.00 oz | 320.00 oz | 0.00%   |            |           |     |
| STABILIZ | RECOVER         | 7.00 oz    | 56.00 oz  | 50.00 oz  | -10.71% |            |           |     |
| WATER3   | WATER           | 100.00 %   | 302.24 gl | 302.00 gl | -0.08%  |            | 302.00 gl |     |

|        |              |                 |        |               |               |           |          |
|--------|--------------|-----------------|--------|---------------|---------------|-----------|----------|
| Actual | Num Batches: | 1               |        |               |               | Manual    | 13:47:21 |
| Load   | 29413 lb     | Design W/C:     | 0.580  | Water/Cement: | 0.581 T       | Design    | 398.0 gl |
| Slump: | 4.00 in      | Water in Truck: | 0.0 gl | Adjust Water: | 0.0 gl / Load | Actual    | 375.6 gl |
|        |              |                 |        |               | Trim Water:   | -1.5 gl / | To Add   |
|        |              |                 |        |               |               | CYC       | 124 gl   |

MIXER B: 1 Mixed 0 of 60 Sec.

REVS IN 68

REVS START 103

REVS OUT 114

TIME START 2:19

TIME STOP

TOTAL TIME

W. E. Sellers 8-28-13

EXP 958 330 oz

Rejected Alicia Smith 8/28/13



509 Main St. • Jackson, S.C. 29831 • (803) 471-9207

TK#6  
43

INFO ONLY 28<sup>th</sup>

JK NO. 039403

|           |          |          |                 |           |       |         |
|-----------|----------|----------|-----------------|-----------|-------|---------|
| Truck     | Driver   | User     | Disp Ticket Num | Ticket ID | Time  | Date    |
| 7116      | 067956   | dsellers | 37724812        | 0         | 14:00 | 8/28/13 |
| Load Size | Mix Code | Returned | Qty             | Mix Age   | Seq   | Load ID |
| 8.00 CYDS | 20JNF033 |          |                 |           | W1    | 44      |

| Material | Description     | Design Qty | Required  | Batched        | % Var   | Moisture | Actual    | Wet |
|----------|-----------------|------------|-----------|----------------|---------|----------|-----------|-----|
| CEMENT1  | TYPE III CEMENT | 125.0 lb   | 1000.0 lb | 1000 4895.8 lb | -9.96%  |          |           |     |
| FFLYASH  | CLASS F ASH     | 363 lb     | 2904 lb   | 2905 lb        | 0.03%   |          |           |     |
| SAND1    | NATURAL SAND    | 1790 lb    | 14862 lb  | 14780 lb       | -0.55%  | 3.79% A  | 69 gl     |     |
| STONE    | STONE           | 600 lb     | 6499 lb   | 6480 lb        | -0.24%  | 1.49% M  | 11 gl     |     |
| WATER1   | CITY WATER      | 48.60 gl   | .00 gl    | .00 gl         |         |          |           |     |
| SLAG     | SLAG            | 210.0 lb   | 1680.0 lb | 1675.0 lb      | -0.30%  |          |           |     |
| STRACCEL | ADVA 575        | 40.00 oz   | 320.00 oz | 320.00 oz      | 0.00%   |          |           |     |
| STABILIZ | RECOVER         | 7.00 oz    | 66.00 oz  | 60.00 oz       | -10.71% |          |           |     |
| WATER2   | WATER           | 100.00 %   | 288.60 gl | 200.00 gl      | 0.13%   |          | 200.00 gl |     |

|        |         |                 |             |               |               |             |           |          |        |          |         |         |
|--------|---------|-----------------|-------------|---------------|---------------|-------------|-----------|----------|--------|----------|---------|---------|
| Actual | Load    | 29402 lb        | Design W/C: | 0.580         | Water/Cement: | 0.577 T     | Design    | 388.0 gl | Actual | 376.0 gl | To Add: | 12.0 gl |
| Slump: | 4.00 in | Water in Truck: | 0.0 gl      | Adjust Water: | 0.0 gl / Load | Trim Water: | -1.5 gl / | CYC      |        |          |         |         |

B: 1 Mixed 0 of 60 Sec.

|            |        |
|------------|--------|
| REVS IN    | 71     |
| REVS START | 292    |
| REVS OUT   | 322    |
| TIME START | 3:13   |
| TIME STOP  | 3:22   |
| TOTAL TIME | 82 min |

OK Sell 8-28-13  
EXP 958 330..

Alicia Smith 8/28/13



509 Main St. • Jackson, S.C. 29831 • (803) 471-9207

\*TEST

INFO: 30.5" @ 78 DEG.  
TEST: 30" @ 78 DEG.  
QMA 6-4-15

#1

TK.16

JK NO. 030918

0-Revs

|                        |                      |                  |                         |          |           |              |                |
|------------------------|----------------------|------------------|-------------------------|----------|-----------|--------------|----------------|
| Truck<br>0812          | Driver<br>003051     | User<br>dsellers | Disp Ticket<br>37729208 | Num<br>0 | Ticket ID | Time<br>6:48 | Date<br>6/4/15 |
| Load Size<br>8.00 CYDS | Mix Code<br>20JNF033 | Returned         | Qty                     | Mix Age  | Seq<br>W1 | Load ID<br>1 |                |

| Material | Description     | Design Qty | Required   | Batched    | % Var  | % Moisture | Actual     | Wat |
|----------|-----------------|------------|------------|------------|--------|------------|------------|-----|
| CEMENT   | TYPE III CEMENT | 125.0 lb   | 1000.0 lb  | 995.0 lb   | -0.50% |            |            |     |
| FLYASH   | CLASS F ASH     | 363 lb     | 2904 lb    | 2905 lb    | 0.03%  |            |            |     |
| SLAG     | SLAG            | 210.0 lb   | 1680.0 lb  | 1675.0 lb  | -0.30% |            |            |     |
| STONE    | STONE           | 800 lb     | 6574 lb    | 6580 lb    | 0.09%  | 2.72% M    | 21 g       |     |
| SAND     | NATURAL SAND    | 1730 lb    | 19014 lb   | 14900 lb   | -0.76% | 4.85% A    | 83 g       |     |
| WATER    | CITY WATER      | 48.50 gal  | .00 gal    | .00 gal    |        |            |            |     |
| STABILIZ | RECOVER         | 3.49 oz    | 27.92 oz   | 30.00 oz   | 7.45%  |            |            |     |
| STRACCEL | ADVA 575        | 40.97 oz   | 327.76 oz  | 330.00 oz  | 0.69%  |            |            |     |
| WH       | HOT WATER       | 100.00 %   | 276.96 gal | 276.00 gal | 0.02%  |            | 276.00 gal |     |

|             |          |                |         |              |         |                |            |            |           |        |         |
|-------------|----------|----------------|---------|--------------|---------|----------------|------------|------------|-----------|--------|---------|
| Actual Load | 29381 lb | Design W/C     | 0.580   | Water/Cement | 0.568 A | Design         | 388.0 gal  | Actual     | 379.4 gal | Manual | 6:48:27 |
| Slump       | 4.00 in  | Water in Truck | 0.0 gal | Adjust Water |         | 0.0 gal / Load | Trim Water | -1.0 gal / | CYC       | To Add | 8.6 gal |

B: 1 Mixed 0 of 60 Sec.

|            |         |
|------------|---------|
| REVS IN    | 75      |
| REVS START | 114     |
| REVS OUT   | 125     |
| TIME START | 7:50    |
| TIME STOP  | 7:55    |
| TOTAL TIME | 67 MIN. |

6-4-15

EXP 958 330oz



ARGOS

509 Main St. • Jackson, S.C. 29831 • (803) 471-9207

PLANT  
Info:

Spread - 32"

#1  
TK 16

✓ SRR PLB

QC 6-25-15

INFO: 30.5" @ 78°

INFO #2: 29.25" @ 79° JK NO. 041638

TEST: 28.5" @ 79°

O-Reus

| Truck    | Driver          | User       | Disp Ticket | Num       | Ticket ID | Time       | Date      |
|----------|-----------------|------------|-------------|-----------|-----------|------------|-----------|
| 1513     | 003041          | dsellers   | 37729629    | 0         |           | 7:22       | 6/25/15   |
| Load     | Size            | Mix Code   | Returned    | Qty       | Mix Age   | Seq        | Load ID   |
| 8.00     | CYDS            | 20JNF033   |             |           |           | W1         | 4         |
| Material | Description     | Design Qty | Required    | Batched   | % Var     | % Moisture | Actual    |
| CEMENT   | TYPE III CEMENT | 125.0 lb   | 1000.0 lb   | 1005.0 lb | 0.50%     |            |           |
| FFLYASH  | CLASS F ASH     | 363 lb     | 2904 lb     | 2910 lb   | 0.21%     |            |           |
| SLAG     | SLAG            | 210.0 lb   | 1680.0 lb   | 1670.0 lb | -0.60%    |            |           |
| STONE    | STONE           | 600 lb     | 6512 lb     | 6540 lb   | 0.43%     | 1.79% M    | 13 gl     |
| SAND     | NATURAL SAND    | 1790 lb    | 14901 lb    | 14880 lb  | -0.14%    | 4.05% A    | 69 gl     |
| WATER    | CITY WATER      | 48.60 gl   | .00 gl      | .00 gl    |           |            |           |
| STABILIZ | RECOVER         | 3.49 oz    | 60.87 oz    | 60.00 oz  | -1.42%    |            |           |
| STRACCEL | ADVA 575        | 40.97 oz   | 327.76 oz   | 330.00 oz | 0.68%     |            |           |
| WC       | CHILLED WATER   | 100.00 %   | 297.00 gl   | 297.00 gl | 0.00%     |            | 297.00 gl |

| Actual   | Load    | Blump: | Design W/C:     | Water/Cement: | Design        | Actual      | Manual  |
|----------|---------|--------|-----------------|---------------|---------------|-------------|---------|
| 29508 lb | 4.00 in |        | 0.580           | 0.568 A       | 388.0 gl      | 380.0 gl    | 7:22:52 |
|          |         |        | Water in Truck: | Adjust Water: | 0.0 gl / Load | Trim Water: | To Add: |
|          |         |        | 0.0 gl          |               |               | -1.0 gl /   | 8.0 gl  |
|          |         |        |                 |               |               | CYC         |         |

B: 1 Mixed 0 of 60 Sec.

|            |        |
|------------|--------|
| REVS IN    | 81     |
| REVS START | 151    |
| REVS OUT   | 179    |
| TIME START | 8:27   |
| TIME STOP  | 8:33   |
| TOTAL TIME | 71 MIN |

W/S 6-25-15  
EXP 958 330oz



509 Main St. • Jackson, S.C. 29831 • (803) 471-9207

INFO: 27.5" @ 80°  
TEST: 28" @ 80° #1  
TK16

JK NO. 041934

O-Revs

|                        |                      |                  |                         |          |           |              |                |
|------------------------|----------------------|------------------|-------------------------|----------|-----------|--------------|----------------|
| Truck<br>0812          | Driver<br>003051     | User<br>dsellers | Disp Ticket<br>37729926 | Num<br>0 | Ticket ID | Time<br>7:03 | Date<br>7/9/15 |
| Load Size<br>8.00 CYDS | Mix Code<br>20JNF033 | Returned         | Qty                     | Mix Age  | Seq<br>W1 | Load ID<br>1 |                |

| Material | Description     | Design Qty | Required  | Batched   | % Var  | % Moisture | Actual    | Wet |
|----------|-----------------|------------|-----------|-----------|--------|------------|-----------|-----|
| CEMENT1  | TYPE III CEMENT | 125.0 lb   | 1000.0 lb | 990.0 lb  | -1.02% |            |           |     |
| FFLYASH  | CLASS F ASH     | 363 lb     | 2904 lb   | 2900 lb   | -0.14% |            |           |     |
| SLAG     | SLAG            | 210.0 lb   | 1680.0 lb | 1670.0 lb | -0.60% |            |           |     |
| 8STONE   | 8 STONE         | 800 lb     | 6507 lb   | 6600 lb   | 1.43%  | 1.67% M    | 13 gl     |     |
| SAND1    | NATURAL SAND    | 1790 lb    | 14695 lb  | 14760 lb  | 0.78%  | 4.02% A    | 68 gl     |     |
| WATER1   | CITY WATER      | 49.50 gl   | .00 gl    | .00 gl    |        |            |           |     |
| STABILIZ | RECOVER         | 3.49 oz    | 27.92 oz  | 30.00 oz  | 7.45%  |            |           |     |
| BTRACCEL | ADVA 575        | 40.97 oz   | 327.76 oz | 330.00 oz | 0.68%  |            |           |     |
| WC       | CHILLED WATER   | 100.00 %   | 298.17 gl | 298.00 gl | -0.06% |            | 298.00 gl |     |

|                |                        |                             |                       |                 |                |  |                                |
|----------------|------------------------|-----------------------------|-----------------------|-----------------|----------------|--|--------------------------------|
| Actual         | Num Batches: 1         |                             |                       |                 |                |  | Manual 7:05:26                 |
| Load 29449 lb  | Design W/C: 0.580      | Water/Cement: 0.570 A       | Design 388.0 gl       | Actual 379.5 gl | To Add: 8.5 gl |  |                                |
| Blump: 4.00 in | Water in Truck: 0.0 gl | Adjust Water: 0.0 gl / Load | Trim Water: -1.0 gl / |                 |                |  | CYC Note: Manual feed occurred |

MIXER

B: 1 Mixed 0 of 60 Sec.

|            |        |
|------------|--------|
| Revs in    | 97     |
| Revs START | 125    |
| Revs out   | 150    |
| Time START | 8:06   |
| Time STOP  | 8:10   |
| Total time | 67 MIN |

dsellers 7-9-15  
EXP 958 33002



ARGOS

509 Main St. • Jackson, S.C. 29831 • (803) 471-9207

INFO

Test: 31.5" @ 85°

#1  
TK16

JK NO. 042239

O-Ress

|           |          |          |                 |           |      |         |
|-----------|----------|----------|-----------------|-----------|------|---------|
| Truck     | Driver   | User     | Disp Ticket Num | Ticket ID | Time | Date    |
| 0812      | 10002211 | dsellers | 37730258        | 0         | 7:02 | 8/31/15 |
| Load Size | Mix Code | Returned | Qty             | Mix Age   | Seq  | Load ID |
| 7.00 CYDS | 00GNV208 |          |                 |           | W1   | 1       |

8-31-15

| Material | Description     | Design Qty | Required   | Batched    | % Variance | Moisture | Actual     | Wet |
|----------|-----------------|------------|------------|------------|------------|----------|------------|-----|
| CEMENT1  | TYPE III CEMENT | 174.0 lb   | 1218.0 lb  | 1220.0 lb  | 0.15%      |          |            |     |
| FFLYASH  | CLASS F ASH     | 868 lb     | 6076 lb    | 6085 lb    | 0.15%      |          |            |     |
| SLAG     | SLAG            | 868.0 lb   | 6076.0 lb  | 6080.0 lb  | 0.07%      |          |            |     |
| WATER1   | CITY WATER      | 114.50 gal | 794.50 gal | 795.00 gal | 0.06%      |          | 795.00 gal |     |
| TEMPER   | TEMPER          | .00        | 2.00 gal   | 2.00 gal   | 0.00%      |          | 2.00 gal   |     |

|                    |          |                 |         |               |         |                |             |            |           |        |         |
|--------------------|----------|-----------------|---------|---------------|---------|----------------|-------------|------------|-----------|--------|---------|
| Actual Load Blump: | 20066 lb | Design W/C:     | 0.500   | Water/Cement: | 0.496 A | Design         | 801.5 gal   | Actual     | 797.0 gal | To Add | 4.5 gal |
|                    | 4.00 in  | Water in Truck: | 0.0 gal | Adjust Water: |         | 0.0 gal / Load | Trim Water: | -1.0 gal / | CYC       |        |         |

MIXER B: 1 Mixed 0 of 60 Sec.  
B: 2 Mixed 0 of 60 Sec.

8-31-15

|            |        |
|------------|--------|
| Revs in    | 102    |
| Revs START | 178    |
| Revs OUT   | 192    |
| Time start | 8:30   |
| Time stop  | 8:36   |
| Total Time | 94 MIN |



ARGOS

509 Main St. • Jackson, S.C. 29831 • (803) 471-9207

INFO: 36" @ 86°F  
TEST: 36" FLOW @ 86°F

#1  
TK 16

JK NO. 042345

0-Revs

|           |          |          |                 |           |      |         |
|-----------|----------|----------|-----------------|-----------|------|---------|
| Truck     | Driver   | User     | Disp Ticket Num | Ticket ID | Time | Date    |
| 1513      | 10002041 | dsellers | 37730364        | 0         | 7:29 | 9/10/15 |
| Load Size | Mix Code | Returned | Qty             | Mix Age   | Seq  | Load ID |
| 7.00 CYDS | 00GNV208 |          |                 |           | W1   | 1       |

| Material | Description     | Design Qty | Required   | Batched    | % Var  | % Moisture | Actual     | Wat |
|----------|-----------------|------------|------------|------------|--------|------------|------------|-----|
| CEMENT1  | TYPE III CEMENT | 174.0 lb   | 1218.0 lb  | 1210.0 lb  | -0.66% |            |            |     |
| FFLYASH  | CLASS F ASH     | 868 lb     | 6076 lb    | 6070 lb    | -0.10% |            |            |     |
| SLAG     | SLAG            | 868.0 lb   | 6076.0 lb  | 6070.0 lb  | -0.10% |            |            |     |
| WATER1   | CITY WATER      | 114.50 gal | 794.50 gal | 794.00 gal | -0.06% |            | 794.00 gal |     |

|        |         |                 |             |               |                |             |            |        |           |         |           |        |         |
|--------|---------|-----------------|-------------|---------------|----------------|-------------|------------|--------|-----------|---------|-----------|--------|---------|
| Actual | Load    | 19976 lb        | Design W/C: | 0.500         | Water/Cement:  | 0.496       | A          | Design | 801.5 gal | Actual  | 794.0 gal | Manual | 7:29:28 |
| Skump: | 4.00 in | Water in Truck: | 0.0 gal     | Adjust Water: | 0.0 gal / Load | Trim Water: | -1.0 gal / | CYC    | To Add:   | 7.5 gal |           |        |         |

B: 1 Mixed 0 of 60 Sec.  
B: 2 Mixed 0 of 60 Sec.  
B: 3 Mixed 0 of 60 Sec.

*filed 9-10-15*

|            |                |
|------------|----------------|
| Revs in    | 75             |
| Revs start | 90             |
| Revs out   | 135            |
| Time start | 8:27           |
| Time stop  | 9:12           |
| Total Time | 43 103 MINUTES |

GPR  
9/10/2015



ARGOS

509 Main St. • Jackson, S.C. 29831 • (803) 471-9207

#15  
Tank 16

INFO 25" @ 88°  
Test QMA 6-15-15  
2ND INFO AFTER WATER ADDS:  
24" QMA 6-15-15

JK NO. 031089

0-Revs

|                   |                           |                  |                         |          |           |               |                 |
|-------------------|---------------------------|------------------|-------------------------|----------|-----------|---------------|-----------------|
| Truck<br>0798     | Driver<br>100161          | User<br>dsellers | Disp Ticket<br>37729378 | Num<br>0 | Ticket ID | Time<br>9:37  | Date<br>6/15/15 |
| Load Size<br>8.00 | Mix Code<br>CYDS 20JNF033 | Returned         | Qty                     | Mix Age  | Seq<br>W1 | Load ID<br>16 |                 |

| Material | Description     | Design Qty | Required  | Batched   | % Var  | % Moisture | Actual    | Wat |
|----------|-----------------|------------|-----------|-----------|--------|------------|-----------|-----|
| CEMENT1  | TYPE III CEMENT | 125.0 lb   | 1000.0 lb | 990.0 lb  | -1.00% |            |           |     |
| FLYASH   | CLASS F ASH     | 963 lb     | 2904 lb   | 2900 lb   | -0.14% |            |           |     |
| SLAG     | SLAG            | 210.0 lb   | 1680.0 lb | 1670.0 lb | -0.60% |            |           |     |
| STONE    | STONE           | 800 lb     | 6466 lb   | 6520 lb   | 0.84%  | 1.03% M    | 8 gl      |     |
| SAND1    | NATURAL SAND    | 1790 lb    | 14829 lb  | 14800 lb  | -0.20% | 3.96% A    | 61 gl     |     |
| WATER1   | CITY WATER      | 48.60 gl   | .00 gl    | .00 gl    |        |            |           |     |
| STABILIZ | RECOVER         | 3.49 oz    | 27.92 oz  | 30.00 oz  | 7.45%  |            |           |     |
| STRACCEL | ADVA 575        | 48.97 oz   | 327.76 oz | 330.00 oz | 0.68%  |            |           |     |
| WH       | HOT WATER       | 100.00 %   | 311.10 gl | 312.00 gl | 0.29%  |            | 312.00 gl |     |

|        |          |                 |        |               |               |             |           |        |          |        |         |
|--------|----------|-----------------|--------|---------------|---------------|-------------|-----------|--------|----------|--------|---------|
| Actual | 29506 lb | Design W/C:     | 0.580  | Water/Cement: | 0.572 A       | Design      | 388.0 gl  | Actual | 380.9 gl | Manual | 9:37:53 |
| Slump: | 4.00 in  | Water in Truck: | 0.0 gl | Adjust Water: | 0.0 gl / Load | Trim Water: | -1.0 gl / | CYC    | To Add:  | 7.2 gl |         |

MIXER B: 1 Mixed 0 of 60 Sec.

Pavs IN 89  
 Pavs START             
 Pavs STOP             
 Time START             
 Time STOP             
 Total Time           

✓ 25" 6-15-15

Exp 958 330.2

Rejected Added 7.2  
Gallons  
by 6-15-15





509 Main St. • Jackson, S.C. 29831 • (803) 471-9207

# 19  
TK 16

JK NO. 031170

O-Revs

|                        |                      |                  |                         |          |                |               |                 |
|------------------------|----------------------|------------------|-------------------------|----------|----------------|---------------|-----------------|
| Truck<br>0819          | Driver<br>003031     | User<br>dsellers | Disp Ticket<br>37729467 | Num<br>0 | Ticket ID<br>0 | Time<br>14:25 | Date<br>6/17/15 |
| Load Size<br>8.00 CYDS | Mix Code<br>20JNF033 | Returned         | Qty<br>6-17-15          | Mix Age  | Seq<br>W1      | Load ID<br>29 |                 |

| Material | Description     | Design Qty | Required  | Batched   | % Var  | % Moisture | Actual    | Wet |
|----------|-----------------|------------|-----------|-----------|--------|------------|-----------|-----|
| CEMENT1  | TYPE III CEMENT | 125.0 lb   | 1000.0 lb | 1000.0 lb | -2.50% |            |           |     |
| FFLYASH  | CLASS F ASH     | 363 lb     | 2904 lb   | 2915 lb   | 0.38%  |            |           |     |
| SLAG     | SLAG            | 210.0 lb   | 1680.0 lb | 1680.0 lb | 0.00%  |            |           |     |
| STONE    | STONE           | 800 lb     | 6451 lb   | 6460 lb   | 0.15%  | 0.79% M    | 6 gl      |     |
| SAND1    | NATURAL SAND    | 1790 lb    | 14751 lb  | 14720 lb  | -0.21% | 3.01% A    | 52 gl     |     |
| WATER1   | CITY WATER      | 48.50 gl   | .00 gl    | .00 gl    |        |            |           |     |
| STABILIZ | RECOVER         | 3.49 oz    | 60.87 oz  | 60.00 oz  | -1.42% |            |           |     |
| STRACCEL | ADVA 575        | 40.97 oz   | 327.76 oz | 330.00 oz | 0.68%  |            |           |     |
| WC       | CHILLED WATER   | 100.00 %   | 322.30 gl | 322.00 gl | -0.09% |            | 322.00 gl |     |

|             |          |                |        |              |         |               |            |           |          |        |          |        |        |
|-------------|----------|----------------|--------|--------------|---------|---------------|------------|-----------|----------|--------|----------|--------|--------|
| Actual Load | 29521 lb | Design W/C     | 0.580  | Water/Cement | 0.563 A | Design        | 388.0 gl   | Actual    | 379.6 gl | Manual | 14:25:31 | To Add | 8.4 gl |
| Slump       | 4.00 in  | Water In Truck | 0.0 gl | Adjust Water |         | 0.0 gl / Load | Trim Water | -1.0 gl / | CYC      |        |          |        |        |

B: 1 Mixed 0 of 60 Sec.

REVS IN 106

---

REVS START

---

REVS OUT

---

TIME START

---

TIME STOP

---

TOTAL TIME

---

REJECTED  
NOT MIXED  
GAR 6/17/15

6-17-15  
EXP 958 330 oz



509 Main St. • Jackson, S.C. 29831 • (803) 471-9207

INFO 36"  
TEST 33" @ 80° #14  
TK 16

JK NO. 041739

Truck rejected due to excessive Reus flow and segregation. *Paul R. Redwood 6/30/15*

|                   |                           |                  |                         |          |                |               |                 |
|-------------------|---------------------------|------------------|-------------------------|----------|----------------|---------------|-----------------|
| Truck<br>1412     | Driver<br>100011          | User<br>dsellers | Disp Ticket<br>37729729 | Num<br>0 | Ticket ID<br>0 | Time<br>9:19  | Date<br>6/30/15 |
| Load Size<br>8.00 | Mix Code<br>CYDS 20JNF033 | Returned         | Qty                     | Mix Age  | Seq<br>W1      | Load ID<br>19 |                 |

| Material | Description     | Design Qty | Required  | Batched   | % Var  | % Moisture | Actual    | Wgt |
|----------|-----------------|------------|-----------|-----------|--------|------------|-----------|-----|
| CEMENT   | TYPE III CEMENT | 125.0 lb   | 1000.0 lb | 990.0 lb  | -1.00% |            |           |     |
| FLYASH   | CLASS F ASH     | 363 lb     | 2804 lb   | 2900 lb   | -0.14% |            |           |     |
| SLAG     | SLAG            | 210.0 lb   | 1680.0 lb | 1670.0 lb | -0.60% |            |           |     |
| STONE    | STONE           | 800 lb     | 6499 lb   | 6460 lb   | -0.59% | 1.54% M    | 12 gl     |     |
| SAND     | NATURAL SAND    | 1790 lb    | 14962 lb  | 14920 lb  | -0.28% | 4.48% A    | 77 gl     |     |
| WATER    | CITY WATER      | 48.50 gl   | .00 gl    | .00 gl    |        |            |           |     |
| STABILIZ | RECOVER         | 3.49 oz    | 60.87 oz  | 60.00 oz  | -1.42% |            |           |     |
| STRACCEL | ADVA 575        | 40.97 oz   | 327.76 oz | 330.00 oz | 0.68%  |            |           |     |
| W/C      | CHILLED WATER   | 100.00 %   | 291.30 gl | 290.00 gl | -0.45% |            | 290.00 gl |     |

|             |          |                |        |              |         |               |            |           |          |        |         |
|-------------|----------|----------------|--------|--------------|---------|---------------|------------|-----------|----------|--------|---------|
| Actual Load | 29384 lb | Design W/C     | 0.980  | Water/Cement | 0.969 A | Design        | 398.0 gl   | Actual    | 378.4 gl | Manual | 9:19:34 |
| Slump       | 4.00 in  | Water in Truck | 0.0 gl | Adjust Water |         | 0.0 gl / Load | Trim Water | -1.0 gl / | CYC      | To Add | 9.6 gl  |

B: 1 Mixed 0 of 60 Sec.

Reus in 86

Reus start                     

Reus out                     

Time start                     

Time stop                     

Total Time                     

*W. L. L. 6-30-15*  
EXP 958 330 oz



ARGOS

509 Main St. • Jackson, S.C. 29831 • (803) 471-9207

INFO: 23 1/2" @ 80°F #1  
TEST: 24" @ 41°F TK 16

JK NO. 041980

O-Lows  
Ct

|                   |                           |                  |                         |          |                |              |                 |
|-------------------|---------------------------|------------------|-------------------------|----------|----------------|--------------|-----------------|
| Truck<br>0772     | Driver<br>200097          | User<br>dsellers | Disp Ticket<br>37729973 | Num<br>0 | Ticket ID<br>0 | Time<br>8:49 | Date<br>7/13/15 |
| Load Size<br>8.00 | Mix Code<br>CYDS 20JNF033 | Returned         | Qty                     | Mix Age  | Seq<br>W1      | Load ID<br>5 |                 |

| Material | Description     | Design Qty | Required  | Batched   | % Var  | % Moisture | Actual    | Wat |
|----------|-----------------|------------|-----------|-----------|--------|------------|-----------|-----|
| CEMENT1  | TYPE III CEMENT | 125.0 lb   | 1300.0 lb | 990.0 lb  | -1.00% |            |           |     |
| FFLYASH  | CLASS F ASH     | 363 lb     | 2904 lb   | 2890 lb   | -0.48% |            |           |     |
| SLAG     | SLAG            | 210.0 lb   | 1690.0 lb | 1680.0 lb | -0.60% |            |           |     |
| STONE    | 8 STONE         | 600 lb     | 6433 lb   | 6460 lb   | -0.51% | 1.45% M    | 11 gl     |     |
| SAND1    | NATURAL SAND    | 1730 lb    | 14805 lb  | 14740 lb  | -0.44% | 3.35% A    | 56 gl     |     |
| WATER1   | CITY WATER      | 48.50 gl   | 00 gl     | 00 gl     |        |            |           |     |
| STABILIZ | RECOVER         | 3.49 oz    | 60.87 oz  | 60.00 oz  | -1.42% |            |           |     |
| STRACCEL | ADVA 575        | 40.97 oz   | 327.76 oz | 320.00 oz | -2.37% |            |           |     |
| WC       | CHILLED WATER   | 100.00 %   | 310.69 gl | 310.00 gl | -0.22% |            | 310.00 gl |     |

|        |          |                 |        |               |        |        |             |          |                                |          |         |        |
|--------|----------|-----------------|--------|---------------|--------|--------|-------------|----------|--------------------------------|----------|---------|--------|
| Actual | 29371 lb | Design W/C:     | 0.580  | Water/Cement: | 0.569  | A      | Design      | 368.0 gl | Actual                         | 379.0 gl | To Add: | 9.0 gl |
| Slump: | 4.00 in  | Water in Truck: | 0.0 gl | Adjust Water: | 0.0 gl | / Load | Trim Water: | -1.0 gl  | CYC Note: Manual feed occurred |          |         |        |

B: 1 Mixed 0 of 60 Sec.  
Revs in 95  
Revs START  
Revs OUT  
Time START  
Time STOP  
Total Time

*[Signature]* 7-13-15  
 Exp 958 330.02

ADDED 6 GAL H<sub>2</sub>O  
 FLOW TOO LOW CPR  
 REJECTED 7/13/2015



ARGOS

509 Main St. • Jackson, S.C. 29831 • (803) 471-9207

#13  
TK16

JK NO.042287

O-Rees

Truck 0817 Driver 10002303 User operations Disp Ticket Num 37730306 Ticket ID 0 Time Date 10:56 9/1/15  
Load Size 8.00 CYDS Mix Code 20JNF033 Returned Qty Mix Age Seq W1 Load ID 19

| Material | Description     | Design Qty | Required  | Batched   | % Var  | % Moisture | Actual    | Wet |
|----------|-----------------|------------|-----------|-----------|--------|------------|-----------|-----|
| CEMENT1  | TYPE III CEMENT | 125.0 lb   | 1000.0 lb | 1005.0 lb | 0.50%  |            |           |     |
| FFLYASH  | CLASS F ASH     | 363 lb     | 2904 lb   | 2905 lb   | 0.03%  |            |           |     |
| SLAG     | SLAG            | 210.0 lb   | 1680.0 lb | 1670.0 lb | -0.60% |            |           |     |
| STONE    | STONE           | 900 lb     | 6480 lb   | 6520 lb   | 0.62%  | 1.25% M    | 10 gl     |     |
| SAND1    | NATURAL SAND    | 1750 lb    | 14825 lb  | 14760 lb  | -0.31% | 3.54% A    | 60 gl     |     |
| WATER1   | CITY WATER      | 48.50 gl   | .00 gl    | .00 gl    |        |            |           |     |
| STABILIZ | RECOVER         | 3.49 oz    | 60.87 oz  | 60.00 oz  | -1.42% |            |           |     |
| STRACCEL | ADVA 575        | 48.97 oz   | 327.76 oz | 320.00 oz | -2.37% |            |           |     |
| WC       | CHILLED WATER   | 100.00 %   | 308.74 gl | 310.00 gl | 0.03%  |            | 210.00 gl |     |

Actual Load 29491 lb Blump: 4.00 in Num Batches: 1 Design W/C: 0.580 Water/Cement: 0.569 A Design 388.0 gl Actual 380.1 gl To Add 7.9 gl  
Water In Truck: 0.0 gl Adjust Water: 0.0 gl / Load Trim Water: -1.0 gl / C/E Note: Manual feed occurred Manual 10:56:32

MIXER B: 1 Mixed 0 of 60 Sec.

|            |       |
|------------|-------|
| Revs in    | 117   |
| Revs start | N/A   |
| Revs out   | N/A   |
| Time start | 11:50 |
| Time stop  | 11:59 |
| Total Time | N/A   |

WJL 9-1-15  
EXP 958 33002

REJECT NOT MIXED PROPERLY  
ALL WATER GPR 9/1/15