



FEB 22 2016

L-2016-030
10 CFR 50.36

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555-0001


Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
2015 Annual Report of Reactor Coolant Specific Activity Limits

The 2015 Turkey Point Units 3 and 4 Annual Reactor Coolant System (RCS) Specific Activity Report is submitted herein pursuant to Turkey Point Technical Specification (TS) 6.9.1.2.

The reactor coolant specific activity limits of less than or equal to 0.25 microcuries per gram Dose Equivalent I-131 and less than or equal to 447.7 microcuries per gram of Dose Equivalent Xe-133 defined by Technical Specification 3.4.8.a and 3.4.8.b respectively were not exceeded for Turkey Point Units 3 and 4 during the year 2015.

Should there be any questions regarding this information, please contact Mr. Mitch Guth, Licensing Manager, at (305) 246-6698.

Sincerely,



Thomas Summers
Vice President
Turkey Point Nuclear Plant

SM

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

ADD
NRR