

April 22, 1992

Docket Nos. 50-498
and 50-499

Mr. Donald P. Hall
Group Vice-President, Nuclear
Houston Lighting & Power Company
P. O. Box 1700
Houston, Texas 77251

Dear Mr. Hall:

SUBJECT: SOUTH TEXAS PROJECT UNITS 1 AND 2, RELIEF FROM ASME SECTION XI CODE
REQUIREMENT (TAC NOS. M82912 AND M82913)

By letter dated April 21, 1992, we granted the subject relief request. Page 2 of the Safety Evaluation did not include reference to the correct basis for the granting of the relief. We have enclosed the corrected page for insertion into your copy. The area of change is indicated by a marginal line.

We apologize for any inconvenience that this may have caused.

Sincerely,

Original Signed By

George F. Dick, Jr., Senior Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
Page 2 of Safety
Evaluation

cc w/enclosure:
See next page

DISTRIBUTION:

| | |
|-------------|-----------------|
| Docket File | Murley/Miraglia |
| NRC/PDR | EPeyton |
| Local PDR | GDick |
| PDIV-2 RF | OGC |
| PDIV-2 PF | EJordan |
| JPartlow | GHill(8) |
| CRossi | ACRS(10) |
| JLieberman | OPA |
| BBoger | SShankman |
| MVirgilio | AHowell |
| JWiggins | |

| OFFICE | PDIV-2/La | PDIV-2/PM | PDIV-2/D | | |
|--------|-----------|-----------|----------|-----|-----|
| NAME | EPeyton | GDick:nb | SBlack | | |
| DATE | 4/22/92 | 4/22/92 | 4/22/92 | / / | / / |

280032
9205060165 920422
PDR ADDCK 05000498
P PDR

NRC FILE CENTER COPY

DF01

Mr. Donald P. Hall

- 2 -

April 22, 1992

cc w/enclosure:

Mr. J. Tapia
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 910
Bay City, Texas 77414

Mr. J. C. Lanier/M. B. Lee
City of Austin
Electric Utility Department
P. O. Box 1088
Austin, Texas 78767

Mr. K. J. Fiedler
Mr. M. T. Hardt
City Public Service Board
P. O. Box 1771
San Antonio, Texas 78296

Mr. D. E. Ward
Mr. T. M. Puckett
Central Power and Light Company
P. O. Box 2121
Corpus Christi, Texas 78403

INPO
Records Center
1100 Circle 75 Parkway
Atlanta, Georgia 30339-3064

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. Joseph M. Hendrie
50 Bellport Lane
Bellport, New York 11713

Judge, Matagorda County
Matagorda County Courthouse
1700 Seventh Street
Bay City, Texas 77414

Mr. William J. Jump
Manager, Nuclear Licensing
Houston Lighting and Power Company
P. O. Box 289
Wadsworth, Texas 77483

Jack R. Newman, Esq.
Newman & Holtzinger, P.C.
1615 L Street, N.W.
Washington, D.C. 20036

Licensing Representative
Houston Lighting and Power Company
Suite 610
Three Metro Center
Bethesda, Maryland 20814

Bureau of Radiation Control
State of Texas
1101 West 49th Street
Austin, Texas 78756

Rufus S. Scott
Associate General Counsel
Houston Lighting and Power Company
P. O. Box 61867
Houston, Texas 77208

3.0 EVALUATION

The alternate testing proposed by the licensee and routine monitoring of the ECW system during operation provide adequate assurance of system integrity while the increased availability of the ECW system provided by not performing the hydrostatic testing is desirable in terms of improving plant safety.

Based upon its review of the licensee's submittal, the staff has concluded that relief from the Code hydrostatic testing requirements for the ECW system is appropriate pursuant to 10 CFR 50.55a(a)(3)(i) due to the proposed actions providing an acceptable level of quality and safety and that the granting of such relief is authorized by law, will not endanger life or property, or the common defense and security, and is otherwise in the public interest.

Principal Contributor: W. D. Reckley

Dated: April 21, 1992