
**Advanced Passive 1000 (AP1000)
Generic Technical Specification Traveler (GTST)**

Title: Changes Related to LCO 3.4.14, Low Temperature Overpressure Protection (LTOP) System

I. Technical Specifications Task Force (TSTF) Travelers, Approved Since Revision 2 of STS NUREG-1431, and Used to Develop this GTST

TSTF Number and Title:

TSTF-359-A, Rev 9, Increase Flexibility in MODE Restraints
TSTF-425-A, Rev 3, Relocate Surveillance Frequencies to Licensee Control – RITSTF Initiative 5b
TSTF-479-A, Rev 0, Changes to Reflect Revision of 10 CFR 50.55a
TSTF-481-T, Rev 0, Correct Bases for LTOP COT

STS NUREGs Affected:

TSTF-359-A, Rev 9: NUREGs 1430, 1431, 1432, 1433, and 1434
TSTF-425-A, Rev 3: NUREGs 1430, 1431, 1432, 1433, and 1434
TSTF-479-A, Rev 0: NUREGs 1430, 1431, 1432, 1433, and 1434
TSTF-481-T, Rev 0: NUREG 1431

NRC Approval Date:

TSTF-359-A, Rev 9: 12-May-03
TSTF-425-A, Rev. 3: 06-Jul-09
TSTF-479-A, Rev 0: 06-Dec-05
TSTF-481-T, Rev 0: 10-Dec-04

TSTF Classification:

TSTF-359-A, Rev 9: Technical Change
TSTF-425-A, Rev 3: Technical Change
TSTF-479-A, Rev 0: Technical Change
TSTF-481-T, Rev 0: Bases Only Change

II. Reference Combined License (RCOL) Standard Departures (Std. Dep.), RCOL COL Items, and RCOL Plant-Specific Technical Specifications (PTS) Changes Used to Develop this GTST

RCOL Std. Dep. Number and Title:

There are no Vogtle departures applicable to Specification 3.4.14.

RCOL COL Item Number and Title:

There are no Vogtle COL items applicable to Specification 3.4.14.

RCOL PTS Change Number and Title:

VEGP LAR DOC A003: References to various Chapters and Sections of the Final Safety Analysis Report (FSAR) are revised to include FSAR.
VEGP LAR DOC A060: TS 3.4.14 Title is revised
VEGP LAR DOC A061: TS 3.4.14 is revised
VEGP LAR DOC A062: TS 3.4.14 Condition A is revised
VEGP LAR DOC M09: TS 3.4.14 Condition C is revised

III. Comments on Relations Among TSTFs, RCOL Std. Dep., RCOL COL Items, and RCOL PTS Changes

This section discusses the considered changes that are: (1) applicable to operating reactor designs, but not to the AP1000 design; (2) already incorporated in the GTS; or (3) superseded by another change.

The justification for TSTF-359 is based on vendor-specific evaluations. For Westinghouse plants, that evaluation is in MUHP-3015, "Qualitative Risk Assessment Supporting Increased Flexibility in Mode Restraints," January 2002. This report evaluated "the key plant changes that occur during the Mode changes so it is possible to identify the initiating events that can occur and systems available for event detection, actuation, and mitigation." It also considered initiating events and equipment available to mitigate those events. Based on that evaluation, Notes were proposed for several systems to prohibit the use of LCO 3.0.4.b. These Notes were applied to LTOP, ECCS-Shutdown, AFW, and AC Sources - Operating. TSTF-359-A also removed existing Notes from the ISTS and revised SR 3.0.4. There is no technical basis for concluding that the analysis performed in support of TSTF-359-A and the high-risk configurations addressed by the Notes are applicable to AP1000 plants. TSTF-359-A is not implemented by this GTST and is deferred for future consideration.

TSTF-425-A deferred for future consideration.

TSTF-479-A has been applied to AP1000 GTS 3.4.14, Rev 19 by Westinghouse. TSTF-479-A will not be discussed further as a part of this GTST.

TSTF-481-T clarifies the Westinghouse Owners Group (WOG) surveillance (STS SR 3.4.12.8) regarding a COT on the PORVs to verify that the PORV is capable of performing its LTOP function. The AP1000 design does not utilize pressurizer PORVs to provide LTOP protection and a similar SR for the AP1000 does not exist. Therefore, TSTF-481-T does not apply to the AP1000 GTS. TSTF-481-T will not be discussed further as a part of this GTST.

DOC M06 was initially applied to this GTS. The VEGP TSU LAR was modified in response to NRC staff RAIs in Reference 8 and the Southern Nuclear Operating Company RAI Response in Reference 9. DOC M06 was withdrawn.

IV. Additional Changes Proposed as Part of this GTST (modifications proposed by NRC staff and/or clear editorial changes or deviations identified by preparer of GTST)

Clarification is added in several places in the Bases and grammatical errors are corrected in the Bases.

APOG Recommended Changes to Improve the Bases

Revise the first sentence of the first paragraph of the “ASA” section of the Bases, under the heading “RNS Suction Relief Valve Performance” to provide improved clarity, consistency, and operator usability:

...the relief valve will pass flow greater than that required for the limiting LTOP transient while maintaining RCS pressure less than the ~~minimum lowest~~ of ~~either~~ the P/T limit curve ~~pressure~~, 110% ~~percent~~ of the ~~RNS~~ design pressure ~~of the normal residual heat removal system~~, or the acceptable RNS relief valve inlet pressure.

Revise the second sentence of the first paragraph of the “ASA” section of the Bases, under the heading “RCS Vent Performance” to provide improved clarity, consistency, and operator usability:

...RCS pressure less than the ~~minimum lower~~ of either the maximum pressure on the P/T limit curve or 110% ~~percent~~ of the ~~RNS~~ design pressure ~~of the normal residual heat removal system~~.

Revise the discussion of the elements in the “LCO” section of the Bases to provide improved clarity, consistency, and operator usability:

- a. One OPERABLE RNS suction relief valve. ~~;-or~~

An RNS suction relief valve is OPERABLE for LTOP when both RNS suction isolation valves in one flow path are open, its setpoint is set within the PTLR (Ref. ~~erence~~ 6) limit, and testing has proven its ability to open at this setpoint. ~~;~~ or

- b. A depressurized RCS and an RCS vent.

An RCS vent is OPERABLE when ~~a vent path is~~ open with ~~an a flow~~ area of ≥ 4.15 square inches.

Revise the last sentence of the first paragraph in the “Applicability” section of the Bases to provide consistency with the TS requirement(s) being discussed in the TS Bases. Supplying additional information, deleting statements inconsistent with the TS, or correcting obvious misstatements reduces potential for misunderstanding and misapplication:

In MODE 6, ~~when with~~ the reactor vessel head ~~is off,~~ ~~and~~ ~~an~~ overpressurization cannot occur.

Revise the first sentence in the “SRs” section of the Bases, under the heading “SR 3.4.14.3” to provide consistency with the TS requirement(s) being discussed in the TS Bases. Supplying additional information, deleting statements inconsistent with the TS, or correcting obvious

misstatements reduces potential for misunderstanding and misapplication. There is no “operability” for open verification:

The RCS vent of ≥ 4.15 square inches is ~~proven-OPERABLE-by-verifying-its~~
~~verified~~ open ~~condition~~ either.

Revise the last sentence in the “SRs” section of the Bases, under the heading “SR 3.4.14.3” to provide consistency with the TS requirement(s) being discussed in the TS Bases. Supplying additional information, deleting statements inconsistent with the TS, or correcting obvious misstatements reduces potential for misunderstanding and misapplication:

~~The passive vent arrangement must only be open to be OPERABLE.~~ This
Surveillance **is modified by a Note that states it is only** required to be **met**
~~performed~~ if the vent is being used to satisfy the pressure relief requirements of
~~the~~ LCO 3.4.14.b.

Throughout the Bases, references to Sections and Chapters of the FSAR do not include the “FSAR” clarifier. Since these Section and Chapter references are to an external document, it is appropriate to include the “FSAR” modifier. (DOC A003)

V. Applicability

Affected Generic Technical Specifications and Bases:

Section 3.4.14, Low Temperature Overpressure Protection (LTOP) System

Changes to the Generic Technical Specifications and Bases:

LCO title and description is revised. This is an editorial change for clarity. (DOC A060)

Applicability Note is moved to become an LCO Note. This is an editorial change for clarity. (DOC A061)

Mathematical symbol in Condition A is replaced by text equivalent. This is an editorial change for clarity. (DOC A062)

The Statement of Condition C is replaced. The proposed change revises Condition C such that it applies to either the RNS suction relief valve or RCS depressurized with a vent path using LTOP methods. (DOC M09)

A Note is added to SR 3.4.14.1, SR 3.4.14.2, and SR 3.4.14.4. This is an editorial change for clarity. (DOC A061)

Note text is revised in SR 3.4.14.3. This is an editorial change for clarity. (DOC A061)

The first sentence of the first paragraph of the “ASA” section of the Bases, under the heading “RNS Suction Relief Valve Performance” is revised. (APOG Comment)

The second sentence of the first paragraph of the “ASA” section of the Bases, under the heading “RCS Vent Performance” is revised. (APOG Comment)

The discussion of the elements in the “LCO” section of the Bases is revised to provide improved clarity, consistency, and operator usability. (APOG Comment)

The last sentence of the first paragraph of the “Applicability” section of the Bases is revised to provide consistency with the TS requirement(s) being discussed. (APOG Comment)

The first sentence in the “SRs” section of the Bases, under the heading “SR 3.4.14.3” is revised to provide consistency with the TS requirement(s) being discussed. (APOG Comment)

The last sentence in the “SRs” section of the Bases, under the heading “SR 3.4.14.3” is revised to provide consistency with the TS requirement(s) being discussed.

The acronym “FSAR” is added to modify “Section” and “Chapter” in references to the FSAR throughout the Bases. (DOC A003) (APOG Comment)

VI. Traveler Information**Description of TSTF changes:**

Not Applicable

Rationale for TSTF changes:

Not Applicable

Description of changes in RCOL Std. Dep., RCOL COL Item(s), and RCOL PTS Changes:

DOC A060 revises TS 3.4.14, "Low Temperature Overpressure Protection (LTOP) System," by deleting "System" from the title and corresponding references such that the title is "Low Temperature Overpressure Protection (LTOP)."

DOC A061 moves LCO Applicability Note to after the LCO statement. SR 3.4.14.1 is revised by adding a Note stating "Only required to be met when accumulator pressure is greater than or equal to the maximum RCS pressure for the existing RCS cold leg temperature allowed by the P/T limit curves provided in the PTLR." SR 3.4.14.2 and SR 3.4.14.4 are revised by adding a Note stating "Only required to be met when complying with LCO 3.4.14.a." SR 3.4.14.3 is revised by changing "to be performed" to "to be met."

DOC A062 revises Condition A by replacing the symbol " \geq " with "greater than or equal."

DOC M09 revises Condition C from "The RNS suction relief valve inoperable," to "Required LTOP method inoperable for reasons other than Condition A or B."

A more detailed description of each DOC can be found in Reference 2, VEGP TSU LAR Enclosure 1, and the NRC staff safety evaluation can be found in Reference 3, VEGP LAR SER. The VEGP TSU LAR was modified in response to NRC staff RAIs in Reference 8 and the Southern Nuclear Operating Company RAI Response in Reference 9.

Rationale for changes in RCOL Std. Dep., RCOL COL Item(s), and RCOL PTS Changes:

DOC A060 is implemented because the reference to a Low Temperature Overpressure Protection (LTOP) System is misleading. There is no "system" for overpressure protection; instead, there are methods of overpressure protection, or conditions that must be met to prevent overpressurization, as specified in LCO 3.4.14.

The changes to the surveillance column note of SR 3.4.14.3 and its associated Bases per DOC A061 involve replacing the phrase "to be performed" with "to be met." The phrase "to be met" is appropriate, since the intended meaning of the note is to convey an exception to meeting the surveillance requirement acceptance criteria under specified conditions consistent with the LCO. These changes and the changes made per DOC A062 are consistent with the guidance provided in the TS Writer's Guide (Reference 7), Section 4.1.7.g.

DOC M09 is implemented because no Condition currently addresses the Actions required to be taken in the event the required method of LTOP consisting of RCS depressurized and an RCS

vent of ≥ 4.15 square inches is not Operable in compliance with GTS LCO 3.4.14.b. The proposed change revises Condition C such that it applies to either the RNS suction relief valve or RCS depressurized with a vent path using LTOP methods. In either case, GTS Required Actions and Completion Times specified in Required Action C.1 and Required Action C.2 are reasonable and result in restoration of LTOP.

Description of additional changes proposed by NRC staff/preparer of GTST:

The first sentence of the first paragraph of the “ASA” section of the Bases, under the heading “RNS Suction Relief Valve Performance” is revised to state (APOG Comment):

...the relief valve will pass flow greater than that required for the limiting LTOP transient while maintaining RCS pressure less than the ~~minimum~~ **lowest** of ~~either~~ the P/T limit curve **pressure**, 110% ~~percent~~ of the **RNS** design pressure ~~of the normal residual heat removal system~~, or the acceptable RNS relief valve inlet pressure.

The second sentence of the first paragraph of the “ASA” section of the Bases, under the heading “RCS Vent Performance” is revised to state (APOG Comment):

...RCS pressure less than the ~~minimum~~ **lower** of either the maximum pressure on the P/T limit curve or 110% ~~percent~~ of the **RNS** design pressure ~~of the normal residual heat removal system~~.

The discussion of the elements in the “LCO” section of the Bases is revised (APOG Comment):

- a. One OPERABLE RNS suction relief valve. ~~;~~ ~~or~~

An RNS suction relief valve is OPERABLE for LTOP when both RNS suction isolation valves in one flow path are open, its setpoint is set within the PTLR (Ref. ~~erence~~ 6) limit, and testing has proven its ability to open at this setpoint. ~~;~~ or

- b. A depressurized RCS and an RCS vent.

An RCS vent is OPERABLE when **a vent path is** open with ~~an a flow~~ **a flow** area of ≥ 4.15 square inches.

The last sentence of the first paragraph in the “Applicability” section of the Bases is revised (APOG Comment):

In MODE 6, ~~when with~~ the reactor vessel head ~~is off,~~ ~~and~~ **an** overpressurization cannot occur.

The first sentence in the “SRs” section of the Bases, under the heading “SR 3.4.14.3” is revised (APOG Comment):

The RCS vent of ≥ 4.15 square inches is ~~proven OPERABLE by verifying its~~ **verified** open ~~condition~~ either.

The last sentence in the “SRs” section of the Bases, under the heading “SR 3.4.14.3” is revised (APOG Comment):

~~The passive vent arrangement must only be open to be OPERABLE.~~ This Surveillance **is modified by a Note that states it is only** required to be **met performed** if the vent is being used to satisfy the pressure relief requirements of ~~the~~ LCO 3.4.14.b.

The acronym “FSAR” is added to modify “Section” and “Chapter” in references to the FSAR throughout the Bases. (DOC A003) (APOG Comment)

Clarifications are also added to the Bases and several grammatical errors are corrected in the Bases.

Rationale for additional changes proposed by NRC staff/preparer of GTST:

The revision to the “ASA” section of the Bases, under the heading “RNS Suction Relief Valve Performance” is a non-technical change that provides improved clarity, consistency, and operator usability.

The revision to the “ASA” section of the Bases, under the heading “RCS Vent Performance” is a non-technical change that provides improved clarity, consistency, and operator usability.

The revision to the discussion of the elements in the “LCO” section of the Bases is a non-technical change that provides improved clarity, consistency, and operator usability.

The revision to the “Applicability” section of the Bases provides consistency with the TS requirement(s) being discussed in the TS Bases. Supplying additional information, deleting statements inconsistent with the TS, or correcting obvious misstatements reduces potential for misunderstanding and misapplication.

The revision to the “SRs” section of the Bases, under the heading “SR 3.4.14.3” provides consistency with the TS requirement(s) being discussed in the TS Bases. Supplying additional information, deleting statements inconsistent with the TS, or correcting obvious misstatements reduces potential for misunderstanding and misapplication. There is no “operability” for open verification.

Clarifying remarks are necessary to make the Bases discussion complete.

Since Bases references to FSAR Sections and Chapters are to an external document, it is appropriate to include the “FSAR” modifier.

VII. GTST Safety Evaluation

Technical Analysis:

DOC A060 revises TS 3.4.14, “Low Temperature Overpressure Protection (LTOP) System,” by deleting “System” from the title and corresponding references such that the title is “Low Temperature Overpressure Protection (LTOP).” Reference to a LTOP System is misleading. There is no “system” for overpressure protection; instead, there are methods of overpressure protection, or conditions that must be met to prevent overpressurization, as provided in the TS 3.4.14 LCO.

DOC M09 revises Condition C from “The RNS suction relief valve inoperable,” to “Required LTOP method inoperable for reasons other than Condition A or B.” TS 3.4.14 LCO requires accumulators to be isolated and either the Normal Residual Heat Removal System (RNS) suction relief valve with lift setting within the limit specified in the Pressure Temperature Limits Report (PTLR), or the RCS depressurized with an RCS vent of ≥ 4.15 square inches. TS 3.4.14 provides Actions in the event an accumulator is not isolated when required (Condition A) and for an inoperable RNS suction relief valve (Condition C). However, no Condition currently addresses the Actions required to be taken in the event the required method of LTOP consisting of RCS depressurized and an RCS vent of ≥ 4.15 square inches is not operable in compliance with GTS LCO 3.4.14.b.

With respect to GTS 3.4.14, the LCO is applicable in Mode 4 when any cold leg temperature is $\leq 275^{\circ}\text{F}$; in Mode 5; and in Mode 6 when the reactor vessel head is on. If the required method of LTOP consists of the depressurized RCS with an RCS vent of ≥ 4.15 square inches, and the vent is found to be covered such that sufficient pressure protection does not exist, the GTS 3.4.14 Actions would result in entry into the requirements of LCO 3.0.3. LCO 3.0.3 requires, in part, that when an LCO is not met and an associated Action is not provided, that the unit shall be placed in a Mode or other specified condition in which the LCO is not applicable. Action shall be initiated within 1 hour to place the unit, as applicable, in: a) Mode 3 within 7 hours; and b) Mode 4 within 13 hours; and c) Mode 5 within 37 hours. Therefore, if in Mode 4 with cold leg temperature $\leq 275^{\circ}\text{F}$ with an insufficient RCS vent, LCO 3.0.3 would require that action be initiated within 1 hour to place the unit in Mode 5 within 37 hours. LCO 3.0.3 would then require no further actions; the unit would still be in the Mode of applicability without sufficient LTOP. Entry into LCO 3.0.3 would result in no actions if the unit is in Mode 5 or Mode 6 when the reactor vessel head is on with an insufficient RCS vent.

DOC M09 revises Condition C such that it applies to either the RNS suction relief valve or RCS depressurized with a vent path using LTOP methods. In either case, GTS Required Actions and Completion Times specified in Required Action C.1 and Required Action C.2 are reasonable and result in restoration of LTOP.

The remaining changes are editorial, clarifying, grammatical, or otherwise considered administrative. These changes do not affect the technical content, but improve the readability, implementation, and understanding of the requirements, and are therefore acceptable.

Having found that this GTST’s proposed changes to the GTS and Bases are acceptable, the NRC staff concludes that AP1000 STS Subsection 3.4.14 is an acceptable model Specification for the AP1000 standard reactor design.

References to Previous NRC Safety Evaluation Reports (SERs):

None

VIII. Review Information**Evaluator Comments:**

None

Randy Belles
Oak Ridge National Laboratory
865-574-0388
bellesrj@ornl.gov

Review Information:

Availability for public review and comment on Revision 0 of this traveler approved by NRC staff on 5/16/2014.

APOG Comments (Ref. 10) and Resolutions:

1. (Internal #3) Throughout the Bases, references to Sections and Chapters of the FSAR do not include the "FSAR" clarifier. Since these Section and Chapter references are to an external document, it is appropriate (DOC A003) to include the "FSAR" modifier. This is resolved by adding the FSAR modifier as appropriate.
2. (Internal # 6) The GTST sections often repeat VEGP LAR DOCs, which reference "existing" and "current" requirements. The inclusion in the GTST of references to "existing" and "current," are not always valid in the context of the GTS. Each occurrence of "existing" and "current" should be revised to be clear and specific to GTS, MTS, or VEGP COL TS (or other), as appropriate. Noted ambiguities are corrected in the GTST body.
3. (Internal #7) Section VII, GTST Safety Evaluation, inconsistently completes the subsection "References to Previous NRC Safety Evaluation Reports (SERs)" by citing the associated SE for VEGP 3&4 COL Amendment 13. It is not clear whether there is a substantive intended difference when omitting the SE citation. This is resolved by removing the SE citation in Section VII of the GTST and ensuring that appropriate references to the consistent citation of this reference in Section X of the GTST are made.
4. (Internal # 11) The GTST incorporates TSTF-359-A, Rev. 9. The justification for TSTF-359 was based on vendor-specific evaluations. For Westinghouse plants, that evaluation was in MUHP-3015, "Qualitative Risk Assessment Supporting Increased Flexibility in Mode Restraints," January 2002. This report evaluated "the key plant changes that occur during the Mode changes so it is possible to identify the initiating events that can occur and systems available for event detection, actuation, and mitigation." It also considered initiating events and equipment available to mitigate those events. Based on that evaluation, Notes were proposed for several systems to prohibit the use of LCO 3.0.4.b. These Notes were applied to LTOP, ECCS-Shutdown, AFW, and AC Sources - Operating. TSTF-359-A also removed existing Notes from the ISTS and revised SR 3.0.4. There is no technical basis for concluding that the analysis performed in support of TSTF-359-A and the high-risk configurations addressed by the Notes are applicable to AP1000 plants. Remove TSTF-359-A from the GTST. Include TSTF-359-A in the reference disposition tables, as "TSTF deferred for future consideration"

Note: also reinstate LCO 3.0.4 “not applicable” Notes deleted in various Specifications as a result of incorporating TSTF-359. This is resolved by reversing all changes implemented by the initial application of TSTF-359-A to this GTST.

5. (Internal #13) Many GTSTs evaluated TSTF-425 with the following note: Risk-informed TS changes will be considered at a later time for application to the AP1000 STS.

The NRC approval of TSTF-425, and model safety evaluation provided in the CLIIP for TSTF-425, are generically applicable to any design’s Technical Specifications. As such, the replacement of certain Frequencies with a Surveillance Frequency Control Program should be included in the GTST for AP1000 STS NUREG.

However, implementation in the AP1000 STS should not reflect optional (i.e., bracketed) material showing retention of fixed Surveillance Frequencies where relocation to a Surveillance Frequency Control Program is acceptable. Since each represented AP1000 Utility is committed to maintaining standardization, there is no rationale for an AP1000 STS that includes bracketed options.

Consistent with TSTF-425 criteria, replace applicable Surveillance Frequencies with “In accordance with the Surveillance Frequency control Program” and add that Program as new AP1000 STS Specification 5.5.15.

NRC Staff disagreed with implementing TSTF-425 in the initial version of the STS. Although the APOG thinks the analysis supporting this traveler is general enough to be applicable to AP1000, staff thinks an AP1000-specific proposal from APOG is needed to identify any GTS SRs that should be excluded. Also, with the adoption of a Surveillance Frequency Control Program (SFCP) in the AP1000 STS, bracketed Frequencies, which provide a choice between the GTS Frequency and the SFCP Frequency, are needed because the NRC will use the AP1000 STS as a reference, and to be consistent with NUREG-1431, Rev. 4. APOG was requested to consider proposing an AP1000 version of TSTF-425 for a subsequent revision of the STS.

6. (Internal # 277) Condition C wording has a typo. Revise Condition C statement to say “. . . Condition A or B . . .” This is resolved by making the recommended change.
7. (Internal # 278) An editorial change is recommended to the “ASA” section of the Bases, under the heading “RNS Suction Relief Valve Performance.” Revise the first sentence of the first paragraph, as indicated:

. . . the relief valve will pass flow greater than that required for the limiting LTOP transient while maintaining RCS pressure less than the ~~minimum~~ **lowest** of either the P/T limit curve, 110% ~~percent~~ of the . . .

This non-technical change provides improved clarity, consistency, and operator usability. This is resolved by making the recommended change with additional edits.

. . . the relief valve will pass flow greater than that required for the limiting LTOP transient while maintaining RCS pressure less than the ~~minimum~~ **lowest** of ~~either~~ the P/T limit curve **pressure**, 110% ~~percent~~ of the **RNS** design pressure ~~of the normal residual heat removal system~~, or the acceptable RNS relief valve inlet pressure.

In addition, in the “Background” section of the Bases, under the heading “RNS Suction Relief Valve Requirements,” a blank line is inserted between the second and third paragraphs. (NRC Staff Comment)

8. (Internal # 279) An editorial change is recommended to the “ASA” section of the Bases, under the heading “RCS Vent Performance.” Revise the second sentence of the first paragraph, as indicated:

...RCS pressure less than the ~~minimum~~ **lower** of either the maximum pressure on the P/T limit curve or 110% ~~percent~~ of the design pressure of the normal residual heat removal system.

This non-technical change provides improved clarity, consistency, and operator usability. This is resolved by making the recommended change with additional edits.

...RCS pressure less than the ~~minimum~~ **lower** of either the maximum pressure on the P/T limit curve or 110% ~~percent~~ of the **RNS** design pressure ~~of the normal residual heat removal system.~~

9. (Internal # 280 and 281) An editorial change is recommended to the “LCO” section of the Bases to move the word “or” such that it follows the discussion in element “a.” This non-technical change provides improved clarity, consistency, and operator usability. This is resolved by making the recommended change with additional edits. Revise the second paragraph by adding a blank line after it and make the remaining revisions as indicated:

- a. One OPERABLE RNS suction relief valve. ~~;~~~~or~~

An RNS suction relief valve is OPERABLE for LTOP when both RNS suction isolation valves in one flow path are open, its setpoint is set within the PTLR (Ref. ~~erence~~ 6) limit, and testing has proven its ability to open at this setpoint. ; ~~or~~

- b. A depressurized RCS and an RCS vent.

An RCS vent is OPERABLE when **a vent path is** open with ~~an~~ **a flow** area of ≥ 4.15 square inches.

10. (Internal # 282) An editorial change is recommended to provide consistency with the TS requirement(s) being discussed in the TS Bases. Supplying additional information, deleting statements inconsistent with the TS, or correcting obvious misstatements reduces potential for misunderstanding and misapplication. In the “Applicability” section of the Bases, revise the last sentence of the first paragraph, as indicated:

In MODE 6, ~~when~~ **with** the reactor vessel head ~~is off,~~ **and** **an** overpressurization cannot occur.

This is resolved by making the recommended change.

11. (Internal # 283) An editorial change is recommended to provide consistency with the TS requirement(s) being discussed in the TS Bases. Supplying additional information, deleting statements inconsistent with the TS, or correcting obvious misstatements reduces potential for misunderstanding and misapplication. There is no “operability” for open verification. In the “SRs” section of the Bases, under the heading “SR 3.4.14.3”, revise the first sentence, as indicated:

The RCS vent of ≥ 4.15 square inches is ~~proven OPERABLE by verifying its~~ **verified** open ~~condition~~ either:

This is resolved by making the recommended change.

12. (Internal # 284) An editorial change is recommended to provide consistency with the TS requirement(s) being discussed in the TS Bases. Supplying additional information, deleting statements inconsistent with the TS, or correcting obvious misstatements reduces potential for misunderstanding and misapplication. In the "SRs" section of the Bases, under the heading "SR 3.4.14.3", revise the last sentence, as indicated:

~~The passive vent arrangement must only be open to be OPERABLE.~~ This Surveillance **is modified by a Note that states it is only** required to be performed if the vent is being used to satisfy the pressure relief requirements of the LCO 3.4.14.b.

This is resolved by making the recommended change with additional edits based on DOC A061:

~~The passive vent arrangement must only be open to be OPERABLE.~~ This Surveillance **is modified by a Note that states it is only** required to be **met performed** if the vent is being used to satisfy the pressure relief requirements of ~~the~~ LCO 3.4.14.b.

13. (Internal # 284) Based on generic observation E in Reference 7, GTST Section VI is revised to include additional rationale for DOC A061. Observation E noted that the level of discussion varies from section to section. For example, the discussion detail for DOC L03 in the Description of changes in RCOL Std. Dep., RCOL COL Item(s), and RCOL PTS Changes and the Rationale for changes in RCOL Std. Dep., RCOL COL Item(s), and RCOL PTS Changes for GTST Sections 1.1, 3.8.2, 3.8.4, and 3.8.6 differ from those provided in GTST Sections 3.9.1, 3.9.2, and 3.9.3.

NRC Final Approval Date: 12/7/2015

NRC Contact:

Hien Le
United States Nuclear Regulatory Commission
301-415-1511
Hien.Le@nrc.gov

IX. Evaluator Comments for Consideration in Finalizing Technical Specifications and Bases

None

X. References Used in GTST

1. AP1000 DCD, Revision 19, Section 16, "Technical Specifications," June 2011 (ML11171A500).
2. Southern Nuclear Operating Company, Vogtle Electric Generating Plant, Units 3 and 4, Technical Specifications Upgrade License Amendment Request, February 24, 2011 (ML12065A057).
3. NRC Safety Evaluation (SE) for Amendment No. 13 to Combined License (COL) No. NPF-91 for Vogtle Electric Generating Plant (VEGP) Unit 3, and Amendment No. 13 to COL No. NPF-92 for VEGP Unit 4, September 9, 2013, ADAMS Package Accession No. ML13238A337, which contains:
 - ML13238A355 Cover Letter - Issuance of License Amendment No. 13 for Vogtle Units 3 and 4 (LAR 12-002).
 - ML13238A359 Enclosure 1 - Amendment No. 13 to COL No. NPF-91
 - ML13239A256 Enclosure 2 - Amendment No. 13 to COL No. NPF-92
 - ML13239A284 Enclosure 3 - Revised plant-specific TS pages (Attachment to Amendment No. 13)
 - ML13239A287 Enclosure 4 - Safety Evaluation (SE), and Attachment 1 - Acronyms
 - ML13239A288 SE Attachment 2 - Table A - Administrative Changes
 - ML13239A319 SE Attachment 3 - Table M - More Restrictive Changes
 - ML13239A333 SE Attachment 4 - Table R - Relocated Specifications
 - ML13239A331 SE Attachment 5 - Table D - Detail Removed Changes
 - ML13239A316 SE Attachment 6 - Table L - Less Restrictive Changes

The following documents were subsequently issued to correct an administrative error in Enclosure 3:

 - ML13277A616 Letter - Correction To The Attachment (Replacement Pages) - Vogtle Electric Generating Plant Units 3 and 4-Issuance of Amendment Re: Technical Specifications Upgrade (LAR 12-002) (TAC No. RP9402)
 - ML13277A637 Enclosure 3 - Revised plant-specific TS pages (Attachment to Amendment No. 13) (corrected)
4. 10 CFR 50.65, "Requirements for Monitoring the Effectiveness of Maintenance at Nuclear Power Plants."
5. NUMARC 93-01, Section 11, Revision 4, "Industry Guideline for Monitoring the Effectiveness of Maintenance at Nuclear Power Plants," December 2010 (ML110050227).
6. NRC Regulatory Guide 1.182, "Assessing and Managing Risk before Maintenance Activities at Nuclear Power Plants," May 2000 (ML003699426).
7. TSTF-GG-05-01, "Writer's Guide for Plant-Specific Improved Technical Specifications," June 2005.
8. RAI Letter No. 01 Related to License Amendment Request (LAR) 12-002 for the Vogtle Electric Generating Plant Units 3 and 4 Combined Licenses, September 7, 2012 (ML12251A355).

9. Southern Nuclear Operating Company, Vogtle Electric Generating Plant, Units 3 and 4, Response to Request for Additional Information Letter No. 01 Related to License Amendment Request LAR-12-002, ND-12-2015, October 04, 2012 (ML12286A363 and ML12286A360)
 10. APOG-2014-008, APOG (AP1000 Utilities) Comments on AP1000 Standardized Technical Specifications (STS) Generic Technical Specification Travelers (GTSTs), Docket ID NRC-2014-0147, September 22, 2014 (ML14265A493).
-

XI. MARKUP of the Applicable GTS Subsection for Preparation of the STS NUREG

The entire section of the Specifications and the Bases associated with this GTST is presented next.

Changes to the Specifications and Bases are denoted as follows: Deleted portions are marked in strikethrough red font, and inserted portions in bold blue font.

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.14 Low Temperature Overpressure Protection (LTOP)-~~System~~

LCO 3.4.14

At least one of the following ~~o~~Overpressure ~~p~~Protection **methods**
~~Systems~~ shall be OPERABLE, with the accumulators isolated:

- a. The Normal Residual Heat Removal System (RNS) suction relief valve with lift setting within the limit specified in the PTLR, or
- b. The RCS depressurized and an RCS vent of ≥ 4.15 square inches.

-----NOTES-----

1. No reactor coolant pump (RCP) shall be started when the RCS temperature is $\geq 350^{\circ}\text{F}$ unless pressurizer level is $< 92\%$.
2. No RCP shall be started with any RCS cold leg temperature $\leq 350^{\circ}\text{F}$ unless the secondary side water temperature of each steam generator (SG) is $\leq 50^{\circ}\text{F}$ above each of the RCS cold leg temperatures and the RCP is started at $\leq 25\%$ of RCP speed.
3. **Accumulator isolation is only required when accumulator pressure is greater than or equal to the maximum RCS pressure for the existing RCS cold leg temperature allowed by the P/T limit curves provided in the PTLR.**

APPLICABILITY: MODE 4 when any cold leg temperature is $\leq 275^{\circ}\text{F}$,
MODE 5,
MODE 6 when the reactor vessel head is on.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. An accumulator not isolated when the accumulator pressure is greater than or equal > to the maximum RCS pressure for existing cold leg temperature allowed in the PTLR.	A.1 Isolate affected accumulator.	1 hour
B. Required Action and associated Completion Time of Condition A not met.	B.1 Increase RCS cold leg temperature to a level acceptable for the existing accumulator pressure allowed in the PTLR.	12 hours
	<u>OR</u> B.2 Depressurize affected accumulator to less than the maximum RCS pressure for existing cold leg temperature allowed in the PTLR.	12 hours
C. Required LTOP method inoperable for reasons other than Condition A or B. The RNS suction relief valve inoperable.	C.1 Restore the RNS suction relief valve to OPERABLE status.	12 hours
	<u>OR</u> C.2 Depressurize RCS and establish RCS vent of ≥ 4.15 square inches.	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.14.1 -----NOTE----- Only required to be met when accumulator pressure is greater than or equal to the maximum RCS pressure for the existing RCS cold leg temperature allowed by the P/T limit curves provided in the PTLR. ----- Verify each accumulator is isolated.	12 hours
SR 3.4.14.2 -----NOTE----- Only required to be met when complying with LCO 3.4.14.a. ----- Verify both RNS suction isolation valves in one RNS suction flow path are open.	12 hours
SR 3.4.14.3 -----NOTE----- Only required to be met performed when complying with LCO 3.4.14.b. ----- Verify RCS vent \geq 4.15 square inches is open.	12 hours for unlocked-open vent <u>AND</u> 31 days for locked-open vent

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.4.14.4</p> <p>-----NOTE----- Only required to be met when complying with LCO 3.4.14.a. -----</p> <p>Verify the lift setting of the RNS suction relief valve.</p>	<p>In accordance with the Inservice Testing Program</p>

B 3.4 REACTOR COOLANT SYSTEM (RCS)

B 3.4.14 Low Temperature Overpressure Protection (LTOP)-System

BASES

BACKGROUND ~~The~~ LTOP ~~System~~ limits RCS pressure at low temperatures so that the integrity of the reactor coolant pressure boundary (RCPB) is not compromised by violating the pressure and temperature (P/T) limits of 10 CFR 50, Appendix G (Ref. 1). The reactor vessel is the limiting RCPB component for demonstrating such protection. The PTLR provides the limits which set the maximum allowable setpoints for the Normal Residual Heat Removal System (RNS) suction relief valve. LCO 3.4.3 provides the maximum RCS pressure for the existing RCS cold leg temperature during cooldown, shutdown, and heatup to meet the Reference 1 requirements during the LTOP MODES.

The reactor vessel material is less tough at low temperatures than at normal operating temperature. As the vessel neutron exposure accumulates, the material toughness decreases and becomes less resistant to pressure stress at low temperatures (Ref. 2). RCS pressure, therefore, is maintained low at low temperatures and is increased only as temperature is increased.

The potential for vessel overpressurization is most acute when the RCS is water solid, occurring only while shutdown; a pressure fluctuation can occur more quickly than an operator can react to relieve the condition. Exceeding the RCS P/T limits by a significant amount could cause brittle cracking of the reactor vessel. LCO 3.4.3, "RCS Pressure and Temperature (P/T) Limits," requires administrative control of RCS pressure and temperature during heatup and cooldown to prevent exceeding the PTLR limits.

This LCO provides RCS overpressure protection by having a maximum coolant input capability and having adequate pressure relief capacity. Limiting coolant input capability requires isolating the accumulators. The pressure relief capacity requires the RNS suction relief valve or a depressurized RCS and an RCS vent of sufficient size. The RNS suction relief valve or the open RCS vent is the overpressure protection device that acts to terminate an increasing pressure event.

BASES

BACKGROUND (continued)

RNS Suction Relief Valve Requirements

During the LTOP MODES, the RNS system is operated for decay heat removal. Therefore, the RNS suction isolation valves are open in the piping from the RCS hot legs to the inlet of the RNS system. While these valves are open, the RNS suction relief valve is exposed to the RCS and able to relieve pressure transients in the RCS.

The RNS suction relief valve is a spring loaded, water relief valve with a pressure tolerance and an accumulation limit established by Section III of the American Society of Mechanical Engineers (ASME) Code (Ref. 3) for Class 2 relief valves.

The RNS suction isolation valves must be open to make the RNS suction relief valves OPERABLE for RCS overpressure mitigation.

RCS Vent Requirements

Once the RCS is depressurized, a vent exposed to the containment atmosphere will maintain the RCS at containment ambient pressure in an RCS overpressure transient, if the relieving requirements of the transient do not exceed the capabilities of the vent. Thus, the vent path must be capable of relieving the flow resulting from the limiting LTOP mass or heat input transient, and maintaining pressure below the P/T limits. The required vent capacity may be provided by one or more vent paths.

For an RCS vent to meet the flow capacity requirement, it may require removing one or more pressurizer safety valves or manually opening one or more Automatic Depressurization System (ADS) valves. The vent path(s) must be above the level of reactor coolant, so as not to drain the RCS when open.

APPLICABLE
SAFETY
ANALYSES

Safety analyses (Ref. 4) demonstrate that the reactor vessel is adequately protected against exceeding the Reference 1 P/T limits. In MODES 1, 2, and 3, and in MODE 4 with the RCS temperature above 275°F, the pressurizer safety valves will prevent RCS pressure from exceeding the Reference 1 limits. When the RNS is aligned and open to the RCS, overpressure protection is provided by the RNS suction relief valve, or a depressurized RCS and a sufficiently sized open RCS vent.

BASES

APPLICABLE SAFETY ANALYSES (continued)

The actual temperature at which the pressure in the P/T limit curve falls below the suction relief setpoint increases as the reactor vessel material toughness decreases due to neutron embrittlement. Each time the PTLR curves are revised, ~~the LTOP System~~ must be re-evaluated to ensure its functional requirements can still be met using the RNS suction relief valve, or the depressurized and vented RCS condition.

The PTLR contains the acceptance limits that define the LTOP requirements. Any change to the RCS must be evaluated against the Reference 4 analyses to determine the impact of the change on the LTOP acceptance limits.

Transients that are capable of overpressurizing the RCS are categorized as either mass or heat input transients. The events listed below were used in the analysis to size the RNS suction relief valve. Therefore, any events with a mass or heat input greater than the listed events cannot be accommodated and must be prevented.

Mass Input

- a. — Makeup water flow rate to the RCS assuming both CVS makeup pumps are in operation and letdown is isolated.

Heat Input

- a. — Restart of one reactor coolant pump (RCP) with water in the steam generator secondary side 50°F hotter than the primary side water, and the RCS water solid.

RNS Suction Relief Valve Performance

Since the RNS suction relief valve does not have a variable P/T lift setpoint, the analysis must show that with **the** chosen setpoint, the relief valve will pass flow greater than that required for the limiting LTOP transient while maintaining RCS pressure less than the **lowest minimum** of ~~either the P/T limit curve~~ **pressure**, 110% ~~percent~~ of the **RNS** design pressure ~~of the normal residual heat removal system~~, or the acceptable RNS relief valve inlet pressure. The current analysis shows that up to a temperature of 70°F, the mass input transient is limiting, and above this temperature the heat input transient is limiting.

BASES

APPLICABLE SAFETY ANALYSES (continued)

To prevent the possibility of a heat input transient, and thereby limit the required flow rate of the RNS suction relief valve, administrative requirements in the LCO note have been imposed for starting an RCP.

RCS Vent Performance

With the RCS depressurized, a vent size of 4.15 square inches is capable of mitigating a limiting overpressure transient. The area of the vent is equivalent to the area of the inlet pipe to the RNS suction relief valve so the capacity of the vent is greater than the flow possible with either the mass or heat input transient, while maintaining the RCS pressure less than the ~~lower minimum~~ of either the maximum pressure on the P/T limit curve or 110% ~~percent~~ of the ~~RNS~~ design pressure ~~of the normal residual heat removal system~~.

The required vent area may be obtained by opening one ADS Stage 2, 3, or 4 flow path.

The RCS vent size will be reevaluated for compliance each time the P/T limit curves are revised based on the results of the vessel material surveillance.

The RCS vent is passive and is not subject to active failure.

~~The~~ LTOP ~~System~~ satisfies Criterion 2 of 10 CFR 50.36(c)(2)(ii).

LCO

This LCO requires that ~~the~~ LTOP ~~System~~ is OPERABLE. ~~The~~ LTOP ~~System~~ is OPERABLE when the maximum coolant input and minimum pressure relief capabilities are OPERABLE. Violation of this LCO could lead to the loss of low temperature overpressure mitigation and violation of the Reference 1 limits as a result of an operational transient.

To limit the coolant input capability, the LCO requires all accumulator discharge isolation valves closed and immobilized, when accumulator pressure is greater than or equal to the maximum RCS pressure for the existing RCS temperature allowed in the PTLR.

BASES

LCO (continued)

The elements of the LCO that provide low temperature overpressure mitigation through pressure relief are:

- a. One OPERABLE RNS suction relief valve. ~~or~~

An RNS suction relief valve is OPERABLE for LTOP when both RNS suction isolation valves in one flow path are open, its setpoint is set within the PTLR (Ref. ~~erence~~ 56) limit, and testing has proven its ability to open at this setpoint. ~~;~~ or

- b. A depressurized RCS and an RCS vent.

An RCS vent is OPERABLE when a vent path is open with a flow ~~an~~ area of ≥ 4.15 square inches.

Each of these methods of overpressure prevention is capable of mitigating the limiting LTOP transient.

Note 1 prohibits startup of an RCP when the RCS temperature is $\geq 350^{\circ}\text{F}$ unless pressurizer level is $< 92\%$. This restraint is to prevent a low temperature overpressure event due to a thermal transient when an RCP is started.

Note 2 requires that the secondary side water temperature of each SG be $\leq 50^{\circ}\text{F}$ above each of the RCS cold leg temperatures before the start of an RCP with any RCS cold leg temperature $\leq 350^{\circ}\text{F}$, and the RCP must be started at $\leq 25\%$ of RCP speed. This restraint is to prevent a low temperature overpressure event due to a thermal transient when an RCP is started. This limitation also helps to ensure that the RNS system pressure remains below both the piping design pressure and the acceptable RNS relief valve inlet pressure.

Note 3 provides that accumulator isolation is only required when the accumulator pressure is more than or at the maximum RCS pressure for the existing temperature, as allowed by the P/T limit curves. This Note permits the accumulator discharge isolation valve closed position verification Surveillance to be performed only under these pressure and temperature conditions.

BASES

APPLICABILITY

This LCO is applicable in MODE 4 when any cold leg temperature is below 275°F, MODE 5, and in MODE 6 when the reactor vessel head is on. The pressurizer safety valves provide overpressure protection that meets the Reference 1 P/T limits above 275°F. In MODE 6, **with** the reactor vessel head ~~is~~-off, **an and** overpressurization cannot occur.

LCO 3.4.3 provides the operational P/T limits for all MODES. LCO 3.4.6, "Pressurizer Safety Valves," requires the OPERABILITY of the pressurizer safety valves that provide overpressure protection during MODES 1, 2, and 3, and MODE 4 with the RNS isolated or RCS temperature $\geq 275^{\circ}\text{F}$.

Low temperature overpressure prevention is most critical during shutdown when the RCS is water solid, and a mass or heat input transient can cause a very rapid increase in RCS pressure with little or no time for operator action to mitigate the event.

~~The Applicability is modified by a Note stating that accumulator isolation is only required when the accumulator pressure is more than or at the maximum RCS pressure for the existing temperature, as allowed by the P/T limit curves.~~

~~This Note permits the accumulator discharge isolation valve Surveillance to be performed only under these pressure and temperature conditions.~~

ACTIONS

A.1, B.1, and B.2

An unisolated accumulator requires isolation within 1 hour. This is only required when the accumulator pressure is at or more than the maximum RCS pressure for the existing temperature allowed by the P/T limit curves.

If isolation is needed and cannot be accomplished in 1 hour, Required Action B.1 and Required Action B.2 provide two options, either of which must be performed in the next 12 hours. By increasing the RCS temperature to $> 275^{\circ}\text{F}$, the accumulator pressure cannot **result in** exceeding the LTOP limits if the accumulators are fully injected. Depressurizing the accumulators below the LTOP limit **in from** the PTLR also gives this protection.

BASES

ACTIONS (continued)

The Completion Times are based on operating experience that these activities can be accomplished in these time periods and on engineering evaluations indicating that an event requiring LTOP is not likely in the allowed times.

C.1 and C.2

If the RNS suction relief valve is inoperable and the RCS is not depressurized, there is a potential to overpressurize the RCS and exceed the limits allowed in LCO 3.4.3. The suction relief valve is considered inoperable if the RNS isolation valves have isolated the RNS from the RCS in such a way that the suction relief valve cannot perform its intended safety function, or if the valve itself will not operate to perform its intended safety function. **If the RCS is depressurized but the RCS vent path does not provide a flow area sufficient to mitigate any of the design low temperature overpressure events and the RNS suction relief valve is inoperable, there is a potential to overpressurize the RCS and exceed the limits allowed in LCO 3.4.3. The RCS vent path is considered inoperable if the area of the vent is not equivalent to the area of the inlet pipe to the RNS suction relief valve.**

Under these conditions, Required Actions C.1 **and** ~~or~~ C.2 provide two options, either of which must be accomplished in 12 hours. If the RNS suction relief valve cannot be restored to OPERABLE status, the RCS must be depressurized and vented with an **n** RCS vent which provides a flow area sufficient to mitigate any of the design low temperature overpressure events.

The 12 hour Completion Time represents a reasonable time to repair the relief valve, open the RNS isolation valves or otherwise restore the **LTOP system** to OPERABLE status, or depressurize and vent the RCS, without imposing a lengthy period when **no the-LTOP methods are available system-is-not-able** to mitigate a low temperature overpressure event.

BASES

SURVEILLANCE
REQUIREMENTSSR 3.4.14.1

To minimize the potential for a low temperature overpressure event by limiting the mass input capability, the accumulator discharge isolation valves are verified closed and locked out. The Frequency of 12 hours is sufficient considering other indications and alarms available to the operator in the main control room to verify the required status of the equipment.

SR 3.4.14.1 is modified by a Note stating that accumulator isolation is only required when the accumulator pressure is more than or at the maximum RCS pressure for the existing temperature, as allowed by the P/T limit curves. This Note requires the accumulator discharge isolation valve Surveillance to be met only under these pressure and temperature conditions.

SR 3.4.14.2

The RNS suction relief valve shall be demonstrated OPERABLE by verifying two RNS suction isolation valves in one flow path are open. This Surveillance is only performed if the RNS suction relief valve is being used to satisfy this LCO.

The RNS suction isolation valves are verified to be opened every 12 hours. The Frequency is considered adequate in view of other administrative controls such as valve status indications available to the operator in the control room that verify the RNS suction isolation valves remain open. **This Surveillance is required to be met if the RNS suction relief valve is being used to satisfy the pressure relief requirements of LCO 3.4.14.a.**

SR 3.4.14.3

The RCS vent of ≥ 4.15 square inches is verified ~~proven OPERABLE by verifying its open condition~~ either:

- a. Once every 12 hours for a valve that is not locked (valves that are sealed or secured in the open position are considered "locked" in this context); or
- b. Once every 31 days for other vent path(s) (e.g., a vent valve that is locked, sealed, or secured in position or a removed pressurizer safety valve or open manway also fits this category).

BASES

SURVEILLANCE REQUIREMENTS (continued)

~~The passive vent arrangement must only be open to be OPERABLE.~~

This Surveillance is **modified by a Note that states it is only** required to be **met performed** if the vent is being used to satisfy the pressure relief requirements of ~~the~~ LCO 3.4.14.b.

SR 3.4.14.4

The RNS suction relief valve shall be demonstrated OPERABLE by verifying that two RNS suction isolation valves in one flow path are open and by testing it in accordance with the Inservice Testing Program. (Refer to SR 3.4.14.2 for the RNS suction isolation valve Surveillance.) This Surveillance is only required to be **met performed** if the RNS suction relief valve is being used to meet this LCO. The ASME OM Code (Ref. ~~65~~) test per Inservice Testing Program verifies OPERABILITY by proving proper relief valve mechanical motion and by measuring and, if required, adjusting the lift setpoint. **This Surveillance is required to be met if the RNS suction relief valve is being used to satisfy the pressure relief requirements of LCO 3.4.14.a.**

REFERENCES

1. Title 10, Code of Federal Regulations, Part 50, Appendix G, "Fracture Toughness Requirements."
2. Generic Letter 88-11, "NRC Position on Radiation Embrittlement of Reactor Vessel Materials and Its Impact on Plant Operation."
3. ASME Boiler and Pressure Vessel Code, Section III.
4. **FSAR** Section 5.2.2, "Overpressure Protection."
5. **APP-RXS-Z0R-001, Revision 2, "AP1000 Generic Pressure Temperature Limits Report," F. C. Gift, September 2008.** ~~ASME OM Code, "Code for Operation and Maintenance of Nuclear Power Plants."~~
6. **ASME OM Code, "Code for Operation and Maintenance of Nuclear Power Plants."** ~~APP-RXS-Z0R-001, Revision 2, "AP1000 Generic Pressure Temperature Limits Report," F. C. Gift, September 2008.~~

XII. Applicable STS Subsection After Incorporation of this GTST's Modifications

The entire subsection of the Specifications and the Bases associated with this GTST, following incorporation of the modifications, is presented next.

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.14 Low Temperature Overpressure Protection (LTOP)

LCO 3.4.14 At least one of the following overpressure protection methods shall be OPERABLE, with the accumulators isolated:

- a. The Normal Residual Heat Removal System (RNS) suction relief valve with lift setting within the limit specified in the PTLR, or
- b. The RCS depressurized and an RCS vent of ≥ 4.15 square inches.

-----NOTES-----

1. No reactor coolant pump (RCP) shall be started when the RCS temperature is $\geq 350^{\circ}\text{F}$ unless pressurizer level is $< 92\%$.
2. No RCP shall be started with any RCS cold leg temperature $\leq 350^{\circ}\text{F}$ unless the secondary side water temperature of each steam generator (SG) is $\leq 50^{\circ}\text{F}$ above each of the RCS cold leg temperatures and the RCP is started at $\leq 25\%$ of RCP speed.
3. Accumulator isolation is only required when accumulator pressure is greater than or equal to the maximum RCS pressure for the existing RCS cold leg temperature allowed by the P/T limit curves provided in the PTLR.

APPLICABILITY: MODE 4 when any cold leg temperature is $\leq 275^{\circ}\text{F}$,
MODE 5,
MODE 6 when the reactor vessel head is on.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. An accumulator not isolated when the accumulator pressure is greater than or equal to the maximum RCS pressure for existing cold leg temperature allowed in the PTLR.	A.1 Isolate affected accumulator.	1 hour
B. Required Action and associated Completion Time of Condition A not met.	B.1 Increase RCS cold leg temperature to a level acceptable for the existing accumulator pressure allowed in the PTLR.	12 hours
	<u>OR</u> B.2 Depressurize affected accumulator to less than the maximum RCS pressure for existing cold leg temperature allowed in the PTLR.	12 hours
C. Required LTOP method inoperable for reasons other than Condition A or B.	C.1 Restore the RNS suction relief valve to OPERABLE status.	12 hours
	<u>OR</u> C.2 Depressurize RCS and establish RCS vent of ≥ 4.15 square inches.	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.14.1 -----NOTE----- Only required to be met when accumulator pressure is greater than or equal to the maximum RCS pressure for the existing RCS cold leg temperature allowed by the P/T limit curves provided in the PTLR. ----- Verify each accumulator is isolated.</p>	12 hours
<p>SR 3.4.14.2 -----NOTE----- Only required to be met when complying with LCO 3.4.14.a. ----- Verify both RNS suction isolation valves in one RNS suction flow path are open.</p>	12 hours
<p>SR 3.4.14.3 -----NOTE----- Only required to be met when complying with LCO 3.4.14.b. ----- Verify RCS vent ≥ 4.15 square inches is open.</p>	12 hours for unlocked-open vent <u>AND</u> 31 days for locked-open vent

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.4.14.4 -----NOTE----- Only required to be met when complying with LCO 3.4.14.a. ----- Verify the lift setting of the RNS suction relief valve.</p>	<p>In accordance with the Inservice Testing Program</p>

B 3.4 REACTOR COOLANT SYSTEM (RCS)

B 3.4.14 Low Temperature Overpressure Protection (LTOP)

BASES

BACKGROUND LTOP limits RCS pressure at low temperatures so that the integrity of the reactor coolant pressure boundary (RCPB) is not compromised by violating the pressure and temperature (P/T) limits of 10 CFR 50, Appendix G (Ref. 1). The reactor vessel is the limiting RCPB component for demonstrating such protection. The PTLR provides the limits which set the maximum allowable setpoints for the Normal Residual Heat Removal System (RNS) suction relief valve. LCO 3.4.3 provides the maximum RCS pressure for the existing RCS cold leg temperature during cooldown, shutdown, and heatup to meet the Reference 1 requirements during the LTOP MODES.

The reactor vessel material is less tough at low temperatures than at normal operating temperature. As the vessel neutron exposure accumulates, the material toughness decreases and becomes less resistant to pressure stress at low temperatures (Ref. 2). RCS pressure, therefore, is maintained low at low temperatures and is increased only as temperature is increased.

The potential for vessel overpressurization is most acute when the RCS is water solid, occurring only while shutdown; a pressure fluctuation can occur more quickly than an operator can react to relieve the condition. Exceeding the RCS P/T limits by a significant amount could cause brittle cracking of the reactor vessel. LCO 3.4.3, "RCS Pressure and Temperature (P/T) Limits," requires administrative control of RCS pressure and temperature during heatup and cooldown to prevent exceeding the PTLR limits.

This LCO provides RCS overpressure protection by having a maximum coolant input capability and having adequate pressure relief capacity. Limiting coolant input capability requires isolating the accumulators. The pressure relief capacity requires the RNS suction relief valve or a depressurized RCS and an RCS vent of sufficient size. The RNS suction relief valve or the open RCS vent is the overpressure protection device that acts to terminate an increasing pressure event.

BASES

BACKGROUND (continued)

RNS Suction Relief Valve Requirements

During the LTOP MODES, the RNS system is operated for decay heat removal. Therefore, the RNS suction isolation valves are open in the piping from the RCS hot legs to the inlet of the RNS system. While these valves are open, the RNS suction relief valve is exposed to the RCS and able to relieve pressure transients in the RCS.

The RNS suction relief valve is a spring loaded, water relief valve with a pressure tolerance and an accumulation limit established by Section III of the American Society of Mechanical Engineers (ASME) Code (Ref. 3) for Class 2 relief valves.

The RNS suction isolation valves must be open to make the RNS suction relief valves OPERABLE for RCS overpressure mitigation.

RCS Vent Requirements

Once the RCS is depressurized, a vent exposed to the containment atmosphere will maintain the RCS at containment ambient pressure in an RCS overpressure transient, if the relieving requirements of the transient do not exceed the capabilities of the vent. Thus, the vent path must be capable of relieving the flow resulting from the limiting LTOP mass or heat input transient, and maintaining pressure below the P/T limits. The required vent capacity may be provided by one or more vent paths.

For an RCS vent to meet the flow capacity requirement, it may require removing one or more pressurizer safety valves or manually opening one or more Automatic Depressurization System (ADS) valves. The vent path(s) must be above the level of reactor coolant, so as not to drain the RCS when open.

APPLICABLE
SAFETY
ANALYSES

Safety analyses (Ref. 4) demonstrate that the reactor vessel is adequately protected against exceeding the Reference 1 P/T limits. In MODES 1, 2, and 3, and in MODE 4 with the RCS temperature above 275°F, the pressurizer safety valves will prevent RCS pressure from exceeding the Reference 1 limits. When the RNS is aligned and open to the RCS, overpressure protection is provided by the RNS suction relief valve, or a depressurized RCS and a sufficiently sized open RCS vent.

BASES

APPLICABLE SAFETY ANALYSES (continued)

The actual temperature at which the pressure in the P/T limit curve falls below the suction relief setpoint increases as the reactor vessel material toughness decreases due to neutron embrittlement. Each time the PTLR curves are revised, LTOP must be re-evaluated to ensure its functional requirements can still be met using the RNS suction relief valve, or the depressurized and vented RCS condition.

The PTLR contains the acceptance limits that define the LTOP requirements. Any change to the RCS must be evaluated against the Reference 4 analyses to determine the impact of the change on the LTOP acceptance limits.

Transients that are capable of overpressurizing the RCS are categorized as either mass or heat input transients. The events listed below were used in the analysis to size the RNS suction relief valve. Therefore, any events with a mass or heat input greater than the listed events cannot be accommodated and must be prevented.

Mass Input

Makeup water flow rate to the RCS assuming both CVS makeup pumps are in operation and letdown is isolated.

Heat Input

Restart of one reactor coolant pump (RCP) with water in the steam generator secondary side 50°F hotter than the primary side water, and the RCS water solid.

RNS Suction Relief Valve Performance

Since the RNS suction relief valve does not have a variable P/T lift setpoint, the analysis must show that with the chosen setpoint, the relief valve will pass flow greater than that required for the limiting LTOP transient while maintaining RCS pressure less than the lowest of the P/T limit curve pressure, 110% of the RNS design pressure, or the acceptable RNS relief valve inlet pressure. The current analysis shows that up to a temperature of 70°F, the mass input transient is limiting, and above this temperature the heat input transient is limiting.

BASES

APPLICABLE SAFETY ANALYSES (continued)

To prevent the possibility of a heat input transient, and thereby limit the required flow rate of the RNS suction relief valve, administrative requirements in the LCO note have been imposed for starting an RCP.

RCS Vent Performance

With the RCS depressurized, a vent size of 4.15 square inches is capable of mitigating a limiting overpressure transient. The area of the vent is equivalent to the area of the inlet pipe to the RNS suction relief valve so the capacity of the vent is greater than the flow possible with either the mass or heat input transient, while maintaining the RCS pressure less than the lower of either the maximum pressure on the P/T limit curve or 110% of the RNS design pressure.

The required vent area may be obtained by opening one ADS Stage 2, 3, or 4 flow path.

The RCS vent size will be reevaluated for compliance each time the P/T limit curves are revised based on the results of the vessel material surveillance.

The RCS vent is passive and is not subject to active failure.

LTOP satisfies Criterion 2 of 10 CFR 50.36(c)(2)(ii).

LCO

This LCO requires that LTOP is OPERABLE. LTOP is OPERABLE when the maximum coolant input and minimum pressure relief capabilities are OPERABLE. Violation of this LCO could lead to the loss of low temperature overpressure mitigation and violation of the Reference 1 limits as a result of an operational transient.

To limit the coolant input capability, the LCO requires all accumulator discharge isolation valves closed and immobilized, when accumulator pressure is greater than or equal to the maximum RCS pressure for the existing RCS temperature allowed in the PTLR.

BASES

LCO (continued)

The elements of the LCO that provide low temperature overpressure mitigation through pressure relief are:

- a. One OPERABLE RNS suction relief valve.

An RNS suction relief valve is OPERABLE for LTOP when both RNS suction isolation valves in one flow path are open, its setpoint is set within the PTLR (Ref. 5) limit, and testing has proven its ability to open at this setpoint; or

- b. A depressurized RCS and an RCS vent.

An RCS vent is OPERABLE when a vent path is open with a flow area of ≥ 4.15 square inches.

Each of these methods of overpressure prevention is capable of mitigating the limiting LTOP transient.

Note 1 prohibits startup of an RCP when the RCS temperature is $\geq 350^{\circ}\text{F}$ unless pressurizer level is $< 92\%$. This restraint is to prevent a low temperature overpressure event due to a thermal transient when an RCP is started.

Note 2 requires that the secondary side water temperature of each SG be $\leq 50^{\circ}\text{F}$ above each of the RCS cold leg temperatures before the start of an RCP with any RCS cold leg temperature $\leq 350^{\circ}\text{F}$, and the RCP must be started at $\leq 25\%$ of RCP speed. This restraint is to prevent a low temperature overpressure event due to a thermal transient when an RCP is started. This limitation also helps to ensure that the RNS system pressure remains below both the piping design pressure and the acceptable RNS relief valve inlet pressure.

Note 3 provides that accumulator isolation is only required when the accumulator pressure is more than or at the maximum RCS pressure for the existing temperature, as allowed by the P/T limit curves. This Note permits the accumulator discharge isolation valve closed position verification Surveillance to be performed only under these pressure and temperature conditions.

BASES

APPLICABILITY This LCO is applicable in MODE 4 when any cold leg temperature is below 275°F, MODE 5, and in MODE 6 when the reactor vessel head is on. The pressurizer safety valves provide overpressure protection that meets the Reference 1 P/T limits above 275°F. In MODE 6 with the reactor vessel head off, an overpressurization cannot occur.

LCO 3.4.3 provides the operational P/T limits for all MODES. LCO 3.4.6, "Pressurizer Safety Valves," requires the OPERABILITY of the pressurizer safety valves that provide overpressure protection during MODES 1, 2, and 3, and MODE 4 with the RNS isolated or RCS temperature $\geq 275^{\circ}\text{F}$.

Low temperature overpressure prevention is most critical during shutdown when the RCS is water solid, and a mass or heat input transient can cause a very rapid increase in RCS pressure with little or no time for operator action to mitigate the event.

ACTIONS

A.1, B.1, and B.2

An unisolated accumulator requires isolation within 1 hour. This is only required when the accumulator pressure is at or more than the maximum RCS pressure for the existing temperature allowed by the P/T limit curves.

If isolation is needed and cannot be accomplished in 1 hour, Required Action B.1 and Required Action B.2 provide two options, either of which must be performed in the next 12 hours. By increasing the RCS temperature to $> 275^{\circ}\text{F}$, the accumulator pressure cannot result in exceeding the LTOP limits if the accumulators are fully injected. Depressurizing the accumulators below the LTOP limit in the PTLR also gives this protection.

The Completion Times are based on operating experience that these activities can be accomplished in these time periods and on engineering evaluations indicating that an event requiring LTOP is not likely in the allowed times.

BASES

ACTIONS (continued)

C.1 and C.2

If the RNS suction relief valve is inoperable and the RCS is not depressurized, there is a potential to overpressurize the RCS and exceed the limits allowed in LCO 3.4.3. The suction relief valve is considered inoperable if the RNS isolation valves have isolated the RNS from the RCS in such a way that the suction relief valve cannot perform its intended safety function, or if the valve itself will not operate to perform its intended safety function. If the RCS is depressurized but the RCS vent path does not provide a flow area sufficient to mitigate any of the design low temperature overpressure events and the RNS suction relief valve is inoperable, there is a potential to overpressurize the RCS and exceed the limits allowed in LCO 3.4.3. The RCS vent path is considered inoperable if the area of the vent is not equivalent to the area of the inlet pipe to the RNS suction relief valve.

Under these conditions, Required Actions C.1 and C.2 provide two options, either of which must be accomplished in 12 hours. If the RNS suction relief valve cannot be restored to OPERABLE status, the RCS must be depressurized and vented with an RCS vent which provides a flow area sufficient to mitigate any of the design low temperature overpressure events.

The 12 hour Completion Time represents a reasonable time to repair the relief valve, open the RNS isolation valves or otherwise restore the LTOP to OPERABLE status, or depressurize and vent the RCS, without imposing a lengthy period when no LTOP methods are available to mitigate a low temperature overpressure event.

SURVEILLANCE
REQUIREMENTSSR 3.4.14.1

To minimize the potential for a low temperature overpressure event by limiting the mass input capability, the accumulator discharge isolation valves are verified closed and locked out. The Frequency of 12 hours is sufficient considering other indications and alarms available to the operator in the main control room to verify the required status of the equipment.

BASES

SURVEILLANCE REQUIREMENTS (continued)

SR 3.4.14.1 is modified by a Note stating that accumulator isolation is only required when the accumulator pressure is more than or at the maximum RCS pressure for the existing temperature, as allowed by the P/T limit curves. This Note requires the accumulator discharge isolation valve Surveillance to be met only under these pressure and temperature conditions.

SR 3.4.14.2

The RNS suction relief valve shall be demonstrated OPERABLE by verifying two RNS suction isolation valves in one flow path are open. This Surveillance is only performed if the RNS suction relief valve is being used to satisfy this LCO.

The RNS suction isolation valves are verified to be opened every 12 hours. The Frequency is considered adequate in view of other administrative controls such as valve status indications available to the operator in the control room that verify the RNS suction isolation valves remain open. This Surveillance is required to be met if the RNS suction relief valve is being used to satisfy the pressure relief requirements of LCO 3.4.14.a.

SR 3.4.14.3

The RCS vent of ≥ 4.15 square inches is verified open either:

- a. Once every 12 hours for a valve that is not locked (valves that are sealed or secured in the open position are considered "locked" in this context); or
- b. Once every 31 days for other vent path(s) (e.g., a vent valve that is locked, sealed, or secured in position or a removed pressurizer safety valve or open manway also fits this category).

This Surveillance is modified by a Note that states it is only required to be met if the vent is being used to satisfy the pressure relief requirements of LCO 3.4.14.b.

BASES

SURVEILLANCE REQUIREMENTS (continued)

SR 3.4.14.4

The RNS suction relief valve shall be demonstrated OPERABLE by verifying that two RNS suction isolation valves in one flow path are open and by testing it in accordance with the Inservice Testing Program. (Refer to SR 3.4.14.2 for the RNS suction isolation valve Surveillance.) This Surveillance is only required to be met if the RNS suction relief valve is being used to meet this LCO. The ASME OM Code (Ref. 6) test per Inservice Testing Program verifies OPERABILITY by proving proper relief valve mechanical motion and by measuring and, if required, adjusting the lift setpoint. This Surveillance is required to be met if the RNS suction relief valve is being used to satisfy the pressure relief requirements of LCO 3.4.14.a.

REFERENCES

1. Title 10, Code of Federal Regulations, Part 50, Appendix G, "Fracture Toughness Requirements."
 2. Generic Letter 88-11, "NRC Position on Radiation Embrittlement of Reactor Vessel Materials and Its Impact on Plant Operation."
 3. ASME Boiler and Pressure Vessel Code, Section III.
 4. FSAR Section 5.2.2, "Overpressure Protection."
 5. APP-RXS-Z0R-001, Revision 2, "AP1000 Generic Pressure Temperature Limits Report," F. C. Gift, September 2008.
 6. ASME OM Code, "Code for Operation and Maintenance of Nuclear Power Plants."
-