

NRR-PMDAPEm Resource

From: Becker, Cindy L <Cindy.Becker@flhealth.gov>
Sent: Monday, May 02, 2016 12:19 PM
To: Lamb, John
Subject: [External_Sender] Re: For State of Florida Comments - St. Lucie Unit 1 Snubber LAR

No comments from Florida. Thank you!

Sent from my iPhone

> On May 2, 2016, at 9:16 AM, "Lamb, John" <John.Lamb@nrc.gov> wrote:
>
> Ms. Becker,
>
> The U.S. Nuclear Regulatory Commission plans to issue an Amendment to Facility Operating License No. DPR-67 for St. Lucie Nuclear Plant, Unit 1 (St. Lucie) approximately on May 27, 2016, in response to the Florida Power & Light Company (FPL) application dated July 15, 2015 (Agencywide Documents and Access Management System (ADAMS) Accession No. ML15198A029), as supplemented by letters dated October 23, 2015 (ADAMS Accession No. ML15303A255), and January 28, 2016 (ADAMS Accession No. ML16053A097). See the attached letters to save searching through ADAMS.
>
> Specifically, the proposed amendments would revise Technical Specification (TS) 3/4.7.10, "Snubbers," Surveillance Requirement (SR) 4.7.10 to reference the newly added TSs Administrative Controls, Section 6.8.4.p, "Snubber Testing Program." This addition includes the planned revisions to the St. Lucie Unit 1 snubber inservice inspection (ISI) testing and service life monitoring programs, and removes the specific snubber inservice examination and testing requirements from TSs.
>
> Additionally, the licensee proposed to use a later Edition and Addenda of the American Society of Mechanical Engineers (ASME) Code for Operation and Maintenance of Nuclear Power Plants (OM Code), 2004 Edition thru 2006 Addenda for the remainder of the fourth 10-year ISI and testing of snubbers at St. Lucie Unit 1.
>
> If the State of Florida has any comments regarding these amendment requests, please e-mail me your comments by the close of business on May 23, 2016.
>
> Thanks.
> John
> 301-415-3100
>
> <LTR - 07-15-2015 - Snubber LAR.pdf>
> <LTR - 10-23-2015 - Admin RAI Response.pdf> <LTR - 01-28-2016 - RAI
> Response.pdf>

Hearing Identifier: NRR_PMDA
Email Number: 2813

Mail Envelope Properties (1B50BF74-CC6A-4E8C-A2D7-F73130089AF6)

Subject: [External_Sender] Re: For State of Florida Comments - St. Lucie Unit 1 Snubber LAR
Sent Date: 5/2/2016 12:18:40 PM
Received Date: 5/2/2016 12:18:47 PM
From: Becker, Cindy L

Created By: Cindy.Becker@flhealth.gov

Recipients:
"Lamb, John" <John.Lamb@nrc.gov>
Tracking Status: None

Post Office: flhealth.gov

Files	Size	Date & Time
MESSAGE	1861	5/2/2016 12:18:47 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: