

## CHAPTER 6

### ENGINEERED SAFETY FEATURES

#### TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
6.0	ENGINEERED SAFETY FEATURES.....	6.0-1
6.1	ENGINEERED SAFETY FEATURES MATERIALS .....	6.1-1
6.1.1.2	Fabrication Requirements.....	6.1-1
6.1.2.1.6	Quality Assurance Features .....	6.1-1
6.1.3	COMBINED LICENSE INFORMATION ITEMS.....	6.1-2
6.1.3.1	Procedure Review .....	6.1-2
6.1.3.2	Coating Program.....	6.1-3
6.1.4	REFERENCES .....	6.1-3
6.2	CONTAINMENT SYSTEMS .....	6.2-1
6.2.4.5.1	Preoperational Inspection and Testing .....	6.2-1
6.2.5.1	Design Basis.....	6.2-1
6.2.5.2.2	System Operation.....	6.2-2
6.2.6	COMBINED LICENSE INFORMATION FOR CONTAINMENT LEAK RATE TESTING .....	6.2-4
6.3	PASSIVE CORE COOLING SYSTEM .....	6.3-1
6.3.1.1.1	Emergency Core Decay Heat Removal.....	6.3-1
6.3.1.1.4	Safe Shutdown .....	6.3-2
6.3.1.1.6	Reliability Requirements .....	6.3-3
6.3.1.2	Non-Safety Design Basis.....	6.3-3
6.3.1.2.1	Post Accident Core Decay Heat Removal .....	6.3-3
6.3.1.3	Power Generation Design Basis.....	6.3-4
6.3.2.1	Schematic Piping and Instrumentation Diagrams.....	6.3-4
6.3.2.1.1	Emergency Core Decay Heat Removal at High Pressure and Temperature Conditions .....	6.3-4
6.3.2.2.5	Passive Residual Heat Removal Heat Exchanger.....	6.3-6
6.3.2.2.7	IRWST and Containment Recirculation Screens.....	6.3-6
6.3.2.2.7.1	General Screen Design Criteria .....	6.3-6
6.3.2.2.7.2	IRWST Screens .....	6.3-7
6.3.2.8	Manual Actions .....	6.3-7
6.3.3	PERFORMANCE EVALUATION .....	6.3-8
6.3.3.2.1.1	Loss of AC Power to the Plant Auxiliaries.....	6.3-9
6.3.3.4.1	Loss of Startup Feedwater During Hot Standby, Cooldowns, and Heat-ups .....	6.3-10
6.3.8	COMBINED LICENSE INFORMATION.....	6.3-10
6.3.8.1	Containment Cleanliness Program .....	6.3-10

## TABLE OF CONTENTS (Continued)

<u>Section</u>	<u>Title</u>	<u>Page</u>
6.4	HABITABILITY SYSTEMS .....	6.4-1
6.4.2.2	General Description .....	6.4-1
6.4.2.3	Component Description .....	6.4-1
6.4.2.6	Shielding Design .....	6.4-2
6.4.3	SYSTEM OPERATION .....	6.4-2
6.4.3.2	Emergency Mode .....	6.4-3
6.4.4	SYSTEM SAFETY EVALUATION .....	6.4-4
6.4.4.1	Dual Unit Analysis .....	6.4-5
6.4.4.2	Toxic Chemical Habitability Analysis .....	6.4-6
6.4.4.2.1	Onsite Chemicals .....	6.4-6
6.4.5.1	Preoperational Inspection and Testing .....	6.4-7
6.4.5.3	Air Quality Testing .....	6.4-7
6.4.7	COMBINED LICENSE INFORMATION .....	6.4-7
6.4.8	REFERENCES .....	6.4-8
6.5	FISSION PRODUCT REMOVAL AND CONTROL SYSTEMS .....	6.5-1
6.6	INSERVICE INSPECTION OF CLASS 2, 3, AND MC COMPONENTS .....	6.6-1
6.6.1	COMPONENTS SUBJECT TO EXAMINATION .....	6.6-1
6.6.2	ACCESSIBILITY .....	6.6-1
6.6.3	EXAMINATION TECHNIQUES AND PROCEDURES .....	6.6-2
6.6.3.1	Examination Methods .....	6.6-2
6.6.3.2	Qualification of Personnel and Examination Systems for Ultrasonic Examination .....	6.6-3
6.6.3.3	Relief Requests .....	6.6-3
6.6.4	INSPECTION INTERVALS .....	6.6-3
6.6.6	EVALUATION OF EXAMINATION RESULTS .....	6.6-4
6.6.9	COMBINED LICENSE INFORMATION ITEMS .....	6.6-4
6.6.9.1	Inspection Programs .....	6.6-4
6.6.9.2	Construction Activities .....	6.6-4
APP. 6A	FISSION PRODUCT DISTRIBUTION IN THE AP1000 POST-DESIGN BASIS ACCIDENT CONTAINMENT ATMOSPHERE .....	6A-1

## LIST OF TABLES

<u>Number</u>	<u>Title</u>
6.4-201	Input Values used in the Analysis of an Off-Site Chlorine Release
6.4-202	Main Control Room Habitability Evaluations of Onsite Toxic Chemicals
6.4-203	Loss of AC Power Heat Load Limits
6.4-204	Main Control Room Habitability Indications and Alarms

## LIST OF FIGURES

<u>Number</u>	<u>Title</u>
6.3-201	Passive Core Cooling System Piping and Instrumentation Diagram
6.4-201	Control Room and Control Room HVAC Intake Chlorine Concentrations at Wind Speed of 1 m/s

**CHAPTER 6****ENGINEERED SAFETY FEATURES****6.0 ENGINEERED SAFETY FEATURES**

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

## 6.1 ENGINEERED SAFETY FEATURES MATERIALS

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

---

### 6.1.1.2 Fabrication Requirements

---

Add the following information to the end of DCD Subsection 6.1.1.2

- STD COL 6.1-1 In accordance with Appendix B to 10 CFR Part 50, the quality assurance program establishes measures to provide control of special processes. One element of control is the review and acceptance of vendor procedures that pertain to the fabrication, welding, and other quality assurance methods for safety related component to determine both code and regulatory conformance. Included in this review and acceptance process are those vendor procedures necessary to provide conformance with the requirements of Regulatory Guides 1.31 and 1.44 for engineered safety features components as discussed in **DCD Section 6.1** and reactor coolant system components as discussed in **DCD Subsection 5.2.3**.
- 

#### 6.1.2.1.6 Quality Assurance Features

---

Replace the third paragraph under the subsection titled "Service Level I and Service Level III Coatings" within DCD Subsection 6.1.2.1.6 with the following information.

- STD COL 6.1-2 During the design and construction phase, the coatings program associated with selection, procurement, and application of safety related coatings is performed to applicable quality standards. The requirements for the coatings program are contained in certified drawings and/or standards and specifications controlling the coating processes of the designer (Westinghouse) (these design documents will be available prior to the procurement and application of the coating material by the constructor of the plant). Regulatory Guide 1.54 and ASTM D5144 (**Reference 201**) form the basis for the coatings program.

During the operations phase, the coatings program is administratively controlled in accordance with the quality assurance program implemented to satisfy 10 CFR Part 50, Appendix B, and 10 CFR Part 52 requirements. The coatings program provides direction for the procurement, application, inspection, and monitoring of safety related coating systems. Prior to initial fuel loading, a consolidated plant coatings program will be in place to address procurement, application, and monitoring (maintenance) of those coating system(s) for the life of the plant.

Coating system monitoring requirements for the containment coating systems are based on ASTM D5163 (Reference 202), "Standard Guide for Establishing Procedures to Monitor the Performance of Coating Service Level I Coating Systems in an Operating Nuclear Power Plant," and ASTM D7167 (Reference 203), "Standard Guide for Establishing Procedures to Monitor the Performance of Safety-Related Coating Service Level III Lining Systems in an Operating Nuclear Power Plant." Any anomalies identified during coating inspection or monitoring are resolved in accordance with applicable quality assurance requirements.

Include a new second paragraph under the subsection titled "Service Level II Coatings" within DCD Subsection 6.1.2.1.6 with the following information.

Such Service Level II coatings used inside containment are procured to the same standards as Service Level I coatings with regard to radiation tolerance and performance under design basis accident conditions as discussed below.

Replace the second sentence of the third paragraph under the subsection titled "Service Level II Coatings" within DCD Subsection 6.1.2.1.6 with the following information.

Coating system application, inspection, and monitoring requirements for the Service Level II coatings used inside containment will be performed in accordance with a program based on ASTM D5144 (Reference 201), "Standard Guide for Use of Protective Coating Standards in Nuclear Power Plants," and the guidance of ASTM D5163 (Reference 202), "Standard Guide for Establishing Procedures to Monitor the Performance of Coating Service Level I Coating Systems in an Operating Nuclear Power Plant." Any anomalies identified during coating inspection or monitoring are resolved in accordance with applicable quality requirements.

---

### 6.1.3 COMBINED LICENSE INFORMATION ITEMS

#### 6.1.3.1 Procedure Review

---

STD COL 6.1-1 This COL Item is addressed in Section 6.1.1.2.

---

6.1.3.2 Coating Program

---

STD COL 6.1-2 This COL Item is addressed in [Section 6.1.2.1.6](#).

---

The following information supplements the information provided in [DCD Subsection 6.1.4](#).

---

6.1.4 REFERENCES

---

201. ASTM D5144-08, "Standard Guide for Use of Protective Coating Standards in Nuclear Power Plants."
202. ASTM D5163-05a, "Standard Guide for Establishing Procedures to Monitor the Performance of Coating Service Level I Coating Systems in an Operating Nuclear Power Plant."
203. ASTM D7167-05, "Standard Guide for Establishing Procedures to Monitor the Performance of Safety-Related Coating Service Level III Lining Systems in an Operating Nuclear Power Plant."



---

## 6.2 CONTAINMENT SYSTEMS

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

---

### 6.2.4.5.1 Preoperational Inspection and Testing

---

Revise the second paragraph of DCD Subsection 6.2.4.5.1, Hydrogen Ignition Subsystem, to read as follows:

---

- WLS DEP 6.2-1 Pre-operational inspection is performed to verify the location of openings through the ceilings of the passive core cooling system valve/accumulator rooms with respect to the containment pressure boundary. The primary openings are those that constitute 98% of the opening area. The primary openings in Room 11206 that vent to Room 11300 are the equipment access opening and CMT-A opening. These openings are verified to be a minimum distance of 24.3 feet and 9.4 feet, respectively, from the containment shell. The primary opening in Room 11207 that vents to Room 11300 is the CMT-B opening, which is verified to be a minimum distance of 24.6 feet away from the containment shell. Other openings through the ceilings of these rooms are verified to be at least 3 feet from the containment shell.
- 

### 6.2.5.1 Design Basis

---

Add the following information at the end of DCD subsection 6.2.5.1, as identified in Appendix A to NuStart technical report AP-TR-NS01-A, Rev. 2, "Containment Leak Rate Test Program Description."

- STD COL 6.2-1 The Containment Leak Rate Test Program using 10 CFR Part 50, Appendix J Option B is established in accordance with NEI 94-01 (**DCD Subsection 6.2.7**, Reference 30), as modified and endorsed by the NRC in Regulatory Guide 1.163. **Table 13.4-201** provides milestones for containment leak rate testing implementation.
-

---

6.2.5.2.2 System Operation

---

Add the following information at the end of the subsection "Scheduling and Reporting of Periodic Tests" within DCD subsection 6.2.5.2.2, as identified in Appendix A to NuStart technical report AP-TR-NS01-A, Rev. 2, "Containment Leak Rate Test Program Description."

- STD COL 6.2-1 Schedules for the performance of periodic Type A, B, and C leak rate tests are in accordance with NEI 94-01, as endorsed and modified by Regulatory Guide 1.163, and described below:

Type A Tests

A preoperational Type A test is conducted prior to initial fuel load. If initial fuel load is delayed longer than 36 months after completion of the preoperational Type A test, a second preoperational Type A test shall be performed prior to initial fuel load. The first periodic Type A test is performed within 48 months after the successful completion of the last preoperational Type A test. Periodic Type A tests are performed at a frequency of at least once per 48 months, until acceptable performance is established. The interval for testing begins at initial reactor operation. Each test interval begins upon completion of a Type A test and ends at the start of the next test. The extension of the Type A test interval is determined in accordance with NEI 94-01.

Type A testing is performed during a period of reactor shutdown at a frequency of at least once per 10 years based on acceptable performance history. Acceptable performance history is defined as successful completion of two consecutive Type A tests where the calculated performance leakage rate was less than  $1.0 L_a$ . A preoperational Type A test may be used as one of the two Type A tests that must be successfully completed to extend the test interval, provided that an engineering analysis is performed to document why a preoperational Type A test can be treated as a periodic test. Elapsed time between the first and last tests in a series of consecutive satisfactory tests used to determine performance shall be at least 24 months.

Type B Tests (Except Containment Airlocks)

Type B tests are performed prior to initial entry into Mode 4. Subsequent periodic Type B tests are performed at a frequency of at least once per 30 months, until acceptable performance is established. The test intervals for Type B penetrations may be increased based upon completion of two consecutive periodic as-found Type B tests where results of each test are within allowable administrative limits. Elapsed time between the first and last tests in a series of consecutive satisfactory tests used to determine performance shall be 24 months or the nominal test interval (e.g., refueling cycle) for the component prior to implementing Option B of 10 CFR Part 50, Appendix J. An extended test interval for Type B tests may be increased to a specific value in a range of frequencies from greater than once per

30 months up to a maximum of once per 120 months. The extension of specific test intervals for Type B penetrations is determined in accordance with NEI 94-01.

#### Type B Tests (Containment Airlocks)

Containment airlock(s) are tested at an internal pressure of not less than  $P_{ac}$ . (Prior to a preoperational Type A test  $P_{ac} = P_a$ .) Subsequent periodic tests are performed at a frequency of at least once per 30 months. In addition, equalizing valves, door seals, and penetrations with resilient seals (i.e., shaft seals, electrical penetrations, view port seals and other similar penetrations) that are testable, are tested at a frequency of once per 30 months.

For periods of multiple containment entries where the airlock doors are routinely used for access more frequently than once every seven days (e.g., shift or daily inspection tours of the containment), door seals may be tested once per 30 days during this time period.

Airlock door seals are tested prior to a preoperational Type A test. When containment integrity is required, airlock door seals are tested within seven days after each containment access.

#### Type C Tests

Type C tests are performed prior to initial entry into Mode 4. Subsequent periodic Type C tests are performed at a frequency of at least once per 30 months, until adequate performance has been established. Test intervals for Type C valves may be increased based upon completion of two consecutive periodic as-found Type C tests where the result of each test is within allowable administrative limits. Elapsed time between the first and last tests in a series of consecutive passing tests used to determine performance shall be 24 months or the nominal test interval (e.g., refueling cycle) for the valve prior to implementing Option B of 10 CFR Part 50, Appendix J. Intervals for Type C testing may be increased to a specific value in a range of frequencies from 30 months up to a maximum of 60 months. Test interval extensions for Type C valves are determined in accordance with NEI 94-01.

#### Reporting

A post-outage report is prepared presenting results of the previous cycle's Type B and Type C tests, and Type A, Type B and Type C tests, if performed during that outage. The report is available on-site for NRC review. The report shows that the applicable performance criteria are met, and serves as a record that continuing performance is acceptable.

---

- STD COL 6.2-1 Add the following subsection at the end of DCD subsection 6.2.5.2.2, as identified in Appendix A to NuStart Technical Report AP-TR-NS01-A, Rev. 2, "Containment Leak Rate Test Program Description."

Acceptance Criteria

Acceptance criteria for Type A, B and C Tests are established in Technical Specification 5.5.8.

---

6.2.6 COMBINED LICENSE INFORMATION FOR CONTAINMENT LEAK  
RATE TESTING

---

- STD COL 6.2-1 This COL item is addressed in Subsections 6.2.5.1 and 6.2.5.2.2.
-

### 6.3 PASSIVE CORE COOLING SYSTEM

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

#### 6.3.1.1.1 Emergency Core Decay Heat Removal

---

Replace the first paragraph of DCD Subsection 6.3.1.1.1 with the following information.

WLS DEP 3.2-1 For postulated non-LOCA events, where a loss of capability to remove core decay heat via the steam generators occurs, the passive core cooling system is designed to perform the following functions for at least 72 hours:

Replace the bulleted list following the first paragraph of DCD Subsection 6.3.1.1.1 with the following information.

- WLS DEP 3.2-1
- The passive residual heat removal heat exchanger automatically actuates to provide reactor coolant system cooling.
  - The passive residual heat removal heat exchanger, in conjunction with the in-containment refueling water storage tank, condensate collection features and the passive containment cooling system, are designed to remove decay heat following a design basis event. Automatic depressurization actuation is not expected, but may occur depending on the amount of reactor coolant system leakage and when normal systems are recovered (refer to **Subsection 6.3.1.1.4**).
  - The passive residual heat removal heat exchanger is designed to maintain acceptable reactor coolant system conditions following a non-LOCA event. The applicable post-accident safety evaluation criteria are discussed in **Chapter 15**.
  - The passive residual heat removal heat exchanger is capable of performing its post-accident safety functions, assuming the steam generated in the in-containment refueling water storage tank is condensed on the containment vessel and returned by gravity via the in-containment refueling water storage tank condensate return gutter and downspouts.

---

WLS DEP 3.2-1 Deleted  
WLS DEP 6.3-1

- 
- During a steam generator tube rupture event, the passive residual heat removal heat exchanger removes core decay heat and reduces reactor coolant system temperature and pressure, equalizing with steam

generator pressure and terminating break flow, without overfilling the steam generator.

WLS DEP 3.2-1 System operation beyond 72 hours is described in [Subsection 6.3.1.2.1](#).

#### 6.3.1.1.4 Safe Shutdown

---

Replace DCD Subsection 6.3.1.1.4 with the following information.

WLS DEP 3.2-1 The functional requirements for the passive core cooling system specify that the plant be brought to a safe, stable condition using the passive residual heat removal heat exchanger for events not involving a loss of coolant. As stated in [Subsection 6.3.1.1.1](#), the passive residual heat removal heat exchanger in conjunction with the passive containment cooling system provides sufficient heat removal to satisfy the post-accident safety evaluation criteria for at least 72 hours. Additionally, the passive core cooling system, in conjunction with the passive containment cooling system and the automatic depressurization system, has the capability to establish long-term safe shutdown conditions in the reactor coolant system, as identified in [Subsection 7.4.1.1](#).

The core makeup tanks automatically provide injection to the reactor coolant system after they are actuated on low reactor coolant temperature or low pressurizer pressure or level. The passive core cooling system can maintain stable plant conditions for a long time in this mode of operation, depending on the reactor coolant leakage and the availability of ac power sources. For example, with a technical specification leak rate of 10 gpm, stable plant conditions can be maintained for at least 10 hours. With a smaller leak a longer time is available.

In scenarios when ac power sources are unavailable for approximately 22 hours, the automatic depressurization system automatically actuates. However, after the initial plant cooldown following a non-LOCA event, operators assess plant conditions and have the option to perform recovery actions to further cool and depressurize the reactor coolant system in a closed-loop mode of operation, i.e., without actuation of the automatic depressurization system. After verifying the reactor coolant system is in an acceptable, stable condition such that automatic depressurization is not needed, the operators may take action to extend the passive residual heat removal heat exchanger operation by de-energizing the loads on the Class 1E dc batteries powering the protection and monitoring system actuation cabinets. After operators have taken action to extend its operation, the passive residual heat removal heat exchanger, in conjunction with the passive containment cooling system, has the capability to maintain safe, stable conditions for at least 72 hours. The automatic depressurization system remains available to maintain safe shutdown conditions at a later time.

In most sequences the operators would return the plant to normal system operations and terminate passive system operation within several hours in accordance with the plant emergency operating procedures. For loss of coolant accidents, when the core makeup tank level reaches the automatic

depressurization system actuation setpoint and other postulated events where the passive residual heat removal heat exchanger operation is not extended or is exhausted, the automatic depressurization system may be initiated. This results in injection from the accumulators and subsequently from the in-containment refueling water storage tank, once the reactor coolant system is nearly depressurized. For these conditions, the reactor coolant system depressurizes to saturated conditions at about 250°F within 24 hours. The passive core cooling system can maintain this safe shutdown condition indefinitely for the plant, as identified in [Subsection 7.4.1.1](#).

The passive core cooling system functional requirements are met over the range of anticipated events and single failure assumptions. The primary function of the passive core cooling system during a safe shutdown using only safety-related equipment is to provide a means for boration, injection, and core cooling. Details of the safe shutdown design bases are presented in [DCD Subsection 5.4.7](#) and [DCD Section 7.4](#). The performance of the passive residual heat removal heat exchanger to bring the plant to 420°F in 36 hours is summarized in [Subsection 19E.4.10.2](#).

---

#### 6.3.1.1.6 Reliability Requirements

---

Replace the last sentence of DCD Subsection 6.3.1.1.6 with the following:

WLS DEP 3.2-1 [DCD Subsection 6.3.1.3](#) includes specific non-safety related design requirements that help to confirm satisfactory system reliability.

---

Add the following subsection after DCD Subsection 6.3.1.1.6.

DCD Subsection 6.3.1.2 is renumbered as Subsection 6.3.1.3.

#### 6.3.1.2 Non-Safety Design Basis

##### 6.3.1.2.1 Post Accident Core Decay Heat Removal

WLS DEP 3.2-1 The passive residual heat removal heat exchanger is designed to cool the reactor  
WLS DEP 6.3-1 coolant system to 420°F in 36 hours, with or without reactor coolant pumps operating. This allows the reactor coolant system to be depressurized and the stress in the reactor coolant system and connecting pipe to be reduced to low levels. This non-bounding, conservative evaluation is discussed in [Subsection 19E.4.10.2](#).

The passive residual heat removal heat exchanger, in conjunction with the in-containment refueling water storage tank, the condensate return features and the passive containment cooling system, has the capability to maintain the reactor

coolant system in the specified, long-term safe shutdown condition of 420°F for greater than 14 days in a closed-loop mode of operation. The automatic depressurization system can be manually actuated by the operators during the extended passive residual heat removal heat exchanger operation to initiate open-loop cooling. The operator actions necessary to achieve safe shutdown using the passive residual heat removal heat exchanger in a closed-loop mode of operation involve preventing unnecessary actuation of the automatic depressurization system as detailed in **DCD Subsection 7.4.1**.

Eventually, if pressurizer heaters are not available, the pressurizer sub-cools due to ambient heat loss. When this happens, the steam void within the pressurizer is transferred to the RCS. It has been determined that this condition is safe, so long as PRHR performance is not affected.

If PRHR performance is affected by sub-cooling (or other plant conditions) and non-safety systems to control core cooling are not reestablished, then the final, long term safe shutdown conditions may be achieved and maintained using ADS as discussed in **Subsection 7.4.1.1**.

WLS DEP 3.2-1 6.3.1.3 Power Generation Design Basis  
WLS DEP 6.3-1

6.3.2.1 Schematic Piping and Instrumentation Diagrams

Replace the first sentence of the first paragraph of DCD Subsection 6.3.2.1 with the following:

WLS DEP 3.2-1 **DCD Figure 6.3-1** shows the piping and instrumentation drawings of the passive  
WLS DEP 6.3-1 core cooling system.

6.3.2.1.1 Emergency Core Decay Heat Removal at High Pressure and Temperature Conditions

Replace the seventh and eighth paragraphs of DCD Subsection 6.3.2.1.1 with the following:

WLS DEP 3.2-1 The passive residual heat removal heat exchanger, in conjunction with the  
WLS DEP 6.3-1 in-containment refueling water storage tank, condensate return features and passive containment cooling system, can provide core cooling for at least 72 hours. After the in-containment refueling water storage tank water reaches its saturation temperature (in several hours), the process of steaming to the



containment initiates. Containment pressure will increase as steam is released from the in-containment refueling water storage tank. As containment temperature increases, condensation begins to form on the subcooled metal and concrete surfaces inside containment. Condensation on these heat sink surfaces transfers energy to the bulk metal and concrete until they come into equilibrium with the containment atmosphere. Condensation that is not returned to the in-containment refueling water storage tank drains to the containment sump.

Condensation occurs on the steel containment vessel, which is cooled by the passive containment cooling system. Most of the condensate formed on the containment vessel wall is collected in a safety-related gutter arrangement. A gutter is located near the operating deck elevation, and a downspout piping system is connected at the polar crane girder and internal stiffener, to collect steam condensate inside the containment during passive containment cooling system operation and return it to the in-containment refueling water storage tank. The gutter normally drains to the containment sump, but when the passive residual heat removal heat exchanger actuates, safety-related isolation valves in the gutter drain line shut and the gutter overflow returns directly to the in-containment refueling water storage tank. Recovery of the condensate maintains the passive residual heat removal heat exchanger heat sink for greater than 14 days.

---

Revise the first and second sentences of the ninth paragraph of DCD Subsection 6.3.2.1.1 as follows:

- WLS DEP 3.2-1 The passive residual heat removal heat exchanger is used to maintain an acceptable, stable reactor coolant system condition. It transfers decay heat and sensible heat from the reactor coolant system to the in-containment refueling water storage tank, the containment atmosphere, the containment vessel, and finally to the ultimate heat sink—the atmosphere outside of containment.

---

Revise the tenth paragraph to DCD Subsection 6.3.2.1.1 to read as follows:

- WLS DEP 3.2-1 The duration the passive residual heat removal heat exchanger can continue to remove decay heat is affected by the efficiency of the return of condensate to the in-containment refueling water storage tank. The in-containment refueling water storage tank water level is affected by the amount of steam that leaves the tank and does not return. Resources are typically recovered within 72 hours, which would allow the operators to place active, defense-in-depth systems into service and to terminate passive system operation. If resources are not recovered within this time frame, closed-loop cooling using the passive residual heat removal heat exchanger can be extended as described in **DCD Subsection 7.4.1.1** to maintain a safe, stable condition after a design basis event.

---

6.3.2.2.5 Passive Residual Heat Removal Heat Exchanger

Replace the third paragraph of DCD Subsection 6.3.2.2.5 with the following:

- WLS DEP 3.2-1 The passive residual heat removal heat exchanger is designed to remove sufficient heat so that its operation, in conjunction with available inventory in the steam generators, provides reactor coolant system cooling during loss of main feedwater or main feedline break events.
- 

---

6.3.2.2.7 IRWST and Containment Recirculation Screens

---

Replace the first paragraph of DCD Subsection 6.3.2.2.7 with the following:

- WLS DEP 3.2-1 The passive core cooling system has two different sets of screens that are used to prevent debris from entering the reactor and blocking core cooling passages during a LOCA: IRWST screens and containment recirculation screens. The screens are AP1000 Equipment Class C and are designed to meet seismic Category I requirements. The structural frames attachment to the building structure, and attachment of the screen modules use the criteria of ASME Code, Section III Subsection NF. The screen modules are fabricated of sheet metal and are designed and fabricated to a manufacturer's standard. The IRWST screens and containment recirculation screens are designed to comply with applicable licensing regulations including:
- GDC 35 of 10 CFR 50 Appendix A
  - Regulatory Guide 1.82
  - NUREG-0897
- 

---

6.3.2.2.7.1 General Screen Design Criteria

---

Insert the following at the beginning of DCD Subsection 6.3.2.2.7.1.

- WLS DEP 3.2-1 The IRWST screens and containment recirculation screens are designed to comply with the following criteria.
-

---

6.3.2.2.7.2 IRWST Screens

---

Replace the third paragraph of DCD Subsection 6.3.2.2.7.2 with the following:

- WLS DEP 3.2-1 During a LOCA, steam vented from the reactor coolant system condenses on the containment shell and drains down the shell to the polar crane girder or internal stiffener where it is drained via downspouts to the IRWST. Steam that condenses below the internal stiffener drains down the shell and is collected in a gutter near the operating deck elevation. It is very unlikely that debris generated by a LOCA can reach the downspouts or the gutter because of their locations. Each downspout inlet is covered with a coarse screen that prevents larger debris from entering the downspout. The gutter is covered with a trash rack which prevents larger debris from clogging the gutter or entering the IRWST through the two 4-inch drain pipes. The inorganic zinc coating applied to the inside surface of the containment shell is safety – Service Level I, and will stay in place and will not detach.
- 

---

6.3.2.8 Manual Actions

---

Replace the third paragraph of DCD Subsection 6.3.2.8 with the following information:

- WLS DEP 3.2-1 The operator can take action to avoid actuation of the automatic depressurization system when it is not needed. For non-LOCA events during which ac power has been lost for more than 22 hours, the protection and monitoring system will automatically open the automatic depressurization system valves to begin a controlled depressurization of the reactor coolant system and, eventually, containment floodup and recirculation prior to depletion of the actuation batteries. However, the operators can take action to block actuation of the automatic depressurization system should actuation be deemed unnecessary based on reactor coolant system conditions. This action allows closed loop passive residual heat removal heat exchanger operation to continue as long as acceptable reactor coolant system conditions are maintained.

**DCD Section 7.4** describes the anticipated operator actions to block the unnecessary automatic depressurization system actuation and to achieve recovery using available systems to remove decay heat. **DCD Section 7.5** describes the post-accident monitoring instrumentation available to the operator in the main control room following an event.

---

---

6.3.3 PERFORMANCE EVALUATION

---

Replace the seventh, eighth, and ninth paragraphs of DCD Subsection 6.3.3 with the following information.

WLS DEP 3.2-1 For non-LOCA events, the passive residual heat removal heat exchanger is actuated so that it can remove core decay heat. The passive residual heat removal heat exchanger can operate for at least 72 hours after initiation of a design basis event to satisfy Condition I, II, III and IV safety evaluation criteria described in the relevant safety analyses. **Subsection 6.3.3.2.1.1** provides an evaluation of the duration of the passive residual heat removal heat exchanger operation using the LOFTRAN code described in **DCD Subsection 15.0.11.2**. In this evaluation it is assumed that the operators power down the protection and monitoring actuation cabinets in the 22 hour time frame prior to the automatic timer actuating ADS.

In addition to mitigating the initiating events, the passive residual heat removal heat exchanger is capable of cooling the reactor coolant system to the specified safe shutdown condition of 420°F within 36 hours as described in **Subsection 19E.4.10.2**. A non-bounding, conservative analysis of the plant response during operator-initiated, extended operation of the passive residual heat removal heat exchanger is demonstrated in the shutdown temperature evaluation of **Subsection 19E.4.10.2**. The closed-loop cooling mode allows the reactor coolant system pressure to decrease and reduces the stress in the reactor coolant system and connecting pipe.

For loss of coolant accidents, the core makeup tanks deliver borated water to the reactor coolant system via the direct vessel injection nozzles. The accumulators deliver flow to the direct vessel injection line whenever reactor coolant system pressure drops below the tank static pressure. The in-containment refueling water storage tank provides gravity injection once the reactor coolant system pressure is reduced to below the injection head from the in-containment refueling water storage tank. The passive core cooling system flow rates vary depending upon the type of event and its characteristic pressure transient.

As the core makeup tanks drain down, the automatic depressurization system valves are sequentially actuated. The depressurization sequence establishes reactor coolant pressure conditions that allow injection from the accumulators, and then from the in-containment refueling water storage tank and the containment recirculation path. Therefore, an injection source is continually available. If onsite or offsite ac power has not been restored after 72 hours, the post-72 hour support actions described in **DCD Subsection 1.9.5.4** maintain this mode of core cooling and provide adequate decay heat removal for an unlimited time.

The transient analyses summarized in **DCD Chapter 15** are extended long enough to demonstrate the applicable safety evaluation criteria are met. It is expected that normal systems would be available such that operators could

terminate the passive safety systems and proceed with an orderly shutdown. However, as discussed in [Subsection 6.3.1.1.4](#), the passive systems are capable of bringing the plant to a safe, stable condition for at least 72 hours in closed loop cooling mode and for longer in an open loop mode.

---

#### 6.3.3.2.1.1 Loss of AC Power to the Plant Auxiliaries

---

WLS DEP 3.2-1 The most severe conditions resulting from a loss of ac power to the plant auxiliaries are associated with loss of offsite power with a loss of main feedwater system flow at full power. A loss of main feedwater with a loss of ac power lasting longer than a few hours presents the highest demand on passive residual heat removal heat exchanger operation. [DCD Subsection 15.2.6](#) provides a description of this short-term event, including criteria and analytical results.

During most events, the passive systems would be terminated in hours. When an ac power source is restored and passive core cooling system termination criteria are satisfied, the operator terminates passive core cooling system operation and initiates normal plant shutdown operations (as discussed in [Subsection 6.3.1.2.1](#)).

However, if normal systems are not recovered as expected, the passive residual heat removal heat exchanger removes core decay heat and maintains acceptable reactor coolant system conditions for at least 72 hours. For a non-loss of coolant accident event where ac power is lost, the automatic depressurization system will actuate in approximately 22 hours if operators do not act to avoid actuation when it is not needed. For this long-term transient, it is assumed operators extend passive residual heat removal heat exchanger operation as described in [DCD Subsection 7.4.1.1](#).

The loss of main feedwater with loss of ac power event is analyzed for a 72 hour period, assuming operators extend closed-loop cooling beyond the time the automatic depressurization system would be actuated by the protection and safety monitoring system. This event mirrors the loss of ac power to the plant auxiliaries as described in [DCD Subsection 15.2.6](#), but the loss of ac power extends to 72 hours. In this event, operation of the passive residual heat removal heat exchanger continues for 72 hours and maintains acceptable reactor coolant system conditions such that the applicable Condition II safety evaluation criteria are met. If non-safety systems capable of removing decay heat are not recovered, operator action to actuate ADS is eventually required. This condition would then be bounded by the Condition III event of inadvertent ADS actuation.

Reactor coolant system leakage could limit closed-loop capacity. A reactor coolant system leak could produce conditions that would preclude the operators from de-energizing the loads on the Class 1E batteries, or could require the operators

to re-energize the buses powered by the Class 1E batteries before 72 hours so that the automatic depressurization system valves could be actuated.

---

6.3.3.4.1 Loss of Startup Feedwater During Hot Standby, Cooldowns, and Heat-ups

Revise the last sentence of the fourth paragraph of DCD Subsection 6.3.3.4.1 to read as follows:

WLS DEP 6.3-1 This allows it to function as a heat sink for greater than 14 days, as discussed in **Subsection 6.3.1.2.1**.

---

6.3.8 COMBINED LICENSE INFORMATION

6.3.8.1 Containment Cleanliness Program

---

Insert the following information at the end of DCD Subsection 6.3.8.1:

This COL Item is addressed below.

STD COL 6.3-1 Administrative procedures implement the containment cleanliness program. Implementation of the program minimizes the amount of debris left in containment following personnel entry and exits. The program is consistent with the containment cleanliness program limits discussed in **DCD Subsection 6.3.8.1**. The program includes, as a minimum, the following:

Responsibilities

The program defines the organizational responsibilities for implementing the program; defines personnel and material controls; and defines the inspection and reporting requirements.

Implementation

Containment Entry/Exit

- Controls to account for the quantities and types of materials introduced into the containment.
- Limits on the types and quantities of materials, including scaffolding and tools, to ensure adequate accountability controls. This may be accomplished by the work management process. Storage of aluminum is prohibited without engineering authorization. Cardboard boxes or

miscellaneous packing material is not brought into containment without approval.

- If entries are made at power, prohibited materials and limits on quantities of materials that may generate hydrogen are established.
- Controls for loose items, such as keys and pens, which could be inadvertently left in containment.
- Methods and controls for securing any items and materials left unattended in containment.
- Administrative controls for accounting for tools, equipment, and other material are established.
- Administrative controls for accounting of the permanent removal of materials previously introduced into the containment.
- Limits on the types and quantities of materials, including scaffolding and tools, that may be left unattended in containment during outages and power operation. Types of materials considered are tape, labels, plastic film, and paper and cloth products.
- Requirements and actions to be taken for unaccounted for material.
- Requirements for final containment cleanliness inspections consistent with the design bases provided in [DCD Subsection 6.3.8.1](#).
- Recordkeeping requirements for entry/exit logs.

#### Housekeeping

Housekeeping procedures require that work areas be maintained in a clean and orderly fashion during work activities and returned to original conditions (or better) upon completion of work.

#### Sampling Program

A sampling program is implemented consistent with NEI Guidance Report 04-07, "Pressurized Water Reactor Sump Performance Evaluation Methodology," as supplemented by the NRC in the "Safety Evaluation by The Office of Nuclear Reactor Regulation Related to NRC Generic Letter 2004-02, Nuclear Energy Institute Guidance Report (Proposed Document Number NEI 04-07), 'Pressurized Water Reactor Sump Performance Evaluation Methodology.'" Latent debris sampling is implemented before startup. The sampling is conducted after containment exit cleanliness inspections to provide reasonable assurance that the plant latent debris design bases are met. Sampling frequency and scope may be

adjusted based on sampling results. Results are evaluated post-start up and any nonconforming results will be addressed in the Corrective Action Program.

---



## 6.4 HABITABILITY SYSTEMS

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

Revise the first sentence of the third paragraph of DCD Section 6.4 as follows:

- WLS DEP 6.4-1 If ac power is unavailable for more than 10 minutes or if "High-2" particulate or iodine radioactivity is detected in the main control room supply air duct, which would lead to exceeding General Design Criteria 19 operator dose limits, the protection and safety monitoring system automatically isolates the main control room and operator habitability requirements are then met by the main control room emergency habitability system (VES).

### 6.4.2.2 General Description

Revise the sixth paragraph of DCD Subsection 6.4.2.2 to read as follows:

- WLS DEP 6.4-2 In the unlikely event that power to the nuclear island nonradioactive ventilation system is unavailable for more than 72 hours, MCR habitability is maintained by operating one of the two MCR ancillary fans to supply outside air to the MCR such that the maximum average Wet Bulb Globe Temperature index for the control room is less than 90°F (32.2°C). See **Subsection 9.4.1** for a description of this cooling mode of operation. Doors and ducts may be opened to provide a supply pathway and an exhaust pathway. Likewise, outside air is supplied to division B and C instrumentation and control rooms in order to maintain the ambient temperature below the qualification temperature of the equipment.

### 6.4.2.3 Component Description

Revise the first paragraph of DCD Subsection 6.4.2.3 and add a new fourteenth bullet to read as follows:

- WLS DEP 6.4-2 The main control room emergency habitability system compressed air supply contains a set of storage tanks connected to a main and an alternate air delivery line and equipment to provide electrical load de-energization. Components common to both lines include a manual isolation valve and a pressure regulating valve. Single active failure protection is provided by the use of redundant, remotely operated isolation valves, which are located within the MCR pressure boundary. In the event of insufficient or excessive flow in the main delivery line, the main delivery line is isolated and the alternate delivery line is manually actuated. The alternate delivery line contains the same components as the main delivery line with the exception of the remotely operated isolation valves, and thus is capable of supplying compressed air to the MCR pressure boundary at the required air flowrate. The VES piping and penetrations for the MCR envelope are designated as equipment Class C. Additional details on Class C designation are provided in **DCD Subsection 3.2.2.5**. The classification of VES components is provided in **DCD Table 3.2-3**, as appropriate.

## WLS DEP 6.4-2 • MCR Load Shed Panels

The de-energization of the Main Control Room (MCR) electrical loads will be performed using Class 1E equipment. Equipment within each of the two electrical panels will be actuated from the "main control room isolation, air supply initiation and electrical load de-energization" engineered safety feature. The de-energization is separated into two stages to provide operators with the maximum available non-safety equipment, while maintaining the MCR heat load within the requirements of the VES.

Each electrical panel will have redundant relays and timers controlled by both PMS Division A and PMS Division C. Either division will be capable of actuating the timers and relays associated with each electrical panel independent of one another. This configuration prevents routine maintenance or single failures of a PMS cabinet from creating a spurious loss of MCR electrical loads, while still providing for single failure protection. In order to accomplish the "De-energize MCR Electrical Loads" function, one set of Stage 1 and Stage 2 timers in each electrical panel must receive the PMS command.

Relays in both electrical panels must be actuated in order to carry out the overall function; however, overall actuation may occur via different combinations of Division A and Division C commands.

## 6.4.2.6 Shielding Design

Revise DCD Subsection 6.4.2.6 to read as follows:

- WLS DEP 6.4-1 The design basis loss-of-coolant accident (LOCA) dictates the shielding requirements for the main control room. Main control room shielding design bases are discussed in [Section 12.3](#). In addition to shielding provided by building structural features, consideration is given to shielding provided by the VES filter shielding. Descriptions of the design basis LOCA source terms, main control room shielding parameters, and evaluation of doses to main control room personnel are presented in [Section 15.6](#).

The main control room and its location in the plant are shown in [Figure 12.3-1](#).

---

6.4.3 SYSTEM OPERATION

---

Add the following text at the end of DCD Subsection 6.4.3:

- STD COL 6.4-2 Generic Issue 83 addresses the importance of maintaining control room habitability following an accidental release of external toxic or radioactive material or smoke and the capability of the control room operators to safely control the reactor. Procedures and training for control room habitability are written in

accordance with [Section 13.5](#) for control room operating procedures, and [Section 13.2](#) for operator training. The procedures and training are verified to be consistent to the intent of Generic Issue 83.

The procedures and training address the toxic chemical events addressed in [Sections 2.2](#) and [6.4](#) consistent with the guidance provided in regulatory position C.5 of Regulatory Guide 1.78, including arrangements with Federal, State, and local agencies or other cognizant organizations for the prompt notification of the nuclear power plant when accidents involving hazardous chemicals occur within five miles of the plant. The procedures include the conduct of periodic surveys of stationary and mobile sources of hazardous chemicals affecting the evaluations consistent with the guidance provided in regulatory position 2.5 of Regulatory Guide 1.196. The procedures include appropriate reviews of the configuration of the control room envelope and habitability systems consistent with the guidance provided in regulatory position 2.2.1 of Regulatory Guide 1.196. The procedures also include periodic assessments of the control room habitability systems' materiel condition, configuration controls, safety analyses, and operating and maintenance procedures consistent with the guidance provided in regulatory position 2.2.1 of Regulatory Guide 1.196.

Procedures for testing and maintenance are consistent with the design requirements of the DCD including the guidance provided in regulatory position 2.7.1 of Regulatory Guide 1.196.

#### 6.4.3.2 Emergency Mode

Revise the first bullet of the first paragraph of DCD Subsection 6.4.3.2 to read as follows:

- WLS DEP 6.4-1 • “High-2” particulate or iodine radioactivity in the main control room supply air duct

Revise the first sentence of the second paragraph of DCD Subsection 6.4.3.2 to read as follows:

- WLS DEP 6.4-1 The nuclear island nonradioactive ventilation system is isolated from the main control room pressure boundary by automatic closure of the isolation devices located in the nuclear island nonradioactive ventilation system ductwork if radiation levels in the main control room supply air duct exceed the “High-2” setpoint or if ac power is lost for more than 10 minutes.

Revise the fifth paragraph of DCD Subsection 6.4.3.2 to read as follows:

- WLS DEP 6.4-2 The temperature and humidity in the main control room pressure boundary following a loss of the nuclear island nonradioactive ventilation system remain within limits for reliable human performance ([Reference 201](#)) over a 72-hour period. The bounding initial values of temperature/relative humidity in the MCR are 75°F/60 percent. The temperature/relative humidity values calculated during the 72 hours following a design basis accident equate to a maximum average Wet Bulb Globe Temperature index for the control room of less than 90°F (32.2°C).

The 90°F (32.2°C) Wet Bulb Globe Temperature index is the design limit for minimizing performance decrements and potential harm, and preserving well-being and effectiveness of the control room staff for an unlimited duration (Reference 201). Non-1E MCR heat loads are de-energized by PMS automatic actions and the 24 hour battery heat loads are terminated or exhausted at 24 hours to maintain the assumed heat load values in Table 6.4-203, which then maintains the occupied zone of the MCR and the zones containing qualified safety-related equipment within the temperature constraints at 72 hours post VES actuation. The occupied zone is considered to be the area between the raised floor and 7 ft. above the floor, which encompasses the reactor operator and senior reactor operator consoles.

6.4.4 SYSTEM SAFETY EVALUATION

Revise the third paragraph of DCD Subsection 6.4.4 to read as follows:

WLS DEP 6.4-1 Doses were determined for the following design basis:

	VES Operating	VBS Operating
Large Break LOCA	4.33 rem TEDE	4.84 rem TEDE
Fuel Handling Accident	1.5 rem TEDE	1.6 rem TEDE
Steam Generator Tube Rupture		
(Pre-existing iodine spike)	3.4 rem TEDE	4.0 rem TEDE
(Accident-initiated iodine spike)	1.0 rem TEDE	1.4 rem TEDE
Steam Line Break		
(Pre-existing iodine spike)	1.1 rem TEDE	0.9 rem TEDE
(Accident-initiated iodine spike)	1.3 rem TEDE	2.9 rem TEDE
Rod Ejection Accident	3.6 rem TEDE	2.5 rem TEDE
Locked Rotor Accident		
(Accident without feedwater available)	0.4 rem TEDE	0.7 rem TEDE
(Accident with feedwater available)	0.2 rem TEDE	0.9 rem TEDE
Small Line Break Outside Containment	0.4 rem TEDE	0.4 rem TEDE

Insert the following information at the end of the eighth paragraph of **DCD Subsection 6.4.4**.

STD COL 6.4-1 **Table 6.4-202** provides additional details regarding the evaluated onsite  
WLS COL 6.4-1 chemicals.

Revise the eleventh paragraph of DCD Subsection 6.4.4 to read as follows:

WLS DEP 6.4-2 During emergency operation, the main control room emergency habitability system passive heat sinks are designed to limit the temperature inside the main control room to remain within limits for reliable human performance (**Reference 201**) over 72 hours. The passive heat sinks limit the air temperature inside the instrumentation and control rooms to 120°F and dc equipment rooms to 120°F. The walls and ceilings that act as the passive heat sinks contain sufficient thermal mass to accommodate the heat sources from equipment, personnel, and lighting for 72 hours.

Revise the first bullet of the thirteenth paragraph of DCD Subsection 6.4.4 to read as follows:

WLS DEP 6.4-1 • “High-2” particulate or iodine radioactivity in MCR air supply duct

Revise the last sentence of the sixteenth paragraph of DCD Subsection 6.4.4 to read as follows:

WLS DEP 6.4-1 The following cases are evaluated since they involve releases that extend beyond 24 hours after the initiation of the event:

Large Break LOCA	4.4 rem TEDE
Steam Line Break	
(Pre-existing iodine spike)	1.2 rem TEDE
(Accident-initiated iodine spike)	2.0 rem TEDE

Add the following subsections at the end of DCD Subsection 6.4.4.

6.4.4.1 Dual Unit Analysis

STD SUP 6.4-1 Credible events that could put the control room operators at risk from a dose standpoint at a single AP1000 unit have been evaluated and addressed in the DCD. The dose to the control room operators at an adjacent AP1000 unit due to a

radiological release from another unit is bounded by the dose to control room operators on the affected unit. While it is possible that a unit may be downwind in an unfavorable location, the dose at the downwind unit would be bounded by what has already been evaluated for a single unit AP1000. Simultaneous accidents at multiple units at a common site are not considered to be a credible event.

---

#### 6.4.4.2 Toxic Chemical Habitability Analysis

WLS COL 6.4-1 Regulatory Guide 1.78 establishes the Occupational Safety and Health Association (OSHA) National Institute for Occupational Safety and Health (NIOSH) Immediately Dangerous to Life and Health (IDLH) guidelines for 30 minute exposure as the required screening criteria for airborne hazardous chemicals. See [Subsection 2.2.3.1.3.1](#) for discussion of screening of chemicals for potential impact to control room habitability.

[Subsection 2.2.3](#) indicates that a release of chlorine could potentially result in elevated concentrations at the control room intake. Therefore, an analysis of chlorine concentrations inside the control room was conducted using the methodology described in [Subsection 2.2.3.1.3.3](#), which discusses the hybrid modeling approach developed using the ALOHA and HABIT codes.

Chlorine is one of the most hazardous DOT approved chemicals, and was used to model a worst case DOT 2.3 release. Other chemicals that may be transported down the roadways are bounded by the properties of chlorine, and hence are precluded from further analysis.

Analyses have been performed to demonstrate that concentrations in the control room remain below the Regulatory Guide 1.78 toxicity limit for chlorine. Therefore, the implementation of control room protective measures is not required. Input values for the toxic gas analysis are summarized in [Tables 2.2-209](#) and [6.4-201](#).

[FSAR Figure 6.4-201](#) indicates the concentration of chlorine in the control room assuming no action is taken to isolate the control room envelope from outside air.

##### 6.4.4.2.1 Onsite Chemicals

[Table 6.4-202](#), Part B, identifies site specific chemicals (stored onsite) that are outside the scope of DCD evaluations. For these site specific chemicals, this table presents the chemical name, evaluated (initial) state, maximum quantity, distance to the main control room, and the evaluation outcome per standard plant definitions in Note a of the table.

As stated in [Subsection 2.2.3.1.1.4](#), the screening of these site specific chemicals identified two chemicals requiring further evaluation. Those chemicals are methoxypropylamine (MPA) and dimethylamine (DMA). While stored in aqueous solution form, the accidental spill of these liquids was evaluated as pools evaporating into the gaseous state. These two chemicals, when in gaseous state, are considered to be dense gases (more dense than air). Airborne concentrations

associated with the accidental spill and dispersion of these chemicals was evaluated with an appropriate dense gas dispersion modeling software that is capable of determining gas concentrations at an elevated control room intake receptor location, consistent with the design of the AP1000 plant. This evaluation demonstrates that concentrations at the elevated control room intake do not represent a toxic hazard to control room personnel.

---

#### 6.4.5.1 Preoperational Inspection and Testing

Revise the third paragraph of DCD Subsection 6.4.5.1 to read as follows:

- WLS DEP 6.4-2 Temperatures within the MCR where the operators are located are verified by analysis and/or testing to remain within limits for reliable human performance (Reference 201) for a 72-hour period following a bounding scenario with MCR isolation and non-safety ac power available (see Table 6.4-203) and a station blackout (battery backed loads only).

#### 6.4.5.3 Air Quality Testing

Revise DCD Subsection 6.4.5.3 as follows:

- WLS DEP 6.4-2 Connections are provided for sampling the air supplied from the compressed and instrument air system and for periodic sampling of the air stored in the storage tanks. Air samples of the compressed air storage tanks are taken quarterly and analyzed for acceptable air quality within the guidelines of Table 1 and Appendix C, Table C-1, of Reference 1 with a pressure dew point of 40°F or lower at 3400 psig or greater.
- 

#### 6.4.7 COMBINED LICENSE INFORMATION

---

- STD COL 6.4-1  
WLS COL 6.4-1 This COL Item is addressed in Subsections 2.2.3.1.1.4, 2.2.3.1.3, 2.2.3.1.4, 6.4.4, and 6.4.4.2.
- 

- STD COL 6.4-2 This COL Item is addressed in Subsection 6.4.3
-

## 6.4.8 REFERENCES

Add a new Reference 201 to DCD Subsection 6.4.8 as follows:

- WLS DEP 6.4-2 201. NUREG-0700, Revision 2, "Human-System Interface Design Review Guidelines," 2002.



TABLE 6.4-201  
INPUT VALUES USED IN THE ANALYSIS OF AN OFF-SITE  
CHLORINE RELEASE

WLS COL 6.4-1	Control Room Parameter	Value	Unit
	Control Room Volume	1011	m <sup>3</sup>
	Occupancy Factor	1	-
	Normal Mode Parameters		
	Intake Flow	0.31	m <sup>3</sup> /s

TABLE 6.4-202 (Sheet 1 of 4)  
 MAIN CONTROL ROOM HABITABILITY EVALUATIONS OF ONSITE TOXIC CHEMICALS<sup>(a)</sup>

	Evaluated Material	Evaluated State	Evaluated Maximum Quantity	Evaluated Minimum Distance to MCR Intake	Evaluated Location	MCR Habitability Impact Evaluation
A - STANDARD ONSITE TOXIC CHEMICALS						
STD COL 6.4-1	Hydrogen	Gas	500 scf	126.3 ft.	Yard at turbine building	MCR
	Hydrogen	Liquid	1,500 gal.	577 ft.	Gas storage	MCR
	Nitrogen	Liquid	3,000 gal.	577 ft.	Gas storage	MCR
	Carbon Dioxide (CO <sub>2</sub> )	Liquid	6 tons	577 ft.	Gas storage	MCR
	Oxygen Scavenger [Hydrazine]	Liquid	1,600 gal.	203 ft.	Turbine building	IH
	pH Addition [Morpholine] <sup>(b)</sup>	Liquid	1,600 gal.	203 ft.	Turbine building	IH
	Sulfuric Acid	Liquid	800 gal.	203 ft.	Turbine building	IH
	Sulfuric Acid	Liquid	20,000 gal.	436 ft.	CWS area	IH
	Sodium Hydroxide <sup>(b)</sup>	Liquid	800 gal.	203 ft.	Turbine building	S
	Sodium Hydroxide <sup>(b)</sup>	Liquid	20,000 gal.	436 ft.	CWS area	S
	Fuel Oil	Liquid	60,000 gal.	197 ft.	DG fuel oil storage tank, DG building, Annex building	IH
	Corrosion Inhibitor [Sodium Molybdate]	Liquid	800 gal.	203 ft.	Turbine building	S
	Corrosion Inhibitor [Sodium Molybdate]	Liquid	10,000 gal.	436 ft.	CWS area	S
	Scale Inhibitor [Sodium Hexametaphosphate] <sup>(b)</sup>	Liquid	800 gal.	203 ft.	Turbine building	S

TABLE 6.4-202 (Sheet 2 of 4)  
MAIN CONTROL ROOM HABITABILITY EVALUATIONS OF ONSITE TOXIC CHEMICALS<sup>(a)</sup>

Evaluated Material	Evaluated State	Evaluated Maximum Quantity	Evaluated Minimum Distance to MCR Intake	Evaluated Location	MCR Habitability Impact Evaluation
Scale Inhibitor [Sodium Hexametaphosphate] <sup>(b)</sup>	Liquid	10,000 gal.	436 ft.	CWS area	S
Biocide/Disinfectant [Sodium hypochlorite]	Liquid	800 gal.	203 ft.	Turbine building	S
Biocide/Disinfectant [Sodium hypochlorite]	Liquid	10,000 gal.	436 ft.	CWS area	S
Algaecide [Ammonium comp. polyethoxylate] <sup>(b)</sup>	Liquid	800 gal.	203 ft.	Turbine building	S
Algaecide [Ammonium comp. polyethoxylate] <sup>(b)</sup>	Liquid	10,000 gal.	436 ft.	CWS area	S
<b>B - SITE SPECIFIC ONSITE TOXIC CHEMICALS</b>					
pH Addition [60% aqueous solution of Methoxypropylamine]	Liquid	330 gal.	203 ft.	Turbine building	IH
pH Addition [5% aqueous solution of Dimethylamine]	Liquid	330 gal.	203 ft.	Turbine building	IH
Oxygen Scavenger [20% aqueous solution of Carbohydrazide] <sup>(c)</sup>	Liquid	330 gal.	203 ft.	Turbine building	S
Corrosion Inhibitor [42% aqueous solution of Sodium Bisulfite] <sup>(c)</sup>	Liquid	330 gal.	203 ft.	Turbine building	S

WLS COL 6.4-1

TABLE 6.4-202 (Sheet 3 of 4)  
 MAIN CONTROL ROOM HABITABILITY EVALUATIONS OF ONSITE TOXIC CHEMICALS<sup>(a)</sup>

Evaluated Material	Evaluated State	Evaluated Maximum Quantity	Evaluated Minimum Distance to MCR Intake	Evaluated Location	MCR Habitability Impact Evaluation
Scale Inhibitor [36% aqueous solution of Polyacrylate] <sup>(c)</sup>	Liquid	5,000 gal.	203 ft.	Turbine building	S
Biocide/Disinfectant [60% aqueous solution of Sodium Bromide] <sup>(c)</sup>	Liquid	5,000 gal.	203 ft.	Turbine building	S
Dispersant [36% aqueous solution of Polyacrylate] <sup>(c)</sup>	Liquid	Turbine building quantity bounded by evaluation of Polyacrylate for Scale Inhibitor			
pH Addition [100% aqueous solution of Sulfuric Acid]	Liquid	CWS area quantity bounded by STANDARD evaluation of Sulfuric Acid			
Sulfuric Acid [100% aqueous solution]	Liquid	CWS area quantity bounded by STANDARD evaluation of Sulfuric Acid			
Scale Inhibitor [36% aqueous solution of Polyacrylate] <sup>(c)</sup>	Liquid	5,000 gal.	436 ft.	CWS area	S
Biocide/Disinfectant [60% aqueous solution of Sodium bromide] <sup>(c)</sup>	Liquid	5,000 gal.	436 ft.	CWS area	S
Dispersant [36% aqueous solution of Polyacrylate] <sup>(c)</sup>	Liquid	CWS area quantity bounded by evaluation of Polyacrylate for Scale Inhibitor			

TABLE 6.4-202 (Sheet 4 of 4)  
MAIN CONTROL ROOM HABITABILITY EVALUATIONS OF ONSITE TOXIC CHEMICALS<sup>(a)</sup>

Evaluated Material	Evaluated State	Evaluated Maximum Quantity	Evaluated Minimum Distance to MCR Intake	Evaluated Location	MCR Habitability Impact Evaluation
Biocide/Disinfectant [6-16% aqueous solution of Sodium hypochlorite]	Liquid	CWS area quantity bounded by STANDARD evaluation of sodium hypochlorite.			
Sulfuric Acid [100% aqueous solution]	Liquid	Clarifier building quantity bounded by STANDARD evaluation of Sulfuric Acid.			
Biocide/Disinfectant [6-16% aqueous solution of Sodium hypochlorite]	Liquid	Clarifier building quantity bounded by STANDARD evaluation of sodium hypochlorite			

- STD COL 6.4-1 a) This table supplements **DCD Table 6.4-1**. Quantities are by largest evaluated container content for the evaluated location per unit. Quantities and distances are bounding evaluation values and may not be actual amounts and distances. Smaller quantities of a chemical at further distances from the MCR air intake are not shown on this table. Actual site locations are confirmed to be at or beyond the evaluated distance.
- S - Chemicals with an Impact Evaluation designation of "S" for the MCR Habitability Impact Evaluation were evaluated and screened out based on the chemical properties, distance, and quantities.
- IH - Chemicals with an Impact Evaluation designation of "IH" indicates the evaluation of this chemical considered the design detail of the main control room intake height.
- MCR - Chemicals with an Impact Evaluation designation of "MCR" indicates the evaluation of this chemical considered design details of the main control room such as volume, envelope boundaries, ventilation systems, and occupancy factor.
- 
- WLS COL 6.4-1 b) Lee does not intend to use these standard chemicals for the water treatment function at the indicated location; alternate site specific chemicals are specified as appropriate.
- c) Screening is based on the chemical properties alone and independent of quantity and distance to the Main Control Room HVAC intake. The listed concentration is the maximum concentration evaluated. Lowering concentrations in storage or in use would decrease the hazard of the identified chemicals.

WLS DEP 6.4-2

TABLE 6.4-203  
LOSS OF AC POWER HEAT LOAD LIMITS

Room Name	Room Numbers	Heat Load 0 to 24 Hours (Btu/sec)	Heat Load 24 to 72 Hours (Btu/sec)
MCR Envelope	12401	26.1 (Hour 0 through 0.5) 15.6 (Hour 0.5 through 3.5) 5.8 (Hour 3.5 through 24)	2.9
I&C Rooms	12301, 12305	8.8	0
I&C Rooms	12302, 12304	13.0	4.2
dc Equipment Rooms	12201, 12205	3.7 (Hour 0 through 1) 2.4 (Hour 2 through 24)	0
dc Equipment Rooms	12203, 12207	5.8 (Hour 0 through 1) 4.5 (Hour 2 through 24)	2.0

TABLE 6.4-204  
MAIN CONTROL ROOM HABITABILITY INDICATIONS AND ALARMS

WLS DEP 6.4-1

VES emergency air storage tank pressure (indication and low and low-low alarms)
VES MCR pressure boundary differential pressure (indication and high and low alarms)
VES air delivery line flowrate (indication and high and low alarms)
VES passive filtration flow rate (indication and high and low alarms)
VBS main control room supply air radiation level (High-1 and High-2 alarms)
VBS outside air intake smoke level (high alarm)
VBS isolation valve position
VBS MCR pressure boundary differential pressure

## 6.5 FISSION PRODUCT REMOVAL AND CONTROL SYSTEMS

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.



---

## 6.6 INSERVICE INSPECTION OF CLASS 2, 3, AND MC COMPONENTS

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

---

Add the following to DCD Section 6.6 ahead of Subsection 6.6.1 heading:

- STD COL 6.6-1 The initial inservice inspection program incorporates the latest edition and addenda of the ASME Boiler and Pressure Vessel Code approved in 10 CFR 50.55a(b) on the date 12 months before initial fuel load. Inservice examination of components and system pressure tests conducted during successive 120-month inspection intervals must comply with the requirements of the latest edition and addenda of the Code incorporated by reference in 10 CFR 50.55a(b) 12 months before the start of the 120-month inspection interval (or the optional ASME Code cases listed in Regulatory Guide 1.147, that are incorporated by reference in 10 CFR 50.55a(b), subject to the limitations and modifications listed in 10 CFR 50.55a(b)).
- 

### 6.6.1 COMPONENTS SUBJECT TO EXAMINATION

---

Add the following to the end of DCD Subsection 6.6.1:

- STD COL 6.6-1 Class 2 and 3 components are included in the equipment designation list and the line designation list contained in the inservice inspection program.
- 

### 6.6.2 ACCESSIBILITY

---

Revise the first and last sentences of the third paragraph in DCD Subsection 6.6.2 to add supplemental information as follows:

- STD SUP 6.6-1 Considerable experience has been drawn on in designing, locating, and supporting Quality Group B and C (ASME Class 2 and 3) and Class MC pressure-retaining components to permit pre-service and inservice inspection required by Section XI of the ASME Code. Factors such as examination requirements, examination techniques, accessibility, component geometry, and material selections are used in establishing the designs. The inspection design goals are to eliminate uninspectable components, reduce occupational radiation exposure, reduce inspection times, allow state-of-the-art inspection systems, and enhance detection and the reliability of flaw characterization. There are no Quality Group B

and C components or Class MC components, which require inservice inspection during reactor operation.

---

Add the following to the end of DCD Subsection 6.6.2:

- STD COL 6.6-2 During the construction phase of the project, anomalies and construction issues are addressed using change control procedures. Modifications reviewed following design certification adhere to the same level of review as the certified design per 10 CFR Part 50, Appendix B as implemented by the Westinghouse Quality Management System. The Quality Management System requires that changes to approved design documents, including field changes, are subject to the same review and approval process as the original design. This explicitly requires the field change process to follow the same level of review that was required during the design process. Accessibility and inspectability are key components of the design process.

Control of accessibility for inspectability and testing during post-design certification activities is provided via procedures for design control and plant modifications.

---

### 6.6.3 EXAMINATION TECHNIQUES AND PROCEDURES

---

Add the following Subsections 6.6.3.1, 6.6.3.2 and 6.6.3.3 to the end of DCD Subsection 6.6.3:

#### 6.6.3.1 Examination Methods

##### **Visual Examination**

- STD COL 6.6-1 Visual examination methods VT-1, VT-2 and VT-3 are conducted in accordance with ASME Section XI, IWA-2210. In addition, VT-2 examinations meet the requirements of IWA-5240.

Where direct visual VT-1 examinations are conducted without the use of mirrors or with other viewing aids, clearance is provided in accordance with Table IWA-2210-1.

##### **Surface Examination**

Magnetic particle test (MT), liquid penetrant test (PT), and eddy current examination techniques are performed in accordance with ASME Section XI, IWA-2221, IWA-2222, and IWA-2223 respectively. Direct examination access for MT and PT examination is the same as that required for direct visual (VT-1) examination (see Visual Examination), except that additional access is provided

as necessary to enable physical contact with the item in order to perform the examination. Remote MT and PT generally are not appropriate as a standard examination process; however, boroscopes and mirrors can be used at close range to improve the angle of vision.

### **Ultrasonic Examination**

Volumetric ultrasonic direct examination is performed in accordance with ASME Section XI, IWA-2232, which references mandatory Appendix I.

### **Alternative Examination Techniques**

As provided by ASME Section XI, IWA-2240, alternative examination methods, a combination of methods, or newly developed techniques may be substituted for the methods specified for a given item in this section, provided that they are demonstrated to be equivalent or superior to the specified method. This provision allows for the use of newly developed examination methods, techniques, etc., which may result in improvements in examination reliability and reductions in personnel exposure. In accordance with 10 CFR 50.55a(b)(2)(xix), IWA-2240 as written in the 1997 Addenda of ASME Section XI must be used when applying these provisions.

#### **6.6.3.2 Qualification of Personnel and Examination Systems for Ultrasonic Examination**

STD COL 6.6-1 Personnel performing examinations shall be qualified in accordance with ASME Section XI, Appendix VII. Ultrasonic examination systems shall be qualified in accordance with industry accepted programs for implementation of ASME Section XI, Appendix VIII.

#### **6.6.3.3 Relief Requests**

STD COL 6.6-1 The specific areas where the applicable ASME Code requirements cannot be met are identified after the examinations are performed. Should relief requests be required, they will be developed through the regulatory process and submitted to the NRC for approval in accordance with 10 CFR 50.55a(a)(3) or 50.55a(g)(5). The relief requests include appropriate justifications and proposed alternative inspection methods.

---

### **6.6.4 INSPECTION INTERVALS**

---

Add the following to the end of DCD Subsection 6.6.4:

STD COL 6.6-1 Because 10 CFR 50.55a(g)(4) requires 120-month inspection intervals, Inspection Program B of IWB-2400 must be chosen. The inspection interval is divided into three periods. Period one comprises the first three years of the interval, period two

comprises the next four years of the interval, and period three comprises the remaining three years of the inspection interval. The periods within each inspection interval may be extended by as much as one year to permit inspections to be concurrent with plant outages. The adjustment of period end dates shall not alter the rules and requirements for scheduling inspection intervals. It is intended that inservice examinations be performed during normal plant outages, such as refueling shutdown or maintenance shutdowns occurring during the inspection interval.

---

## 6.6.6 EVALUATION OF EXAMINATION RESULTS

---

Add the following new paragraph at the end of DCD Subsection 6.6.6:

- STD COL 6.6-1 Components containing flaws or relevant conditions and accepted for continued service in accordance with the requirements of IWC-3122.3 or IWC-3132.3 for Class 2 components, IWD-3000 for Class 3 components, IWE-3122.3 for Class MC components, or IWF-3112.2 or IWF-3122.2 for component supports, are subjected to successive period examinations in accordance with the requirements of IWC-2420, IWD-2420, IWE-2420, or IWF-2420, respectively. Examinations that reveal flaws or relevant conditions exceeding Table IWC-3410-1, IWD-3000, IWE-3000, or IWF-3400 acceptance standards are extended to include additional examinations in accordance with the requirements of IWC-2430, IWD-2430, or IWF-2430, respectively.

---

## 6.6.9 COMBINED LICENSE INFORMATION ITEMS

### 6.6.9.1 Inspection Programs

---

- STD COL 6.6-1 This COL Item is addressed in **Section 6.6** introduction, and in **Subsections 6.6.1, 6.6.3.1, 6.6.3.2, 6.6.3.3, 6.6.4, and 6.6.6.**

---

### 6.6.9.2 Construction Activities

---

- STD COL 6.6-2 This COL Item is addressed in **Subsection 6.6.2.**
-

APPENDIX 6A  
FISSION PRODUCT DISTRIBUTION IN THE AP1000 POST-DESIGN BASIS  
ACCIDENT CONTAINMENT ATMOSPHERE

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.