


* VALVE HEATERS REMOTE

1. (DELETE)
2. ALL STARTER AND CONTACTOR COILS TO BE QUALIFIED FOR CONTINUOUS DUTY AT 140F.
3. FOR WIRING DIAGRAM, SEE TELEMECHANIQUE DWG. WD-36333-A-01.
4. 50VA 480V 110V TYPE T-MTC CONTROL TRANSFORMER.
5. IEC/ECR 14-00140 APPROVED CHANGE OF AH-E-29B WITH SCN 200-47800 WHICH HAS FL AMP RATING OF 25 AND 1755 RPM.

36

THIS IS A COMPUTER
GENERATED DRAWING DO
NOT REVISE IT MANUALLY

Exelon®
Nuclear

R.J. Wassner		05/08/14
DRAWN		DATE
		4/13/14
CHECKER		DATE

N/R
RESPONSIBLE ENGINEER
DATE
ENGINEERING MANAGER
DATE

ELECTRICAL
480V. CONTROL CENTERS
1B ENGINEERED SAFEGUARDS

TMI-1

DWG. NO. 201-044

SHEET	REV.
3	36

SCALE: NONE

INTERFACING CONCURRENCE

NO.	DWG. NO.	TITLE
REFERENCES		