



REVISIONS		
REV	ZONE	DESCRIPTION
10	VARIES	REVISED TO INCORPORATE ECR 06-00067, REV.0

- NOTES
1. VALVE POSITIONS SHOWN FOR REFERENCE ONLY. ACTUAL POSITIONS CONTROLLED BY PROCEDURES.
 2. ALL INSTRUMENT TAG NUMBERS ARE PREFIXED BY SYSTEM DESIGNATOR UNLESS OTHERWISE NOTED.
 3. SET POINT VALUES FOR RELIEF VALVES ARE NOMINAL AND FOR REFERENCE ONLY. ACTUAL DATA CONTROLLED BY GMS2.
 4. NO SLOPE REQ'D ON THE WELDED PIPING ASSOCIATED WITH PENETRATIONS.
 5. SOLENOID VALVES AT PENETRATIONS WILL NOT HAVE MANUAL OVERRIDE.
 6. TUBING TO BE SLOPED 1/8" PER FOOT MINIMUM TOWARD HYDROGEN ANALYZER.
 7. FLOW IN THIS DIRECTION IS OVER SEAT. IS UNDER SEAT.
 8. NNS IS ABBREVIATION FOR NON-NUCLEAR SERVICE.

Cod File Name : 302674_R10	
NUCLEAR SAFETY RELATED	
THIS IS A COMPUTER GENERATED DRAWING DO NOT REVISE IT MANUALLY	
DESIGNED BY R. SCHABLE DATE 07/30/07	DRAWN BY MLC DATE 7/30/07
CHECKED BY DATE 7/30/07	APPROVED BY DATE 7/30/07
INTERFACING CONCURRENCE	
TMI-1	
DWG. NO. 302-674	SHEET REV. 10
SCALE: NONE	

NO.	DWG. NO.	TITLE
3	302-003	COMPONENT & SYS ID INDEX
2	302-002	SYMBOLS INSTRUMENTATION
1	302-001	SYMBOLS FLOW DIAGRAM
REFERENCES		