



- NOTES:
1. VALVE POSITION SHOWN FOR REFERENCE ONLY. ACTUAL POSITIONS CONTROLLED BY PROCEDURES.
 2. ALL INSTRUMENT TAG NUMBERS ARE PREFIXED BY SYSTEM DESIGNATOR UNLESS OTHERWISE NOTED.
 3. SET POINT VALUES FOR RELIEF VALVES TO BE FOUND IN THE APPLICABLE ENGINEERING SET POINT DATA BASE.
 4. ALL PIPING ON THIS DRAWING IS UNLESS NOTED.
 5. ALL PIPING ON THIS DRAWING IS NUCLEAR CLASS N-3 UNLESS NOTED.
 6. SEISMIC CLASS AS NOTED.
 7. ALL DRAINS AND LOCAL SAMPLES AFTER LAST VALVE SHALL BE S-II NON-NUCLEAR.
 8. ALLOY 20 PIPE PER ASTM B-464.
 9. INTERNALS OF VALVE WDL-V357 HAVE BEEN REMOVED.
 10. FOR REFERENCES SEE DWG 302-690.
 11. LEVEL TRANSMITTERS LT-128 AND LT-129 ALSO HAVE LOCAL INDICATING METERS INSTALLED.

NO.	DWG. NO.	REFERENCES
3	302-003	COMPONENT & SYS ID INDEX
2	302-002	SYMBOLS INSTRUMENTATION
1	302-001	SYMBOLS FLOW DIAGRAM

THIS IS A COMPUTER GENERATED DRAWING. DO NOT REVISE IT MANUALLY.

DATE: 10/01/07
DRAWN BY: [Signature]
CHECKED BY: [Signature]
DATE: 10/1/07

AmerGen

LIQUID WASTE DISPOSAL

SPENT RESIN COLLECTION & EVAPORATOR DISTILLATE

TM-1 SCALE: NONE BA NO. -

302-693

REV. 10