REVISIONS		
REV	ZONE	DESCRIPTION
49	E-3	REVISED TO INCORPORATE ECR-07-00174 REV. 1

NOTES

1. VALVE POSITIONS SHOWN FOR REFERENCE ONLY. ACTUAL POSITIONS CONTROLLED BY PROCEDURES.
2. ALL INSTRUMENT TAG NUMBERS ARE PREFIXED BY SYSTEM DESIGNATOR UNLESS OTHERWISE NOTED.
3. SET POINT VALUES FOR RELIEF VALVES TO BE FOUND IN THE APPLICABLE ENGINEERING SET POINT DATA BASE.
4. SYSTEM DESIGN BASIS SEISMIC CLASS 1.
5. NO INSULATION IN THE AUXILARY BUILDING.
6. FOR DESIGN CONDITIONS AND INSTRUMENTATION SEE B & W DWG. 26645F.
7. PENETRATION PROCESS PIPE IS SCHEDULE 80S.
8. BS3-LT IS ONLY A PRESSURE BOUNDARY, NOT A FUNCTIONAL COMPONENT.
9. THE DRAIN & FILL LINES ON EACH DANK CAN BE CONNECTED TO THE SUCTION & DISCHARGED OF A PORTABLE PUMP FOR PROVIDING RECIRCULATION PRIOR TO SAMPLING.
10. THE INTERNALS FROM VALVES BS-V-0023A & BS-V-0023B HAVE BEEN REMOVED.

NO.	DWG. NO.	REFERENCES
3	302-003	COMPONENT & SYS ID INDEX
2	302-002	SYMBOLS INSTRUMENTATION
1	302-001	SYMBOLS FLOW DIAGRAM

Cad File Name : 302712_R49

THIS IS A COMPUTER GENERATED DRAWING DO NOT REVISE IT MANUALLY.

AmerGen

REACTOR BUILDING SPRAY
FLOW DIAGRAM

DRAWN	DATE
MARK TETKOSKIE	12/20/07
CHECKED	DATE
	12/20/07
DESIGN MANAGER	DATE
N/A	
ENGINEER	DATE
N/A	
PROGRAMS MANAGER	DATE
	12/20/07
INTERFACING CONCURRENCE	

TMI-1 | DWG. NO. 302-712 | SH. - | REV. 49 | SCALE: NONE | BA NO.

DWG. NO. 302-712 SH -