










REVISIONS		
REV	ZONE	DESCRIPTION
42	G-4	REVISED TO INCORPORATE AN ADMINISTRATIVE REVISION. REF. AR 01644615. ADDED NOTE TO HIGHLIGHT VENDOR EQUIPMENT BOUNDARY.

DESIGN CONDITIONS					
FLAG	DESIGN PRESSURE 2400 PSIG	DESIGN TEMP. 100°F	SEISMIC CLASS III	CLEANLINESS B	GAS PIPING SPEC.
	150	100	III	B	(150-2)
	150	100	III	C	(150-1)
	650	100	III	C	(600-1)
	150	100	I EXCEPT AS NOTED	C	(150-1)
	650	100	I	B	(600-2)
	650	100	III	B	(600-2)
	150	100	III	B	(C-1)(CU)
	2400	100	I	B	
	150	100	I	C	(600-1)

B31.1-1955 SECTION 2 "INDUSTRIAL GAS AND AIR PIPING SYSTEM"

\*PER GAS QUALITY ACCEPTANCE STD. SP.-3550 FOR FIELD USE ONLY

**NOTES:**

1. VALVE POSITIONS SHOWN FOR REFERENCE ONLY. ACTUAL POSITIONS CONTROLLED BY PROCEDURES.
2. ALL INSTRUMENT TAG NUMBERS ARE PREFIXED BY SYSTEM DESIGNATOR UNLESS OTHERWISE NOTED.
3. SET POINT VALUES FOR RELIEF VALVES TO BE FOUND IN THE APPLICABLE ENGINEERING SET POINT DATA BASE.
4. P5653A AND P5653B ARE ABANDONED IN PLACE.

3	302-003	COMPONENT & SYS ID INDEX	DISPOSED	DATE	TMI-1	DWG. NO.	302-720	SH.	REV. 42
2	302-002	SYMBOLS INSTRUMENTATION	DISPOSABLE	DATE		SCALE: NONE			
1	302-001	SYMBOLS FLOW DIAGRAM	DISPOSABLE	DATE					
NO.	DWG. NO.	TITLE	INTERFACING CONCURRENCE			BA NO.			