



REV		ZONE	DESCRIPTION
20	C-3		REVISED TO (1) INCORPORATE ECR-07-00544 REV. 0 AND (2) TO INCORPORATE AN ADMINISTRATIVE REVISION.

SYSTEM DESIGN BASIS-SEISMIC CLASS I, EXCEPT AS NOTED.

NOTES:

1. VALVE POSITION SHOWN FOR REFERENCE ONLY. ACTUAL POSITIONS CONTROLLED BY PROCEDURES.
2. ALL INSTRUMENT TAG NUMBERS ARE PREFIXED BY SYSTEM DESIGNATOR UNLESS OTHERWISE NOTED.
3. SET POINT VALUES FOR RELIEF VALVES TO BE FOUND IN THE APPLICABLE ENGINEERING SET POINT DATA BASE.
4. ALL SUPPORT SYSTEMS ARE SEISMIC CLASS III UNLESS OTHERWISE NOTED.
5. NO INSULATION IS REQUIRED THROUGHOUT.
6. PENETRATION NO. 417 PROCESS PIPE IS SCH. 80.
7. PENETRATION NO. 414 PROCESS PIPE IS SCH. 40.
8. LEAK RATE TEST AIR DRYER IS SEISMICALLY RESTAINED (REF. ECM-63).
9. CAP CONFIGURATION IS ACCEPTABLE AND IS AN ALTERNATIVE CONFIGURATION FOR FLANGES UPSTREAM OF CHECK VALVES LR-V15 THRU LR-V23.
10. THE SPECTACLE FLANGE IS IN THE BLANK POSITION EXCEPT DURING ILRT.
11. LEAK RATE TEST VALVES ASSOCIATED WITH THE HYDROGEN RECOMBINER SYSTEM HAVE BEEN RELOCATED TO 302-722.

Cad File Name :302725\_R20

THIS IS A COMPUTER GENERATED DRAWING DO NOT RE-EDIT IT MANUALLY

MARK: TETKOSKIE 07/11/07  
DATE: 7/11/07  
BY: [Signature]  
CHECKED: [Signature]  
APPROVED: [Signature]

**AmerGen**

CONTAINMENT VESSEL LEAK RATE TEST FLOW DIAGRAM

NO.	DWG. NO.	TITLE	REFERENCES
3	302-003	COMPONENT & SYS ID INDEX	
2	302-002	SYMBOLS INSTRUMENTATION	
1	302-001	SYMBOLS FLOW DIAGRAM	

NO.	DWG. NO.	TITLE	REFERENCES
3	302-003	COMPONENT & SYS ID INDEX	
2	302-002	SYMBOLS INSTRUMENTATION	
1	302-001	SYMBOLS FLOW DIAGRAM	

NO.	DWG. NO.	TITLE	REFERENCES
3	302-003	COMPONENT & SYS ID INDEX	
2	302-002	SYMBOLS INSTRUMENTATION	
1	302-001	SYMBOLS FLOW DIAGRAM	

NO.	DWG. NO.	TITLE	REFERENCES
3	302-003	COMPONENT & SYS ID INDEX	
2	302-002	SYMBOLS INSTRUMENTATION	
1	302-001	SYMBOLS FLOW DIAGRAM	