

As of: 5/12/16 1:56 PM
Received: May 09, 2016
Status: Pending_Post
Tracking No. 1k0-8pj1-bxfr
Comments Due: May 16, 2016
Submission Type: Web

PUBLIC SUBMISSION

Docket: NRC-2012-0059

Incorporation by Reference of Revisions of ASME Regulatory Guides

Comment On: NRC-2012-0059-0001

Approval of American Society of Mechanical Engineers Code Cases

Document: NRC-2012-0059-DRAFT-0009

Comment on FR Doc # 2016-04355

Submitter Information

Name: Anonymous Anonymous

General Comment

Paragraph 3.2(i) of Code Case N-789 has a typographic error where it states ". . . piping designed to NC-2650, ND-3650. . . ." NC-2650 should be NC-3650. Code Case N-789-2 corrected this statement to read ". . . piping designed to NC-3650 or ND-3650. . . ." The use of this Code Case N-789 should be conditioned to require using the corrected language for paragraph 3.2(i) in N-789-2.