



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 16, 2016

Mr. Bryan C. Hanson
Senior Vice President
Exelon Generation Company, LLC
President and Chief Nuclear Officer (CNO)
Exelon Nuclear
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: CLINTON POWER STATION, UNIT NO. 1 – ACCEPTANCE REVIEW
CONCERNING SCRAM TIME TESTING (CAC NO. MF7559)(RS-16-046)

Dear Mr. Hanson:

By application dated April 4, 2016 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16095A285), Exelon Generation Company, LLC (EGC, the licensee) submitted a license amendment request for Clinton Power Station, Unit 1 (CPS). The proposed amendment supports allowing control rod scram time testing to be performed concurrently with inservice leak and hydrostatic testing. The purpose of this letter is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the technical specifications) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations. It is the NRC staff's understanding that this submittal also includes a non-credited volume (railroad bay) as part of the change to the analyses; however, the licensee is not requesting NRC review of that volume as it relates to any future extension of secondary containment to that volume.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff's ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. You will be advised of any further information needed to support the NRC staff's detailed technical review by separate correspondence.

B. Hanson

- 2 -

If you have any questions, please contact Ms. Eva Brown, at (301) 415-2315.

Sincerely,

/RA/

Eva A. Brown, Senior Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-461

cc: Distribution via Listserv

B. Hanson

- 2 -

If you have any questions, please contact Ms. Eva Brown, at (301) 415-2315.

Sincerely,

/RA/

Eva A. Brown, Senior Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-461

cc: Distribution via Listserv

DISTRIBUTION:

PUBLIC

RidsNrrDssStsb Resource

RidsNrrDorlLpIII-2 Resource

RidsNrrLASRohrer Resource

RidsNsrDssSrxs Resource

LPLIII-2 Reading File

RidsNrrDorl Resource

DWoodyatt, NRR

RGrover, NRR

RidsAcrcAcnw_MailCTR Resource

RidsNrrPMClinton Resource

RidsOgcMailCenter Resource

RidsRg3MailCenter Resource

ADAMS Accession No. ML16133A452

OFFICE	NRR/DORL/LPL3-2/PM	NRR/DORL/LPL3-2/LA	NRR/DORL/LPL3-2/B (A)
NAME	EBrown	SRohrer	GMiller
DATE	5/16/16	5/16/16	5/16/16

OFFICIAL RECORD COPY