

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 SCNEE1 200-00000-000 3411111 4 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

CON'T
01 REPORT SOURCE 1505000269 7020879 8022279 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
02 On February 6, 1979 Keowee Unit 2 was removed from service for maintenance,
03 and Technical Specifications required Unit 1 operability to be verified each
04 eight hours. Contrary to this, on February 8 Unit 1 was verified operable
05 eight hours ten minutes after the previous test. Since the unit would have
06 operated properly if required, the health and safety of the public were not
07 endangered.
08
09

SYSTEM CODE 11 EE 12 CAUSE CODE A 13 CAUSE SUBCODE A 14 COMPONENT CODE ZZZZZZ 15 COMP. SUBCODE Z 16 VALVE SUBCODE Z
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

17 LER/RO REPORT NUMBER 21 79 22 23 24 25 26 27 28 29 30
18 ACTION TAKEN H 19 FUTURE ACTION X 20 EFFECT ON PLANT 7 21 SHUTDOWN METHOD 7 22 HOURS 00000 23 ATTACHMENT SUBMITTED Y 24 NPRO-4 FORM SUB. N 25 PRIME COMP. SUPPLIER L 26 COMPONENT MANUFACTURER Z9999
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
10 Operations personnel inadvertently failed to perform the operability test
11 within the specified time period. The incident has been reviewed with the
12 personnel responsible and proper disciplinary action has been taken.
13
14

15 FACILITY STATUS E 16 % POWER 100 17 OTHER STATUS NA 18 METHOD OF DISCOVERY 19 DISCOVERY DESCRIPTION Operator Observation
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

16 RELEASED OF RELEASE Z 17 AMOUNT OF ACTIVITY NA 18 LOCATION OF RELEASE NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

17 PERSONNEL EXPOSURES NUMBER 000 18 TYPE Z 19 DESCRIPTION NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

18 PERSONNEL INJURIES NUMBER 000 19 DESCRIPTION NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 20 DESCRIPTION NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

20 PUBLICITY ISSUED N 21 DESCRIPTION NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

NAME OF PREPARER S. R. Lewis PHONE: (704) 373-8285

7902276401