

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7912130430 DOC. DATE: 79/11/23 NOTARIZED: NO  
 FACIL: 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.  
 AUTH. NAME: PARKER, W.O. AUTHOR AFFILIATION: Duke Power Co.  
 RECIP. NAME: O'REILLY, J.P. RECIPIENT AFFILIATION: Region 2, Atlanta, Office of the Director

DOCKET #  
05000287

SUBJECT: Discusses loss of power to integrated control sys during which cooldown limits were exceeded. Anticipates submission of RO-287/79-13 by 791130.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: Incident Reports

NOTES: M. CUNNINGHAM - ALL AMENDS TO FSAR & CHANGES TO TECH SPECS.

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL		LTTR	ENCL
	05 BC <u>ORB #4</u>	4	4			
INTERNAL:	01 <u>REG FILE</u>	1	1	02 NRC PDR	1	1
	09 I&E	2	2	11 MPA	3	3
	14 TA/EDO	1	1	15 NOVAK/KNIEL	1	1
	16 EEB	1	1	17 AD FOR ENGR	1	1
	18 PLANT SYS BR	1	1	19 I&C SYS BR	1	1
	20 AD PLANT SYS	1	1	22 REAC SAFT BR	1	1
	23 ENGR BR	1	1	24 KREGER	1	1
	25 PWR SYS BR	1	1	26 AD/SITE ANAL	1	1
	27 OPERA LIC BR	1	1	28 ACCIDENT ANALYS	1	1
	29 AUX SYS BR	1	1	E JORDAN/IE	1	1
	HANAUER, S.	1	1	STS GROUP LEADR	1	1
	TMI-H STREET	1	1			
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	29 ACRS	16	16			

DEC 17 1979

TOTAL NUMBER OF COPIES REQUIRED: LTTR 48 ENCL 0

no 4 up

DUKE POWER COMPANY  
POWER BUILDING  
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.  
VICE PRESIDENT  
STEAM PRODUCTION

November 23, 1979

TELEPHONE: AREA 704  
373-4083


Mr. James P. O'Reilly, Director  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Re: Oconee Unit 3  
Docket Number 50-287

Dear Mr. O'Reilly:

On November 10, 1979 your office was informed of an Oconee 3 incident involving a loss of power to the Integrated Control System. During the course of that incident, Reactor Coolant System cooldown limits were exceeded. Therefore a report was to have been submitted by November 23, 1979 pursuant to Oconee Nuclear Station Technical Specification 6.6.2.1.a(2). However, investigation of the incident has not been completed. It is anticipated that Reportable Occurrence Report RO-287/79-13 providing additional details of the incident will be submitted no later than November 30, 1979.

Very truly yours,

  
William O. Parker, Jr.

SRL:scs

cc: Director, Office of Management Information  
and Program Control

A002  
S  
110  
790178  
ORIGINAL COPY  
7912130 430  
S