REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8211090256 DOC.DATE: 82/11/01 NOTARIZED: NO DOCKET #
FACIL:50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
AUTH.NAME AUTHOR AFFILIATION
TUCKER,H.B. Duke Power Co.
RECIP.NAME RECIPIENT AFFILIATION
DENTON,H.R. Office of Nuclear Reactor Regulation, Director
STOLZ,J.F. Operating Reactors Branch 4

SUBJECT: Submits info re main steam line piping analysis performed as result of incident in RO-287/81-03 Revision 1 dtd 810610, in response to request,Max allowable stress determined to be 17,500 psi.

DISTRIBUTION CODE: A001S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 1
TITLE: OR Submittal: General Distribution

NOTES:AEOD/Ornstein:1cy, 05000287

	RECIPIENT ID CODE/NAME		COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME		COPIES LTTR	COPIES ENCL
	NRR ORB4 BC	01	7	7				
INTERNAL:	ELD/HDS4		1	0	NRR/DL DIR		1	1
	NRR/DL/ORAB		1	0	NRR/DSI/RAB		1	1
	REG FILE	04	1	1	RGN2		1	1
EXTERNAL:	ACRS	09	6	6	LPDR	03	1	1
	NRC PDR	02	1	1	NSIC	05	1	1
	NTIS		1	1				
NOTES:			1	1				

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 22

DUKE POWER COMPANY
P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

November 1, 1982

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

ATtention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4

Subject: Oconee Nuclear Station
Docket No. 50-287

Dear Sir:

In response to a telephonic request for information from Keith R. Wichman (ORAB), the following information is provided regarding the main steam line piping analysis performed as a result of an incident described in Reportable Occurrence Report RO-287/81-03 Revision 1 dated June 10, 1981. The information is provided to aid Mr. Wichman in his generic study of water filled main steam line piping. The information supplied is for Oconee Unit 3 only.

Analysis Method: A computer analysis was performed applying spring constants and pre-loads equal to the cold settings for spring supports.

Reference Code: B31.1 (1967)

Pressure/Temperature: 1050 psi/630°F

Maximum Stress/Location (Outside Containment as Requested): 11042 psi at Turbine Building Wall on "A" Side

Pipe Material at Maximum Stress Location: ASTM A-155, Class 1 GR KC 70, 34 inch ID, 1.164 inch Minimum Wall

Allowable Stress: 17500 psi

Very truly yours,

H.B. Tucker/JFN

Hal B. Tucker

JFN/php

A001