

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8703110165 DOC. DATE: 87/03/04 NOTARIZED: NO  
 FACIL: 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.  
 AUTH. NAME AUTHOR AFFILIATION  
 TUCKER, H. B. Duke Power Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

DOCKET #  
 05000287

SUBJECT: Submits info re steam generators, per Tech Spec 4.17.6(a).  
 Plugging of once-through steam generators (OTSG) completed  
 on 870217. OTSG A & OTSG B had 41 & 24 tubes removed from svc  
 by plugging, respectively.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2  
 TITLE: OR Submittal: General Distribution

NOTES: AEOD/Ornstein: 1cy.

05000287

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PWR-B EB	1 1	PWR-B PEICSB	2 2
PWR-B FOB	1 1	PWR-B PD6 LA	1 0
PWR-B PD6 PD 04	5 5	PASTIS, H	1 1
PWR-B PEICSB	1 1	PWR-B RSB	1 1
INTERNAL: ADM/LFMB	1 0	NRR/DHFT/TSCB	1 1
<del>NRR/GRAS</del>	1 0	OGC/HDS2	1 0
<u>REG FILE</u> 01	1 1		
EXTERNAL: EG&G BRUSKE, S	1 1	LPDR 03	1 1
NRC PDR 02	1 1	NSIC 05	1 1
NOTES:	1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 23 ENCL 19

DUKE POWER COMPANY

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

March 4, 1987


U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Subject: Oconee Nuclear Station, Unit 3  
Docket Nos. 50-287  
OTSG Tube Plugging

Gentlemen:

Pursuant to Oconee Nuclear Station Technical Specification 4.17.6(a), Duke Power Company is providing the following information concerning the Oconee Unit 3 steam generators. The steam generator plugging for the current Unit 3 outage was completed on February 17, 1987. The "A" OTSG had a total of forty-one (41) tubes removed from service by plugging. The "B" OTSG had a total of twenty-four (24) tubes removed from service by plugging.

Very truly yours,



Hal B. Tucker

PJN/138/jgm

8703110165 870304  
PDR ADOCK 05000287  
P PDR

A001  
1/1

Document Control Desk  
March 4, 1987  
Page 2

xc: Dr. J. Nelson Grace, Regional Administrator  
U.S. Nuclear Regulatory Commission - Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, GA. 30323

Ms. Helen Pastis  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Mr. J.C. Bryant  
NRC Resident Inspector  
Oconee Nuclear Station