

KHNPDCDRAIsPEm Resource

From: Ciocco, Jeff
Sent: Wednesday, May 18, 2016 1:01 PM
To: apr1400rai@khnp.co.kr; KHNPDCDRAIsPEm Resource; Jung-ho Kim (jhokim082@gmail.com); Andy Jiyong Oh; Christopher Tyree
Cc: Andrukat, Dennis; Dias, Antonio; Wunder, George; Williams, Donna
Subject: APR1400 Design Certification Application RAI 486-8597 (10.04.05 - Circulating Water System)
Attachments: APR1400 DC RAI 486 SPSB 8597.pdf

KHNP,

The attachment contains the subject request for additional information (RAI). This RAI was sent to you in draft form. Your licensing review schedule assumes technically correct and complete responses within 30 days of receipt of RAIs. However, KHNP requests, and we grant, 45 days to respond to this RAI. We may adjust the schedule accordingly.

Please submit your RAI response to the NRC Document Control Desk.

Thank you,

Jeff Ciocco
New Nuclear Reactor Licensing
301.415.6391
jeff.ciocco@nrc.gov



Hearing Identifier: KHNP_APR1400_DCD_RAI_Public
Email Number: 539

Mail Envelope Properties (e7496268515349359eef860cac45e936)

Subject: APR1400 Design Certification Application RAI 486-8597 (10.04.05 - Circulating Water System)
Sent Date: 5/18/2016 1:01:21 PM
Received Date: 5/18/2016 1:01:24 PM
From: Ciocco, Jeff

Created By: Jeff.Ciocco@nrc.gov

Recipients:

"Andrukat, Dennis" <Dennis.Andrukat@nrc.gov>
Tracking Status: None
"Dias, Antonio" <Antonio.Dias@nrc.gov>
Tracking Status: None
"Wunder, George" <George.Wunder@nrc.gov>
Tracking Status: None
"Williams, Donna" <Donna.Williams@nrc.gov>
Tracking Status: None
"apr1400rai@khnp.co.kr" <apr1400rai@khnp.co.kr>
Tracking Status: None
"KHNPDCDRAIsPEm Resource" <KHNPDCDRAIsPEm.Resource@nrc.gov>
Tracking Status: None
"Jungcho Kim (jhokim082@gmail.com)" <jhokim082@gmail.com>
Tracking Status: None
"Andy Jiyong Oh" <jiyong.oh5@gmail.com>
Tracking Status: None
"Christopher Tyree" <Christopher.tyree@aecon.com>
Tracking Status: None

Post Office: HQPWMSMRS07.nrc.gov

Files	Size	Date & Time
MESSAGE	608	5/18/2016 1:01:24 PM
APR1400 DC RAI 486 SPSB 8597.pdf		94368
image001.jpg	5040	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

REQUEST FOR ADDITIONAL INFORMATION 486-8597

Issue Date: 05/18/2016
Application Title: APR1400 Design Certification Review – 52-046
Operating Company: Korea Hydro & Nuclear Power Co. Ltd.
Docket No. 52-046
Review Section: 10.04.05 - Circulating Water System
Application Section: 10.4.5

QUESTIONS

10.04.05-2

10 CFR 52.47(a)(24) requires the Design Certification applicant to provide, "A representative conceptual design for those portions of the plant for which the application does not seek certification, to aid the NRC in its review of the FSAR and to permit assessment of the adequacy of the interface requirements in paragraph (a)(25) of this section."

DCD Tier 2, Section 10.4.5, "Circulating Water System," and Figure 10.4.5-1 show the circulating water pumps as conceptual design information. However, DCD Tier 2, Figure 3.2-1, "Classification of Structures, Systems, and Components," lists the circulating water pumps as non-conceptual.

The applicant is requested to clarify the conceptual design classification of the circulating water system (i.e., which portions and components are conceptual and which are non-conceptual part of the design certification). The applicant is also requested to modify the DCD for consistency with these clarifications.

