



Previously Westinghouse Homewood

820 WASHINGTON BOULEVARD
PITTSBURGH, PA 15206
(412) 665-2700
1-800-777-1172
FAX: (412) 665-2745

May 13, 2016

NRC Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Subject: Final Report

Homewood Products Corporation (HPC) is submitting this letter to close out a potential Part 21 from our initial report on December 23, 2015. A Part 21 was submitted to HPC by NTS and pertained to irradiation test services performed by Steris Isomedix Services for HPC motors. HPC had completed an evaluation on January 18, 2016 and submitted this evaluation to all of our clients.

HPC and client evaluations have concluded that no safety condition exists based on the reduced radiation levels. When we performed our qualification programs we irradiated to levels greater than customer requirements and additional margins were added as required in IEEE 323.

Regards,

A handwritten signature in black ink, which appears to read "Richard Martin", is positioned above the printed name.

Richard Martin
Quality Assurance Manager
Homewood Products Corporation
820 Washington Blvd.
Pittsburgh, PA 16206
Ph: 412-665-2719
Fax: 412-665-2761
dmartin@homewoodsales.com

IE19
NMSS