

## SummerRAIsPEm Resource

---

**From:** Gleaves, Bill  
**Sent:** Friday, June 17, 2016 9:58 AM  
**To:** SummerRAIsPEm Resource  
**Subject:** LAR 13-31 Talking Points for 6-30-16  
**Attachments:** LAR 13-31 Talking Points for 6-30-16.docx

For discussion with licensee at public meeting on June 30, 2016.

Billy  
William (Billy) Gleaves  
Lead Project Manager for  
V.C. Summer Units 2 and 3  
Licensing Branch 4  
US NRC, Office of New Reactors

The contents of this message may be sensitive. If this message has been received in error, please delete it without reading it. Your receipt of this message is not intended to waive any applicable privilege. Do not disseminate this message without the permission of the author. Communications by this author are not binding on The Commission.

**Hearing Identifier:** Summer\_COL\_eRAIs  
**Email Number:** 139

**Mail Envelope Properties** (d04d725c6e3242119103dd6fcf019f00)

**Subject:** LAR 13-31 Talking Points for 6-30-16  
**Sent Date:** 6/17/2016 9:58:27 AM  
**Received Date:** 6/17/2016 9:58:29 AM  
**From:** Gleaves, Bill

**Created By:** Bill.Gleaves@nrc.gov

**Recipients:**  
"SummerRAIsPEm Resource" <SummerRAIsPEm.Resource@nrc.gov>  
Tracking Status: None

**Post Office:** HQPWMSMRS02.nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	594	6/17/2016 9:58:29 AM
LAR 13-31 Talking Points for 6-30-16.docx		20777

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**

## **Talking Points**

**V.C. Summer LAR 13-31**

**“Relocation of Air Cooled Chiller Pump 3, VWS-MP-03”**

**06/17/2016**

- 1) The LAR discusses that the low capacity VWS performs defense-in-depth functions and is included within the scope of D-RAP. The staff would like to confirm whether the system is necessary or credited for providing cooling water to RTNSS ‘B’ SSCs post 72 hours.
- 2) The LAR states VWS-MP-03 is being relocated from the seismic Category I Auxiliary Building to the seismic Category II Annex Building. The staff notes that only portions of the Annex Building are seismic Category II. The staff would like to verify if Room 40500 is seismic Category II in its entirety.

In addition, the same sentence goes on to say the relocation does not have an adverse impact on any structure, system, or component. Is this referring to any SSC, including nonsafety-related SSCs located in the Annex Building, or a subset of SSCs that are safety-related or otherwise necessary for responding to anticipated transients or postulated accident conditions?

- 3) Potential editorial error: Page 7 of 11, first paragraph of Section 4.3. The last sentence states “...and involves associated changes to UFSAR Tier 2 information”. Should this be Tier 2\* information?
- 4) Although the staff would not expect aspects associated with updates to the plant-specific PRA due to the relocation of equipment to be part of this LAR, the staff would like to have a brief discussion on the use of “no impact” even when a small change to the model is required.